



ADDENDUM

Facilities Administration & Operations Section Office of Operations Administrative Services

Project No.	000315	Addendum No.: One (1)
File No.	591/08247.AGY	Issue Date: December 15, 2008
Project Name:	New Heating & Ventilation System Brighton Maintenance Garage	Sheet 1 of 1

This Addendum is issued to inform the bidder of a correction to the specifications.

Provide all labor, materials, equipment, services, and supervision as necessary to complete the work stated herein.

All costs associated with the work in this Addendum shall be included in the bid price and are considered part of the contract.

All other work shall be in accordance with the original bid documents.

I. Bid date has not been changed.

II. **Plans**

No Change.

III. **Specifications (Section 00100 – Instruction to Bidders (Item 21))**

The revised paragraph language is as follows:

CONTRACT AND CONTRACT AWARD: The Owner intends to award a Contract to the lowest responsible Bidder, provided the Bid has been submitted in accordance with the requirements of the Bidding Documents, and does not exceed the funds available. The lowest Bid will be based on the sum of the Base Bid and any additive or deductive Alternates the Owner accepts as listed in the Bid Summary Form. The Owner will accept an Alternate only if all other previously listed Alternates are also accepted. However, the award will comply with the Public Act 91 of 2005; businesses owned by Qualified Service-Disabled Veterans get a 10% pricing preference. "Service-Connected Disability" is defined as a disability incurred or aggravated in the line of duty in the active military, naval, or air service as described in 38 USC 101(16). "Qualified" means a business entity that is 51% or more owned by one or more veterans with a service-connected disability. The Contractor will be required to submit applicable bonds and insurance. Upon acceptance by the State, this document will constitute the Contract and the executed duplicate will be returned to the Contractor. The Contract, however, is not in force until the Contractor has complied with all of the requirements of insurance and bonds.

END OF ADDENDUM #1

ACKNOWLEDGE RECEIPT OF ADDENDUM #1 ON PROPOSAL

ADDENDUM

Facilities Administration & Operations Section Office of Operations Administrative Services

Project No.	000315	Addendum No.: Two (2)
File No.	591/08247.AGY	Issue Date: January 8, 2009
Project Name:	New Heating & Ventilation System Brighton Maintenance Garage	Sheet 1 of 1

This Addendum is issued to inform the bidder of a correction to the specifications.

Provide all labor, materials, equipment, services, and supervision as necessary to complete the work stated herein.

All costs associated with the work in this Addendum shall be included in the bid price and are considered part of the contract.

All other work shall be in accordance with the original bid documents.

IV. Bid date has not been changed.

V. **Plans**

A. **Disconnect Switch For Infra-Red Tube Heaters (Sheet 3) & Motorized Intake Louver Actuators (Sheet 4)**

Class 2510 (Type F) Manual Starter with Melting Alloy Type Thermal Overload Relay, 16 Amp Rated, Single Pole, Toggle Operator, Handle Guard/Lock-Off, Red Pilot Light, Nema Type 4 Enclosure, as Manufactured by Square-D (Model Number: FW1P) or Approved Equal.

B. **Rooftop Exhaust Fan "EF-2"**

Provide a Factory Installed Pre-Wired Disconnect Switch.

VI. **Specifications (Section 05120 – Structural Steel and Metal Fabrication)**

The Contractor shall hire the services of a professional engineer, who is licensed in the State of Michigan, to design the work items included under this section at no additional cost to Owner. Each work item shall be designed to safely support or resists all applicable loads in accordance with the "Michigan Building Code" (latest edition).

Note: Each set of submitted Shop Drawings must be signed and sealed by licensed professional engineer.

END OF ADDENDUM #2

ACKNOWLEDGE RECEIPT OF ADDENDUM #2 ON PROPOSAL