

ADDENDUM

Operations & Administrative Services Facilities Operations

Project No.	300001	Addendum No.: Two (2)
File No.	591/07246.AGY	Issue Date: February 6, 2009
Project Name:	New Chemical Storage Building Saginaw East Maintenance Garage	Sheet 1 of 2

This Addendum is issued to inform the bidder of a correction to the specifications.

Provide all labor, materials, equipment, services, and supervision as necessary to complete the work stated herein.

All costs associated with the work in this Addendum shall be included in the bid price and are considered part of the contract.

All other work shall be in accordance with the original bid documents.

I. General

There is no change in bid opening date and time.

II. Plans

Add the following notes to the notes shown on Site Plan (Sheet 2 of 7):

- 11.) The top of surface elevation of the new bituminous pavement at outside edges shall match the top of surface elevation of existing bituminous pavement or grade.
- 12.) The excavation limits equal the new bituminous pavement limits as shown on plan (e.g. 75' x 92').
- 13.) The work also includes saw cutting, removing, and legally disposing existing bituminous pavement off-site.
- 14.) Slope new bituminous pavement as follows:
 - a.) Away from building(s).
 - b.) To the east if new pavement is located between buildings.
 - c.) To prevent runoff from entering new building.
- 15.) See Specifications, Section 02741 (Bituminous Paving) for additional information and requirements.
- 16.) Bench Mark #1 (Elevation = 99.67')
(Location: Top of Concrete Frost Header of Ex. Salt Storage Building)

Project No.	300001	Addendum No.: Two (2)
File No.	591/07246.AGY	Issue Date: February 6, 2009
Project Name:	New Chemical Storage Building Saginaw East Maintenance Garage	Sheet 2 of 2

- 17.) The top of surface elevation of the new reinforced concrete slab (15'-0" x 30'-0") at the east and west edges shall match the top of surface elevation of the new bituminous pavement.

END OF ADDENDUM #2

ACKNOWLEDGE RECEIPT OF ADDENDUM #2 ON PROPOSAL