



### MONITORING PLAN FOR COMMUNITY WATER SUPPLIES – DISINFECTANTS AND DISINFECTION BYPRODUCTS (DDBP)

Issued under authority of 1976 PA 399 and Administrative Rules, as amended. Administrative Rule R 325.10719i requires a water supply to develop a monitoring plan. This form is provided as a convenience to the water supply to develop the plan.

#### Water Supply Information

Supply Name	_____	WSSN	_____
Address	_____	Population Served	_____
City, State, Zip	_____	County	_____

#### Contacts – Water Supply

Name and Title	_____	E-mail	_____	( )	_____	Telephone
Name and Title	_____	E-mail	_____	( )	_____	Telephone
Name and Title	_____	E-mail	_____	( )	_____	Telephone

#### Contacts – DEQ and Other

DEQ Drinking Water Analyst Name	_____	E-mail	_____	( )	_____	Telephone	
DEQ Drinking Water District Engineer Name	_____	E-mail	_____	( )	_____	Telephone	
Pollution Emergency Alerting System Information (PEAS)						1-800-292-4706	
Call PEAS number if unable to contact DEQ staff.						_____	Telephone
Local Official	_____	E-mail	_____	( )	_____	Telephone	
Local Official	_____	E-mail	_____	( )	_____	Telephone	
Health Department	_____	E-mail	_____	( )	_____	Telephone	

#### Public Notification

Means of Public Notification						
Newspaper Name and City	_____	E-mail	_____	( )	_____	Telephone
Radio/Television Name and Address or City	_____	E-mail	_____	( )	_____	Telephone

#### Laboratory

Primary Laboratory Name	_____	E-mail	_____	( )	_____	Telephone
Primary Lab Address, City, State, Zip						
Alternate Laboratory Name	_____	E-mail	_____	( )	_____	Telephone
Alternate Lab Address, City, State, Zip						

**Measure Chlorine Residual** (under normal operating conditions)

- This supply serves water disinfected with chlorine or chloramines. The residual disinfectant level must be measured at the same time and the same location as each total coliform compliance sample (includes all routine AND repeat total coliform samples).

**Monitor Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5)** (under normal operating conditions)

Samples will be collected during the:  1<sup>st</sup>  2<sup>nd</sup>  3<sup>rd</sup> full week of the

... peak historical month (month of highest byproduct formation): \_\_\_\_\_

... and during the same week every (check one):  90 days  1 year  3 years

... as indicated below:

Jan-Mar	Apr-Jun	Jul-Sep	Oct-Dec
<i>2nd full week of Feb. Example</i>	<i>2nd full week of May Example</i>	<i>2nd full week of Aug. Example</i>	<i>2nd full week of Nov. Example</i>

Sampling for compliance under Stage 2 begins (month and year): \_\_\_\_\_

**TTHM and HAA5 Sample Sites**

		Sample For...	Site Code	Address of Sample Site	Rationale for Selection
Routine Monitoring Sites	Reduced Monitoring Sites	<input type="checkbox"/> TTHM <input type="checkbox"/> HAA5	DBP__		
		<input type="checkbox"/> TTHM <input type="checkbox"/> HAA5	DBP__		
		<input type="checkbox"/> TTHM <input type="checkbox"/> HAA5	DBP__		
	<b>Sites above cannot be replaced with sites below. Contact the DEQ if a site is no longer available.</b>				
		<input type="checkbox"/> TTHM <input type="checkbox"/> HAA5	DBP__		
		<input type="checkbox"/> TTHM <input type="checkbox"/> HAA5	DBP__		

**Monitor Bromate** (under normal operating conditions)

- This supply uses ozone. This supply must collect 1 sample per month for bromate at the entry point (plant tap) of each treatment plant that uses ozone. The DEQ may reduce frequency from monthly to quarterly if the bromate running annual average (RAA) is  $\leq 0.0025$  mg/L (milligrams per liter) (2.5 parts per billion [ppb]).

**Schematic (optional)**

Check if a schematic is attached showing the sample sites in this monitoring plan.

**TTHM and HAA5 Operational Evaluation**

This supply must conduct an operational evaluation if either the TTHM or the HAA5 Operational Evaluation Level (OEL) exceeds the maximum contaminant level (MCL). This supply must submit the written report to the DEQ district office within 90 days after learning the result that causes the OEL to exceed the MCL. The OEL is an estimate of the following quarter's locational running annual average (LRAAs).  $OEL = 2 \text{ previous quarters results} + \text{twice the current quarter result, all divided by 4.}$

**TTHM and HAA5 Increased Monitoring**

A supply monitoring less frequently than quarterly must begin quarterly monitoring at all sites if any TTHM or HAA5 result is above the MCL at any site. Compliance with the MCL will be determined at the end of four consecutive quarters, including the quarter that triggered increased monitoring.

**Sample Site Plan Completed By**

_____	_____	_____
Name	Title	Date
_____	_____	(      )
Signature	E-mail	Telephone

**Compliance Calculation Procedures on following page.**

## **Compliance Calculation Procedure**

### **General**

Where compliance is based on an RAA of monthly or quarterly samples or averages and the supply fails to monitor for TTHM, HAA5, or bromate, this failure will be treated as a monitoring violation for the entire period covered by the RAA.

All samples taken and analyzed from compliance sites must be included in determining compliance, even if that number is greater than the minimum required.

If any individual quarter's average will cause the RAA of that supply to exceed the MCL, the supply is out of compliance at the end of that quarter.

### **Chlorine**

Chlorine maximum residual disinfectant level (MRDL) is 4.0 mg/L.

Compliance with the MRDL is based on an RAA, computed quarterly, of monthly averages of all measurements taken at the same place and time as total coliform compliance samples.

In cases where supplies switch between the use of chlorine and chloramines during the year, compliance will be based on all monitoring results of both chlorine and chloramines.

### **TTHM and HAA5**

TTHM MCL is 0.080mg/L (80 ppb). HAA5 MCL is 0.060 mg/L (60 ppb).

Compliance with each MCL is based on the LRAA for TTHM and HAA5 at each location. If one location is out of compliance with the MCL, then the supply is out of compliance.

If monitoring annually or less frequently and no sample exceeds the MCL, the sample result for each monitoring location is considered the LRAA for that monitoring location. If a sample exceeds the MCL, the supply shall increase monitoring to a dual sample set at each location every 90 days and calculate compliance at the end of four quarters, including the quarter in which the sample exceeded the MCL.

If monitoring quarterly, the LRAA is calculated quarterly using results from each location. If the supply fails to complete four consecutive quarters of monitoring, compliance with the MCL will be based on the average of available data from the most recent four quarters. If the supply takes more than one sample per quarter at a monitoring location, an average of all samples taken in the quarter at that location will be used to determine the LRAA.

The supply is in violation of the MCL when the LRAA exceeds the MCL, based on four consecutive quarters of monitoring, or the LRAA calculated based on fewer than four quarters of data if the MCL would be exceeded regardless of the monitoring results of subsequent quarters. The supply is in violation of the monitoring requirements for each quarter that a result would be used in calculating an LRAA if the supply fails to monitor.

### **Bromate (for supplies using ozone)**

Bromate MCL is 0.010 mg/L (10 ppb).

Compliance is based on an RAA of the most recent four quarters, computed quarterly, of monthly samples (or for months in which the supply takes more than one sample, the average of all samples taken during the month). If the average of samples covering any consecutive four-quarter period exceeds the MCL, the supply is in violation of the MCL and must notify the public, in addition to reporting to the DEQ. If a supply fails to complete 12 consecutive months of monitoring, compliance with the MCL for the last four-quarter compliance period is based on an average of the available data.