



## LIQUEFIED PETROLEUM GAS INSPECTION CHECKLIST

INSTRUCTIONS: The Hazardous Materials Storage Inspector shall complete this checklist and attach it to an inspection report, one to be retained in the District file and one for the Headquarters file. All boxes shall be completed inserting N/A where non-applicable.	
FACILITY NAME:	FACILITY ID NUMBER:
CONTACT PERSON ON SITE:	FACILITY TYPE:

### FACILITY SECTION

SECTION	DESCRIPTION	CODE	VIO	PASS
1.9.1	DEPARTMENT APPROVAL BEFORE INSTALLED	L126		
4.3.2	NOTIFY DEPARTMENT OF TEMP INSTALLS	L10		
4.4.1	PERSONAL TRAINING	L128		
4.4.2	PERSONAL TRAINING AT DISPENSER STATIONS	L130		
5.2.6.1	CYLS ON DOCK OR IN TRANSIT ARE CAPPED	L132		
5.7.7	VALVES MUST COMPLY WITH TABLES	L22		
5.8.1.5	LIQUID & VAPOR LABELING FOR PIPING	L54		
5.10.4	ESV W/REMOTE & THERMAL SHUTOFF	L30		
5.8.6.4	APPROVED HOSE (PROPERLY MARKED)	L32		
6.15.4	STRAINER INSTALLED AND ABLE TO CLEAN	L36		
6.5.4	POINT OF TRANSFER BY TABLE 6.5.3	L104		
6.4.5.2	COMBUSTIBLE MATERIALS WITHIN 10'	L46		
6.8.3.5	THREADED PIPING MUST BE SCHEDULE 80	L58		
6.8.3.10	PIPING SUPPORTED & PROTECTED	L60		

SECTION	DESCRIPTION	CODE	VIO	PASS
6.8.7.2	FLEXIBLE CONNECTORS/HOSE MAX 36"	L62		
6.10.8.1	BULKHEADS OF STEEL OR CONCRETE	L66		
6.10.1	ESV INSTALLED	L134		
6.11	HYDROSTATIC RELIEF FOR PIPING	L68		
6.15.5	PUMP & METER INSTALLATION	L70		
6.16.5	TAMPERING PROTECTION	L80		
6.20.2.1	ELECTRICAL INSPECTOR APPROVAL	L90		
6.22.3.5	HOSE PROTECTION-ESV, BACK CHECK, EXCESS FLOW	L38		
6.22.4.2	SELF SERVE BREAKAWAY	L78		
6.23.4.2	FIRE EXTINGUISHER 18#	L96		
5.2.6.1	VALVE PROTECTION @ DIST POINTS	L112		
6.3.1	EXCHANGE CYL LOCATION TO BLDG	L142		
10.2.2	CYL FILL BUILDING VENT SIZES	L120		
	OTHER			

### TANK SECTION

SECTION	DESCRIPTION	CODE	VIO	PASS
5.2.8.3	CONTAINER DESIGN/MARKING	L18		
5.7.2.1	PRESSURE RELIEF DEVICES FOR TANKS	L20		
5.7.8.3	FIXED LIQUID LEVEL GAUGE 12/31/65	L24		
5.7.8.9	VARIABLE LIQUID GAUGE	L26		
6.3.1	LOCATION OF CONTAINER	L44		
6.6.1.7	CONTAINER PROTECTION 4" SCH 40 W/CONCRETE 5' ON CTR	L122		
6.6.3.1	CONTAINER SUPPORTS & PROTECTION	L48		

SECTION	DESCRIPTION	CODE	VIO	PASS
6.7.2.4	RAIN CAPS	L50		
6.7.2.7	7' RELIEF STACKS ON 2000 GAL TANKS	L52		
5.7.7.4	PRESSURE GAUGE OVER 2000 GAL	L56		
6.14.1(d)	CATHODIC PROTECTION RECORDS	L136		
6.14.1	CATHODIC PROTECTION UNDERGROUND	L136		
7.2.2.5.1(a)	3" NO SMOKING – NO OPEN FLAMES	L138		
7.2.2.5.1(b)	WARNING LABEL FOR NON-FILL CYLS	L140		

COMMENTS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

INSPECTOR: \_\_\_\_\_ DATE \_\_\_\_\_