

PERMIT NO. MIS210000

**STATE OF MICHIGAN**  
**DEPARTMENT OF ENVIRONMENTAL QUALITY**

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
WASTEWATER DISCHARGE GENERAL PERMIT**

**STORM WATER, FROM INDUSTRIAL ACTIVITY AND/OR WITH  
REQUIRED MONITORING, IN CYCLE-YEAR 2 WATERSHEDS**

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et seq; the "Federal Act"), Michigan Act 451, Public Acts of 1994, as amended (the "Michigan Act"), Parts 31 and 41, and Michigan Executive Order 2011-1, storm water associated with industrial activity, as defined under 40 CFR 122.26(b)(14)(i-ix) and (xi), or as deemed necessary under Section 402(p)(2)(E) of the Federal Act, and other storm water which is adequately regulated by this general permit is authorized to be discharged from facilities specified in individual "certificates of coverage" (COCs) in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this general National Pollutant Discharge Elimination System (NPDES) permit (the "permit").

The applicability of this permit shall be limited to facilities which discharge storm water to surface waters of the state located within a cycle-year 2 watershed as determined by the Michigan Department of Environmental Quality (the "Department"). Applicable discharges include storm water from secondary containment structures required by State or Federal law, from lands on Michigan's List of Sites of Environmental Contamination pursuant to Part 201 (Environmental Response) of the Michigan Act, or from other activities which may contribute pollutants to the storm water for which the Department determines monitoring is needed. This permit does not authorize discharges determined by the Department to need individual NPDES permits or different general permits, or that may cause or contribute to a violation of the Water Quality Standards.

In order to constitute a valid authorization to discharge, this permit must be complemented by a COC issued by the Department. The COC will specify which sections of this permit apply at the individual facility.

Unless specified otherwise, all contact with the Department required by this permit shall be to the position indicated in the COC.

This general permit shall take effect **April 1, 2012**. The provisions of this permit are severable. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term in accordance with applicable laws and rules.

This general permit shall expire at midnight, **April 1, 2017**.

Issued October 6, 2011. Based on a request submitted on April 23, 2012, this permit was **modified (minor)** on May 7, 2012.



Philip Argiroff, Chief  
Permits Section  
Water Resources Division

## PERMIT FEE REQUIREMENTS

In accordance with Section 324.3118 of the Michigan Act, the permittee shall make payment of an annual storm water fee to the Department for each January 1 the permit is in effect regardless of occurrence of discharge. The permittee shall submit the fee in response to the Department's annual notice. The fee shall be postmarked by March 15 for notices mailed by February 1. The fee is due no later than 45 days after receiving the notice for notices mailed after February 1.

## CONTESTED CASE INFORMATION

The terms and conditions of this general permit shall apply to an individual facility on the effective date of a certificate of coverage for the facility. The Department of Licensing and Regulatory Affairs may grant a contested case hearing on this general permit in accordance with the Michigan Act. Any person who is aggrieved by this permit may file a sworn petition with the State Office of Administrative Hearings and Rules of the Michigan Department of Licensing and Regulatory Affairs, setting forth the conditions of the permit which are being challenged and specifying the grounds for the challenge. The Department of Licensing and Regulatory Affairs may grant a contested case hearing on the certificate of coverage issued to an individual facility under this general permit in accordance with Rule 2192(c) (Rule 323.2192 of the Michigan Administrative Code).

**PART I****Section A. Effluent Limitations And Monitoring Requirements****1. Final Effluent Limitations for Facilities without Required Monitoring**

During the period beginning on the effective date of this permit and an individual COC and lasting until the expiration of this permit or termination of the individual COC, the permittee is authorized to discharge an unspecified amount of storm water to the surface waters of the State of Michigan from industrial activity as defined under 40 CFR 122.26(b)(14)(i-ix). The discharge shall be limited by the permittee as specified below.

Storm water discharges are a violation of this permit if:

- a. The receiving water will contain unnatural turbidity, color, oil films, floating solids, foams, settleable solids, suspended solids, or deposits as a result of this discharge; or
- b. The permittee has not implemented an acceptable Storm Water Pollution Prevention Plan (SWPPP) as required by Part I.C. of this permit.

**2. Final Effluent Limitations for Facilities with Required Monitoring**

During the period beginning on the effective date of this permit and an individual COC and lasting until the expiration of this permit or termination of the individual COC, the permittee is authorized to discharge an unspecified amount of storm water to the surface waters of the State of Michigan from secondary containment structures required by State or Federal law, from lands on Michigan's List of Sites of Environmental Contamination pursuant to Part 201 (Environmental Response) of the Michigan Act, and from other activities which may contribute pollutants to the storm water for which the Department determines monitoring is needed. The discharge shall be limited by the permittee as specified below.

- a. Limitations for Discharges from Secondary Containment Structures  
Contained storm water may not be discharged if:
  - 1) The storm water contains unnatural turbidity, color, oil film, floating solids, foams, settleable solids, or suspended solids;
  - 2) The permittee knows or has reason to believe the contained storm water is contaminated by or has come in contact with materials stored within the primary containment structure, unless the Department approves the discharge. An operator of a bulk fuel storage facility may discharge storm water that is known to have contacted petroleum products stored within primary containment structures if the contained storm water has been treated to assure that the limitations in item 1) (above) are met; or
  - 3) The permittee has not implemented an acceptable SWPPP for the secondary containment as required by Part I.C. of this permit.
- b. Limitations for Discharges from Areas without Secondary Containment including Sites of Environmental Contamination and Areas with Other Activities which May Contribute Pollutants to the Storm Water for which the Department Determines Monitoring is Needed  
Storm water may not be discharged if:
  - 1) The receiving water will contain unnatural turbidity, color, oil films, floating solids, foams, settleable solids, suspended solids, or deposits as a result of this discharge;
  - 2) The permittee knows, or has reason to believe, the storm water contains contaminants from the site that may cause a violation of the Water Quality Standards; or
  - 3) The permittee has not implemented an acceptable SWPPP as required by Part I.C. of this permit.

**PART I****Section A. Effluent Limitations And Monitoring Requirements**

- c. Short-Term Storm Water Characterization Study (STSWCS) for Facilities with Required Monitoring  
The permittee shall complete a STSWCS which is an analysis of the storm water discharges authorized by Part I.B.2. of this permit. Permittees seeking reissuance under this permit may complete the STSWCS by following their STSWCS plan previously approved (written approval or approval as defined in a previous permit) by the Department, in which case the STSWCS shall be submitted to the Department within six (6) months of the effective date of the COC issued under this permit. If, however, changes have occurred at the facility which could result in the discharge of different pollutants than those identified in the previously approved STSWCS plan or if the permittee has never submitted a STSWCS plan then the permittee shall submit a new STSWCS plan in accordance with the following:

1) Monitoring Plan Submittal

Within six (6) months after the effective date of a COC issued under this permit the permittee shall submit to the Department either:

- (a) a STSWCS plan (permittees without an approved STSWCS plan or permittees needing to revise the previously approved STSWCS plan), or  
(b) a STSWCS (permittees with an approved STSWCS plan which is still appropriate).

The date for submittal of the STSWCS plan or STSWCS will be included in the COC. Guidance for the STSWCS plan is available on the Internet at [www.michigan.gov/deq](http://www.michigan.gov/deq), on the left hand side click on 'Water', then 'Surface Water', and then 'Storm Water'. In the center of the page, under the 'Information' heading, click on the 'Industrial Program' link and halfway down the page under the 'How do I get a Permit' heading is the guidance document link. The STSWCS plan shall include a proposed list of pollutants to be monitored to adequately characterize the discharge. At a minimum, the proposed list of pollutants shall include significant materials that the permittee knows or has reason to believe are present in areas which require storm water monitoring (these areas include secondary containment structures and associated storage vessels, Sites of Environmental Contamination, or other activities or areas which may contribute pollutants to the storm water for which the Department determines monitoring is needed). If the permittee has more than one area which requires storm water monitoring, such as a secondary containment structure and a Site of Environmental Contamination, then a separate STSWCS plan shall be submitted for each area. The STSWCS plan may include a request to monitor a combined discharge from multiple secondary containment structures if the permittee demonstrates in the STSWCS plan that the monitoring is representative of water from all secondary containment structures. The STSWCS plan(s) shall describe the monitoring frequency and duration, the total number of sampling events (each discharge is one event), the monitoring and analysis methods to be used, and a date for submittal of the summarized analytical results. Samples shall be collected, preserved, handled, and analyzed using EPA approved methods (see 40 CFR Part 136) and appropriate quantification levels. Some desired quantification levels are available in the NPDES Permit Application Appendix at [www.michigan.gov/deq](http://www.michigan.gov/deq), then on the left hand side click on 'Water', then 'Surface Water', and then 'NPDES Permits'. In the center of the page, under the 'Information' heading, click on 'How to Apply for an NPDES permit'. The Permit Application Appendix is under the 'Downloadable Forms' header.

2) Monitoring Secondary Containment Structures or Detention Basins with Detention Periods Greater than 24 Hours

Samples shall be collected from the water within a secondary containment structure or detention basin, or of the discharge prior to mixing with the receiving water or other waste streams. Grab samples may be taken unless the Department specifies other sampling methods. Pollutant concentrations and estimated total volume of the discharge shall be reported. Sampling may include visual observations to determine if the storm water contains unnatural turbidity, color, oil film, floating solids, foams, settleable solids, or suspended solids.

**PART I****Section A. Effluent Limitations And Monitoring Requirements**

- 3) Monitoring Storm Water Runoff from a Site of Environmental Contamination or Other Activity (without Secondary Containment or 24-Hour Detention) which May Contribute Pollutants to the Storm Water for which the Department Determines Monitoring is Needed

Samples shall be collected from the discharge resulting from a storm event that is greater than 0.1 inch of rainfall, causes a discharge, and is at least 72 hours from the previous measurable (greater than 0.1 inch) storm event. Quantitative data shall be reported for a grab sample taken during the **first 30 minutes** of the discharge. Additional samples shall be collected during a discharge event, as necessary, to be representative of the pollutants discharged from the site. Date and duration of the storm event, the rainfall measurement or estimate, duration between the storm event sampled and the end date of the previous measurable storm event, pollutant concentration(s), visual observations, and estimated total volume of the discharge shall be reported.

- 4) Monitoring Startup

Upon approval of the STSWCS plan, the permittee shall begin monitoring the authorized discharge as specified in the plan. If the Department does not take action to approve or comment on the monitoring plan within 90 days after submittal, the permittee shall begin storm water monitoring in accordance with the STSWCS plan submitted. Nothing in this permit shall prevent additional sampling in addition to that specified in the monitoring plan from being conducted. The analytical results of all representative discharge samples collected must be reported to the Department.

If, upon review of the analysis, it is determined that any of the materials or constituents require limiting to protect the receiving waters in accordance with applicable Water Quality Standards, the Department may determine that an individual permit is needed for the discharge in accordance with Part I.D.10. of this permit.

## PART I

## Section B. Schedules and Certifications

**1. Schedules and Certifications for New Storm Water General Permit Applicants**

Applicants requesting first-time authorization to discharge under Part I.A.1. and/or Part A.2. of this permit shall comply with the following requirements prior to submittal of a Notice of Intent (NOI) or other Department-approved application to be covered under this permit.

**a. Schedule**

A first-time applicant will not receive a COC issued under this permit unless the NOI or application is accompanied by certification of compliance with the certified operator and SWPPP requirements of this permit as follows:

**1) Certified Operator**

The applicant shall have a storm water operator certified by the Department, as required by Section 3110 of the Michigan Act. The Certified Storm Water Operator shall have supervision over the facility's storm water treatment and control measures included in the SWPPP.

**2) SWPPP**

The applicant's SWPPP shall be developed in accordance with Part I.C. and ready for implementation prior to submittal of an NOI or other application to be covered under this permit. The SWPPP shall be reviewed and signed by the Certified Storm Water Operator and the permittee. Applicants shall be fully ready to carry out the activities specified in their SWPPP and comply with this permit in order to be issued a COC. New facilities shall have a COC issued under this permit prior to commencement of discharge of storm water.

**b. Certification**

If the permittee submits an application other than an NOI for this permit, the permittee shall also submit a written certification that the facility is in compliance with the requirements identified in Parts I.B.1.b.1) through I.B.1.b.5) of this permit. The certification shall be a written statement that the SWPPP has been completed and is being implemented. It is not necessary to submit the SWPPP to the Department unless requested. New facilities shall fulfill the requirements of Parts I.B.1.b.3) and I.B.1.b.4) when industrial activity begins.

1) The facility has a Certified Storm Water Operator as required in Part I.B.1.a.1) of this permit. The name and certification number of a Certified Storm Water Operator shall be included in the written certification. If the Certified Storm Water Operator's number is not available at the time the written certification is submitted, provide the date the individual took the certification exam, the location of the Department's office where the exam was taken and the signature of the person who took the exam.

2) The source identification requirements of the SWPPP are completed and identified in the SWPPP (see Part I.C.1.).

3) Non-structural preventive measures and source controls are being implemented (see Part I.C.2.).

4) The structural controls for prevention and treatment (see Part I.C.3.), if needed, are installed and operational. The permittee shall indicate, in writing, if a determination is made that no structural controls are necessary.

5) Non-storm water discharges are eliminated or authorized by an NPDES permit (see Part I.D.3.).

## PART I

**Section B. Schedules and Certifications****2. Schedules and Certifications for Storm Water Dischargers with Previous Permit Requirements for a SWPPP**

A permittee who has been authorized to discharge storm water under a permit other than this permit, which required a SWPPP, and who submits an NOI or other application for authorization to discharge under this permit shall comply with the following:

- a. **Schedule**  
Continue development and implementation of the SWPPP in accordance with the schedule established under the individual permit, or general permit and COC, held previous to this permit. That schedule shall be enforceable under this permit.
- b. **Certification**
  - 1) If the permittee submits an application other than an NOI for this permit, the permittee shall also submit a written certification that the facility is in compliance with its current storm water general permit and COC or the SWPPP requirements of its individual permit. The certification shall be a written statement that the SWPPP has been completed and is being implemented. The written certification shall include the name and certification number of the Certified Storm Water Operator. It is not necessary to submit the SWPPP to the Department unless requested to do so.
  - 2) The applicant shall have a storm water operator certified by the Department as required by Section 3110 of the Michigan Act. The Certified Storm Water Operator shall have supervision over the facility's storm water treatment and control measures included in the SWPPP.

**PART I****Section C. Storm Water Pollution Prevention Plan (SWPPP)****1. Source Identification**

To identify potential sources of significant materials that can pollute storm water and subsequently be discharged from the facility, the SWPPP shall, at a minimum, include the following items:

- a. A site map identifying the following:
  - 1) buildings and other permanent structures;
  - 2) storage or disposal areas for significant materials;
  - 3) secondary containment structures and descriptions of what is contained in the primary containment structures;
  - 4) storm water discharge outfalls (numbered or otherwise labeled for reference);
  - 5) location of storm water and non-storm water inlets (catch basins, roof drains, conduits, drain tiles, detention pond riser pipes, and sump pumps) (numbered or otherwise labeled for reference) contributing to each outfall;
  - 6) location of NPDES permitted discharges other than storm water;
  - 7) outlines of the drainage areas contributing to each outfall;
  - 8) structural runoff controls or storm water treatment facilities;
  - 9) areas of vegetation (with brief description such as lawn, old field, marsh, wooded, etc);
  - 10) areas of exposed and/or erodible soils and gravel lots;
  - 11) impervious surfaces (roofs, asphalt, concrete);
  - 12) name and location of receiving water(s); and
  - 13) areas of known or suspected impacts on surface waters as designated under Part 201 (Environmental Response) of the Michigan Act.
- b. A list of all significant materials that could pollute storm water. For each material listed the SWPPP shall include each of the following descriptions:
  - 1) Ways in which each type of significant material has been or has reasonable potential to become exposed to storm water (e.g., spillage during handling; leaks from pipes, pumps, and vessels; contact with storage piles, contaminated materials, or soils; waste handling and disposal; deposits from dust or overspray; etc.).
  - 2) An evaluation of the reasonable potential for contribution of significant materials to runoff from at least the following areas or activities:
    - a. loading, unloading, and other significant material handling operations;
    - b. outdoor storage including secondary containment structures;
    - c. outdoor manufacturing or processing activities;
    - d. significant dust or particulate generating processes;
    - e. discharge from vents, stacks, and air emission controls;
    - f. on-site waste disposal practices;
    - g. maintenance and cleaning of vehicles, machines, and equipment;
    - h. areas of exposed and/or erodible soils;
    - i. Sites of Environmental Contamination listed under Part 201 (Environmental Response) of the Michigan Act;
    - j. areas of significant material residues;
    - k. areas where animals congregate (wild or domestic) and deposit wastes; and
    - l. other areas where storm water may contact significant materials.
  - 3) Identification of the outfall(s) and the inlet(s) contributing the significant material to each outfall through which the significant material may be discharged if released.

## PART I

### Section C. Storm Water Pollution Prevention Plan

- c. A listing of significant spills and significant leaks of polluting materials that occurred at areas that are exposed to precipitation or that otherwise discharge to a point source at the facility. The listing shall include spills that occurred over the three (3) years prior to the effective date of a COC authorizing discharge under this permit. The listing shall include the date, volume, and exact location of release, and the action taken to clean up the material and/or prevent exposure to storm water runoff or contamination of surface waters of the state. Any release that occurs after the SWPPP has been developed shall be controlled in accordance with the SWPPP and is cause for the SWPPP to be updated as appropriate within 14 calendar days of obtaining knowledge of the spill or loss.
- d. The permittee shall determine whether its facility discharges storm water to a water body for which the Department has established a Total Maximum Daily Load (TMDL). If so, the permittee shall assess whether the TMDL requirements for the facility's discharge are being met through the existing SWPPP controls or whether additional control measures are necessary. The permittee's assessment of whether the TMDL requirements are being met shall focus on the effectiveness, adequacy, and implementation of the permittee's SWPPP controls. The applicable TMDLs will be identified in the COC issued under this permit.
- e. A summary of existing storm water discharge sampling data (if available) describing pollutants in storm water discharges at the facility. This summary shall be accompanied by a description of the suspected source(s) of the pollutants detected.

### 2. Preventive Measures and Source Controls, Non-Structural

To prevent significant materials from contacting storm water at the source, the SWPPP shall, at a minimum, include each of the following non-structural controls:

- a. A program which includes a schedule for routine preventive maintenance. The preventive maintenance program shall consist of routine inspections and maintenance of storm water management and control devices (e.g., cleaning of oil/water separators and catch basins, routine housekeeping activities, etc.) as well as inspecting and testing plant equipment and systems to uncover conditions that could cause breakdowns or failures resulting in discharges of pollutants to the storm sewer system or the surface waters of the state. The routine inspection shall include areas of the facility in which significant materials have the reasonable potential to contaminate runoff. A written report of the inspection and corrective actions shall be retained in accordance with Part I.D.1.
- b. A description of good housekeeping procedures to maintain a clean, orderly facility. Good housekeeping procedures shall include routine inspections that focus on the areas of the facility that have a reasonable potential to contaminate storm water runoff from the property. The routine housekeeping inspections may be combined with the routine inspections for the preventive maintenance program. A written report of the inspection and corrective actions shall be retained in accordance with Part I.D.1.
- c. A schedule for comprehensive site inspection shall include, but not be limited to, structural controls in use at the facility and the areas and equipment identified in the preventive maintenance program and good housekeeping procedures. This inspection shall also include a review of the routine preventive maintenance reports, good housekeeping inspections reports, and any other paperwork associated with the SWPPP. The comprehensive site inspection shall be conducted by the Certified Storm Water Operator at least quarterly. The permittee may request Department approval of an alternate schedule for comprehensive site inspections. A written report of the inspection and corrective actions shall be retained in accordance with Part I.D.1. Included in the report shall be a certification that the facility is in compliance with this permit and the SWPPP.

**PART I****Section C. Storm Water Pollution Prevention Plan**

- d. A description of material handling procedures and storage requirements for significant materials. Equipment and procedures for cleaning up spills shall be identified in the SWPPP and made available to the appropriate personnel. The procedures shall identify measures to prevent spilled materials or material residues from contaminating storm water runoff from the property. The SWPPP shall include language describing what a reportable spill or release is and the appropriate reporting requirements in accordance with Part II.C.6. and Part II.C.7. The SWPPP may include, by reference, requirements of either a Pollution Incident Prevention Plan (PIPP) prepared in accordance with the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code); a Hazardous Waste Contingency Plan prepared in accordance with 40 CFR 264 and 265 Subpart D, as required by Part 111 of the Michigan Act; or a Spill Prevention Control and Countermeasure (SPCC) plan prepared in accordance with 40 CFR 112.
- e. Identification of areas which, due to topography, activities, or other factors, have a high potential for significant soil erosion. Gravel lots are areas to be included. The SWPPP shall also identify measures used to control soil erosion and sedimentation.
- f. A description of the employee training program which will be implemented on an annual basis to inform appropriate personnel at all levels of their responsibility as it relates to the components and goals of the SWPPP. The SWPPP shall identify periodic dates for the employee training program. Records of the employee training program shall be retained in accordance with Part I.D.1.
- g. Identification of actions to limit the discharge of significant materials in order to comply with TMDL requirements.
- h. Identification of significant materials expected to be present in storm water discharges following implementation of non-structural preventive measures and source controls.

**3. Structural Controls for Prevention and Treatment**

Where implementation of the measures required by Part I.C.2. does not control storm water discharges in accordance with Part I.D.2., the SWPPP shall provide a description of the location, function, design criteria, and installation/construction schedule of structural controls for prevention and treatment. Structural controls may be necessary:

- a. To prevent uncontaminated storm water from contacting or being contacted by significant materials; or
- b. If preventive measures are not feasible or are inadequate to keep significant materials at the site from contaminating storm water. Structural controls shall be used to treat, divert, isolate, recycle, reuse, or otherwise manage storm water in a manner that reduces the level of significant materials in the storm water and provides compliance with the Water Quality Standards as identified in Part I.D.2.

## PART I

### Section C. Storm Water Pollution Prevention Plan

#### 4. Keeping SWPPPs Current

- a. The permittee and/or the Certified Storm Water Operator shall review the SWPPP annually after it is developed and maintain a written report of the review in accordance with Part I.D.1. Based on the review, the permittee or the Certified Storm Water Operator shall amend the SWPPP as needed to ensure continued compliance with the terms and conditions of this permit. The written report shall be submitted to the department on or before January 10<sup>th</sup> of each year.
- b. The SWPPP developed under the conditions of a previous permit shall be amended as necessary to ensure compliance with this permit.
- c. The SWPPP shall be updated or amended whenever changes at the facility have the potential to increase the exposure of significant materials to storm water, significant spills at the facility occur, or when the SWPPP is determined by the permittee or the Department to be ineffective in achieving the general objectives of controlling pollutants in storm water discharges associated with industrial activity. Updates based on increased activity or spills at the facility shall include a description of how the permittee intends to control any new sources of significant materials or respond to and prevent spills in accordance with the requirements of Parts I.C.1., I.C.2., and I.C.3. of this permit.
- d. The Department or authorized representative may notify the permittee at any time that the SWPPP does not meet minimum requirements. Such notification shall identify why the SWPPP does not meet minimum requirements. The permittee shall make the required changes to the SWPPP within 30 days after such notification from the Department or authorized representative and shall submit to the Department a written certification that the requested changes have been made.
- e. Amendments shall be signed and retained with the SWPPP on site pursuant to Part I.C.6.

#### 5. Certified Storm Water Operator Update

If the Certified Storm Water Operator is changed or an additional Certified Storm Water Operator is added, the permittee shall provide the name and certification number of the new Certified Storm Water Operator to the Department. If a facility has multiple Certified Storm Water Operators, the names and certification numbers of the Certified Storm Water Operators shall be included in the SWPPP.

#### 6. Signature and SWPPP Review

- a. The SWPPP shall be reviewed and signed by the Certified Storm Water Operator(s) and by either the permittee or an authorized representative in accordance with 40 CFR 122.22. The SWPPP and associated records shall be retained on-site at the facility which generates the storm water discharge.
- b. The permittee shall make the SWPPP, reports, log books, storm water discharge sampling data (if collected), and items required by Part I.D.1. available upon request to the Department or authorized representative.

**PART I****Section D. Special Conditions****1. Record Keeping**

The permittee shall maintain records of all SWPPP related inspection and maintenance activities. Records shall also be kept describing incidents such as spills or other discharges that can affect the quality of storm water runoff. All such records shall be retained for three years. The following records are required by this permit:

- a. Routine preventive maintenance inspections reports (Part I.C.2.a.);
- b. Routine good housekeeping inspections reports (Part I.C.2.b.);
- c. Comprehensive site inspection reports (Part I.C.2.c.);
- d. Employee training records (Part I.C.2.f.); and
- e. Written summaries of the annual SWPPP review (Part I.C.4.a.).

**2. Water Quality Standards**

At the time of discharge, there shall be no violation of the Water Quality Standards in the receiving waters as a result of the storm water discharge. This requirement includes, but is not limited to, the following conditions:

- a. In accordance with Rule 323.1050 of the Water Quality Standards, the receiving waters shall not have any of the following unnatural physical properties as a result of this discharge in quantities which are or may become injurious to any designated use: turbidity, color, oil films, floating solids, foams, settleable solids, suspended solids, or deposits;
- b. Any unusual characteristics of the discharge (i.e., unnatural turbidity, color, oil film, floating solids, foams, settleable solids, suspended solids, or deposits) shall be reported within 24 hours to the Department followed by a written report within five days detailing the findings of the investigation and the steps taken to correct the condition; and
- c. Any pollutant for which a level of control is specified to meet a TMDL established by the Department shall be controlled at the facility so that its discharge is reduced by/to the amount specified in the TMDL.

**3. Prohibition of Non-Storm Water Discharges**

Discharges of material other than storm water shall be in compliance with an NPDES permit (other than this permit) issued for the discharge. Storm water shall be defined to include all of the following non-storm water discharges provided pollution prevention controls for the non-storm water component are identified in the SWPPP:

- a. discharges from fire hydrant flushing;
- b. potable water sources including water line flushing;
- c. water from fire system testing and fire fighting training without burned materials or chemical fire suppressants;
- d. irrigation drainage;
- e. lawn watering;

**PART I****Section D. Special Conditions**

- f. routine building wash down which does not use detergents or other compounds;
- g. pavement wash waters where contamination by toxic or hazardous materials have not occurred (unless all contamination by toxic or hazardous materials have been removed) and where detergents are not used;
- h. air conditioning condensate;
- i. springs;
- j. uncontaminated ground water;
- k. foundation or footing drains where flows are not contaminated with process materials such as solvents; and
- l. discharges from fire fighting activities. Discharges from fire fighting activities are exempted from the requirement to be identified in the SWPPP.

**4. Request for Discharge of Water Treatment Additives**

In the event a permittee proposes to discharge water additives, the permittee shall submit a request to discharge water additives to the Department for approval. Such requests shall be sent to the Permits Section, Water Resources Division, Department of Environmental Quality, P.O. Box 30458, Lansing, Michigan 48909, with a copy to the Department contact listed on the cover page of this permit. Instructions to submit a request electronically may be obtained via the Internet (<http://www.michigan.gov/deqnpdes>; then click on Applicable Rules and Regulations which is under the Information banner and then click on Water Treatment Additive Discharge Application Instructions). Written approval from the Department to discharge such additives at specified levels shall be obtained prior to discharge by the permittee. Additional monitoring and reporting may be required as a condition for the approval to discharge the additive.

A request to discharge water additives shall include all of the following water additive usage and discharge information:

- a. Material Safety Data Sheet;
- b. the proposed water additive discharge concentration;
- c. the discharge frequency (i.e., number of hours per day and number of days per year);
- d. the monitoring point from which the product is to be discharged;
- e. the type of removal treatment, if any, that the water additive receives prior to discharge;
- f. product function (i.e. microbiocide, flocculant, etc.);
- g. a 48-hour LC<sub>50</sub> or EC<sub>50</sub> for a North American freshwater planktonic crustacean (either *Ceriodaphnia* sp., *Daphnia* sp., or *Simocephalus* sp.); and
- h. the results of a toxicity test for one other North American freshwater aquatic species (other than a planktonic crustacean) that meets a minimum requirement of Rule 323.1057(2) of the Water Quality Standards.

Prior to submitting the request, the permittee may contact the Permits Section by telephone at 517-241-1346 or via the Internet at the address given above to determine if the Department has the product toxicity data required by items g. and h. above. If the Department has the data, the permittee will not need to submit product toxicity data.

**PART I****Section D. Special Conditions****5. Tracer Dye Discharges**

This permit does not authorize the discharge of tracer dyes without approval from the Department. Requests to discharge tracer dyes shall be submitted to the Department in accordance with Rule 1097 (Rule 323.1097 of the Michigan Administrative Code).

**6. Facility Contact**

The "Facility Contact" was specified in the application. The permittee may replace the facility contact at any time, and shall notify the Department in writing within 10 days after replacement (including the name, address and telephone number of the new facility contact).

- a. The facility contact shall be (or a duly authorized representative of this person):
  - 1) for a corporation, a principal executive officer of at least the level of vice president, or a designated representative, if the representative is responsible for the overall operation of the facility from which the discharge described in the permit application or other NPDES form originates;
  - 2) for a partnership, a general partner;
  - 3) for a sole proprietorship, the proprietor; or
  - 4) for a municipal, state, or other public facility, either a principal executive officer, the mayor, village president, city or village manager, or other duly authorized employee.
- b. A person is a duly authorized representative only if:
  - 1) the authorization is made in writing to the Department by a person described in Part I.D.6.a. of this permit; and
  - 2) the authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the facility (a duly authorized representative may thus be either a named individual or any individual occupying a named position).

Nothing in this section obviates the permittee from properly submitting reports and forms as required by law.

**7. Portable Industrial Facilities**

- a. Storm water discharges from satellite locations of a portable industrial facility may be authorized by obtaining a COC issued under this permit. To obtain a COC, an NOI, or other Department-approved application must be submitted to the Department for a primary mailing address of the owner or operator of the portable facility. Following receipt of a COC, if the portable facility is to be moved to a satellite location, the permittee shall notify the Department of the relocation, in writing, at least 10 days prior to start-up at the satellite location. Written notification shall include the location (township, range, section, and quarter-quarter section) of the current and proposed sites for the portable facility, the receiving water for the discharge, and the anticipated date of the move. Failure to notify the Department concerning the satellite location is a permit violation.
- b. The permittee shall submit an NOI or other Department-approved application for each portable facility that could be moved to a satellite location. A SWPPP shall be in place for each facility at the time of start-up and shall be modified for each new location as necessary.

**PART I****Section D. Special Conditions****8. Expiration and Reissuance**

On or before October 1, 2016, a permittee seeking continued authorization to discharge under this permit beyond the permit's expiration date shall submit to the Department a written request containing such information, forms, and fees as required by the Department. Without an adequate request, a permittee's authorization to discharge will expire on April 1, 2017. With an adequate request, a permittee shall continue to be subject to the terms and conditions of the expired permit until the Department takes action on the request unless this permit is terminated or revoked.

If this permit is terminated or revoked, all authorizations to discharge under the permit shall expire on the date of termination or revocation.

If this permit is modified, the Department will notify the permittee of any required action. Without an adequate response, a permittee's authorization to discharge will terminate on the effective date of the modified permit. With an adequate response, a permittee shall be subject to the terms and conditions of the modified permit on the effective date of the modified permit unless the Department notifies the permittee otherwise.

If a discharge is terminated, the permittee shall request termination of discharge authorization.

**9. Termination of General Permit Coverage**

A permittee may submit a request to the Department to terminate the COC for a facility when:

- a. all storm water discharges authorized by Part I.A.1. and Part I.A.2. are eliminated; or
- b. industrial activity has ceased, no significant materials remain or are exposed to storm water, and no discharges are authorized under Part I.A.2.

**10. Requirement to Obtain Individual Permit**

The Department may require any person who is authorized to discharge by a COC and this permit to apply for and obtain an individual NPDES permit if any of the following circumstances apply:

- a. the discharge is a significant contributor to pollution as determined by the Department on a case-by-case basis;
- b. the discharger is not complying or has not complied with the conditions of the permit;
- c. a change has occurred in the availability of demonstrated technology or practices for the control or abatement of waste applicable to the point source discharge;
- d. effluent standards and limitations are promulgated for point source discharges subject to this permit; or
- e. the Department determines that the criteria under which the permit was issued no longer apply.

Any person may request the Department to take action pursuant to the provisions of Rule 2191 (Rule 323.2191 of the Michigan Administrative Code).

## PART II

### Section A. Definitions

This list of definitions may include terms not applicable to this permit.

**Acute toxic unit (TU<sub>A</sub>)** means  $100/LC_{50}$  where the  $LC_{50}$  is determined from a whole effluent toxicity (WET) test which produces a result that is statistically or graphically estimated to be lethal to 50% of the test organisms.

**Bioaccumulative chemical of concern (BCC)** means a chemical which, upon entering the surface waters, by itself or as its toxic transformation product, accumulates in aquatic organisms by a human health bioaccumulation factor of more than 1000 after considering metabolism and other physiochemical properties that might enhance or inhibit bioaccumulation. The human health bioaccumulation factor shall be derived according to R 323.1057(5). Chemicals with half-lives of less than 8 weeks in the water column, sediment, and biota are not BCCs. The minimum bioaccumulation concentration factor (BAF) information needed to define an organic chemical as a BCC is either a field-measured BAF or a BAF derived using the biota-sediment accumulation factor (BSAF) methodology. The minimum BAF information needed to define an inorganic chemical as a BCC, including an organometal, is either a field-measured BAF or a laboratory-measured bioconcentration factor (BCF). The BCCs to which these rules apply are identified in Table 5 of R 323.1057 of the Water Quality Standards.

**Biosolids** are the solid, semisolid, or liquid residues generated during the treatment of sanitary sewage or domestic sewage in a treatment works. This includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes and a derivative of the removed scum or solids.

**Bulk biosolids** means biosolids that are not sold or given away in a bag or other container for application to a lawn or home garden.

**Certificate of Coverage (COC)** means a document, issued by the Department, which authorizes a discharge under this permit.

**Chronic toxic unit (TU<sub>C</sub>)** means  $100/MATC$  or  $100/IC_{25}$ , where the maximum acceptable toxicant concentration (MATC) and  $IC_{25}$  are expressed as a percent effluent in the test medium.

**Class B Biosolids** refers to material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with the Part 24 Rules. Processes include aerobic digestion, composting, anaerobic digestion, lime stabilization and air drying.

**Daily concentration** is the sum of the concentrations of the individual samples of a parameter divided by the number of samples taken during any calendar day. If the parameter concentration in any sample is less than the quantification limit, regard that value as zero when calculating the daily concentration. The daily concentration will be used to determine compliance with any maximum and minimum daily concentration limitations (except for pH and dissolved oxygen). When required by the permit, report the maximum calculated daily concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the Discharge Monitoring Reports (DMRs).

For pH, report the maximum value of any individual sample taken during the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs and the minimum value of any individual sample taken during the month in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs. For dissolved oxygen, report the minimum concentration of any individual sample in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Daily loading** is the total discharge by weight of a parameter discharged during any calendar day. This value is calculated by multiplying the daily concentration by the total daily flow and by the appropriate conversion factor. The daily loading will be used to determine compliance with any maximum daily loading limitations. When required by the permit, report the maximum calculated daily loading for the month in the "MAXIMUM" column under "QUANTITY OR LOADING" on the DMRs.

**Department** means the Michigan Department of Environmental Quality.

**Detection Level** means the lowest concentration or amount of the target analyte that can be determined to be different from zero by a single measurement at a stated level of probability.

## PART II

### Section A. Definitions

**EC<sub>50</sub>** means a statistically or graphically estimated concentration that is expected to cause 1 or more specified effects in 50% of a group of organisms under specified conditions.

**Fecal coliform bacteria monthly** is the geometric mean of the samples collected in a calendar month (or 30 consecutive days). The calculated monthly value will be used to determine compliance with the maximum monthly fecal coliform bacteria limitations. When required by the permit, report the calculated monthly value in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Fecal coliform bacteria 7-day** is the geometric mean of the samples collected in any 7-day period. The calculated 7-day value will be used to determine compliance with the maximum 7-day fecal coliform bacteria limitations. When required by the permit, report the maximum calculated 7-day concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Flow Proportioned sample** is a composite sample with the sample volume proportional to the effluent flow.

**Grab sample** is a single sample taken at neither a set time nor flow.

**IC<sub>25</sub>** means the toxicant concentration that would cause a 25% reduction in a nonquantal biological measurement for the test population.

**Individual Permit** means a site-specific NPDES permit.

**Inlet** means a catch basin, roof drain, conduit, drain tile, retention pond riser pipe, sump pump, or other point where storm water or wastewater enters into a closed conveyance system prior to discharge off site or into waters of the state.

**Interference** is a discharge which, alone or in conjunction with a discharge or discharges from other sources, both: 1) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and 2) therefore, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or, of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent state or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including state regulations contained in any state sludge management plan prepared pursuant to Subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act. [This definition does not apply to sample matrix interference.]

**Land Application** means spraying or spreading biosolids or a biosolids derivative onto the land surface, injecting below the land surface, or incorporating into the soil so that the biosolids or biosolids derivative can either condition the soil or fertilize crops or vegetation grown in the soil.

**LC<sub>50</sub>** means a statistically or graphically estimated concentration that is expected to be lethal to 50% of a group of organisms under specified conditions.

**Maximum acceptable toxicant concentration (MATC)** means the concentration obtained by calculating the geometric mean of the lower and upper chronic limits from a chronic test. A lower chronic limit is the highest tested concentration that did not cause the occurrence of a specific adverse effect. An upper chronic limit is the lowest tested concentration which did cause the occurrence of a specific adverse effect and above which all tested concentrations caused such an occurrence.

**MGD** means million gallons per day.

**Monthly frequency of analysis** refers to a calendar month. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

## PART II

### Section A. Definitions

**Monthly concentration** is the sum of the daily concentrations determined during a reporting month (or 30 consecutive days) divided by the number of daily concentrations determined. The calculated monthly concentration will be used to determine compliance with any maximum monthly concentration limitations. When required by the permit, report the calculated monthly concentration in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMRs.

For minimum percent removal requirements, the monthly influent concentration and the monthly effluent concentration shall be determined. The calculated monthly percent removal, which is equal to 100 times the quantity [1 minus the quantity (monthly effluent concentration divided by the monthly influent concentration)], shall be reported in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Monthly loading** is the sum of the daily loadings of a parameter divided by the number of daily loadings determined in the reporting month (or 30 consecutive days). The calculated monthly loading will be used to determine compliance with any maximum monthly loading limitations. When required by the permit, report the calculated monthly loading in the "AVERAGE" column under "QUANTITY OR LOADING" on the DMRs.

**National Pretreatment Standards** are the regulations promulgated by or to be promulgated by the Federal Environmental Protection Agency pursuant to Section 307(b) and (c) of the Federal Act. The standards establish nationwide limits for specific industrial categories for discharge to a POTW.

**New Facility** means a facility located on a newly-developed or redeveloped site which is ready to begin industrial operations on or after the effective date of this permit.

**NOI** means Notice of Intent to be covered by this permit.

**No observed adverse effect level (NOAEL)** means the highest tested dose or concentration of a substance which results in no observed adverse effect in exposed test organisms where higher doses or concentrations result in an adverse effect.

**Noncontact Cooling Water** is water used for cooling which does not come into direct contact with any raw material, intermediate product, by-product, waste product or finished product.

**Nondomestic user** is any discharger to a POTW that discharges wastes other than or in addition to water-carried wastes from toilet, kitchen, laundry, bathing or other facilities used for household purposes.

**Partially treated sewage** is any sewage, sewage and storm water, or sewage and wastewater, from domestic or industrial sources that is treated to a level less than that required by the permittee's National Pollutant Discharge Elimination System permit, or that is not treated to national secondary treatment standards for wastewater, including discharges to surface waters from retention treatment facilities.

**Point Source Discharge** means a discharge from any discernible, confined, and discrete conveyance, including but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container or rolling stock. Changing the surface of land or establishing grading patterns on land will result in a point source where the runoff from the site is ultimately discharged to waters of the state.

**Polluting Materials** means oil and any material, in solid or liquid form, identified as polluting material under the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code).

**Pretreatment** is reducing the amount of pollutants, eliminating pollutants, or altering the nature of pollutant properties to a less harmful state prior to discharge into a public sewer. The reduction or alteration can be by physical, chemical, or biological processes, process changes, or by other means. Dilution is not considered pretreatment unless expressly authorized by an applicable National Pretreatment Standard for a particular industrial category.

**POTW** is a publicly owned treatment works.

## PART II

### Section A. Definitions

**Quantification level** means the measurement of the concentration of a contaminant obtained by using a specified laboratory procedure calculated at a specified concentration above the detection level. It is considered the lowest concentration at which a particular contaminant can be quantitatively measured using a specified laboratory procedure for monitoring of the contaminant.

**Quarterly frequency of analysis** refers to a three month period, defined as January through March, April through June, July through September, and October through December. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**Regional Administrator** is the Region 5 Administrator, U.S. EPA, located at R-19J, 77 W. Jackson Blvd., Chicago, Illinois 60604.

**Secondary Containment Structure** means a unit, other than the primary container in which significant materials are packaged or held, which is required by State or Federal law to prevent the escape of significant materials by gravity into sewers, drains, or otherwise directly or indirectly into any sewer system or to the surface or ground waters of this state.

**Significant industrial user** is a nondomestic user that: 1) is subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N; or 2) discharges an average of 25,000 gallons per day or more of process wastewater to a POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the permittee as defined in 40 CFR 403.12(a) on the basis that the industrial user has a reasonable potential for adversely affecting the POTW's treatment plant operation or violating any pretreatment standard or requirement (in accordance with 40 CFR 403.8(f)(6)).

**Significant Materials** means any material which could degrade or impair water quality, including but not limited to: raw materials; fuels; solvents, detergents, and plastic pellets; finished materials such as metallic products; hazardous substances designated under section 101(14) of Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) (See 40 CFR 372.65); any chemical the facility is required to report pursuant to section 313 of the Emergency Planning and Community Right-to-Know Act (EPCRA); polluting materials (as defined above); Hazardous Wastes as defined in Part 111 of the Michigan Act; fertilizers; pesticides; and waste products such as ashes, slag, sludge, and plant and animal wastes that have the potential to be released with storm water discharges.

**Significant Spills and Significant Leaks** means any release of a polluting material reportable under the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code).

**Storm Water** means storm water runoff, snow melt runoff, surface runoff and drainage, and non-storm water included under the conditions of Part I.D.3.

**SWPPP** means the Storm Water Pollution Prevention Plan prepared in accordance with Part I.C. of this permit.

**Tier I value** means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier I toxicity database.

**Tier II value** means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier II toxicity database.

**Total Maximum Daily Load or TMDL** means the amount of pollutant load a water body such as a lake or stream can assimilate and still meet Water Quality Standards.

**Toxicity Reduction Evaluation (TRE)** means a site-specific study conducted in a stepwise process designed to identify the causative agents of effluent toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in effluent toxicity.

## PART II

### Section A. Definitions

**Water Quality Standards** means the Part 4 Water Quality Standards promulgated pursuant to Part 31 of Act No. 451 of the Public Acts of 1994, as amended, being Rules 323.1041 through 323.1117 of the Michigan Administrative Code.

**Weekly frequency of analysis** refers to a calendar week which begins on Sunday and ends on Saturday. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**Yearly frequency of analysis** refers to a calendar year beginning on January 1 and ending on December 31. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**24-Hour Composite sample** is a flow proportioned composite sample consisting of hourly or more frequent portions that are taken over a 24-hour period.

**3-Portion Composite sample** is a sample consisting of three equal volume grab samples collected at equal intervals over an 8-hour period.

**7-day concentration** is the sum of the daily concentrations determined during any 7 consecutive days in a reporting month divided by the number of daily concentrations determined. The calculated 7-day concentration will be used to determine compliance with any maximum 7-day concentration limitations. When required by the permit, report the maximum calculated 7-day concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs. FOR SEASONAL LAGOON DISCHARGES ONLY: If the seven day period was partially in each of two months, the seven day average shall be reported on the DMR of the month in which the last day of discharge occurred.

**7-day loading** is the sum of the daily loadings of a parameter divided by the number of daily loadings determined during any 7 consecutive days in a reporting month. The calculated 7-day loading will be used to determine compliance with any maximum 7-day loading limitations. When required by the permit, report the maximum calculated 7-day loading for the month in the "MAXIMUM" column under "QUANTITY OR LOADING" on the DMRs. FOR SEASONAL LAGOON DISCHARGES ONLY: If the seven day period was partially in each of two months, the seven day average shall be reported on the DMR of the month in which the last day of discharge occurred.

**PART II****Section B. Monitoring Procedures****1. Representative Samples**

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge.

**2. Test Procedures**

Test procedures for the analysis of pollutants shall conform to regulations promulgated pursuant to Section 304(h) of the Federal Act (40 CFR Part 136 - Guidelines Establishing Test Procedures for the Analysis of Pollutants), unless specified otherwise in this permit. Requests to use test procedures not promulgated under 40 CFR Part 136 for pollutant monitoring required by this permit shall be made in accordance with the Alternate Test Procedures regulations specified in 40 CFR 136.4. These requests shall be submitted to the Chief of the Permits Section, Water Resources Division, Michigan Department of Environmental Quality, P.O. Box 30273, Lansing, Michigan, 48909-7773. The permittee may use such procedures upon approval.

The permittee shall periodically calibrate and perform maintenance procedures on all analytical instrumentation at intervals to ensure accuracy of measurements. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

**3. Instrumentation**

The permittee shall periodically calibrate and perform maintenance procedures on all monitoring instrumentation at intervals to ensure accuracy of measurements.

**4. Recording Results**

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information: 1) the exact place, date, and time of measurement or sampling; 2) the person(s) who performed the measurement or sample collection; 3) the dates the analyses were performed; 4) the person(s) who performed the analyses; 5) the analytical techniques or methods used; 6) the date of and person responsible for equipment calibration; and 7) the results of all required analyses.

**5. Records Retention**

All records and information resulting from the monitoring activities required by this permit including all records of analyses performed and calibration and maintenance of instrumentation and recordings from continuous monitoring instrumentation shall be retained for a minimum of three (3) years or longer if requested by the Regional Administrator or the Department.

## PART II

### Section C. Reporting Requirements

#### 1. Start-up Notification

If the permittee will not discharge during the first 60 days following the effective date of the facility's COC, the permittee shall notify the Department within 14 days following the effective date of the COC, and then 60 days prior to the commencement of the discharge.

#### 2. Submittal Requirements for Self-Monitoring Data

Part 31 of Act 451 of 1994, as amended, specifically Section 324.3110(3) and Rule 323.2155(2) of Part 21 allows the Department to specify the forms to be utilized for reporting the required self-monitoring data. Unless instructed on the effluent limitations page to conduct "Retained Self Monitoring" the permittee shall submit self-monitoring data via the Department's Electronic Environmental Discharge Monitoring Reporting (e2-DMR) system.

The permittee shall utilize the information provided on the e2-Reporting website @ <https://secure1.state.mi.us/e2rs/> to access and submit the electronic forms. Both monthly summary and daily data shall be submitted to the department no later than the **20<sup>th</sup> day of the month** following each month of the authorized discharge period(s).

#### 3. Retained Self-Monitoring Requirements

If instructed on the effluent limits page (or otherwise authorized by the Department in accordance with the provisions of this permit) to conduct retained self-monitoring, the permittee shall maintain a year-to-date log of retained self-monitoring results and, upon request, provide such log for inspection to the staff of the Department (Department as defined on the COC). Retained self-monitoring results are public information and shall be promptly provided to the public upon written request from the public.

The permittee shall certify, in writing, to the Department, on or before January 10<sup>th</sup> of each year, that: 1) all retained self-monitoring requirements have been complied with and a year-to-date log has been maintained; and 2) the application on which this permit is based still accurately describes the discharge. With this annual certification, the permittee shall submit a summary of the previous year's monitoring data. The summary shall include maximum values for samples to be reported as daily maximums and/or monthly maximums and minimum values for any daily minimum samples.

#### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

Monitoring required pursuant to Part 41 of the Michigan Act or Rule 35 of the Mobile Home Park Commission Act (Act 96 of the Public Acts of 1987) for assurance of proper facility operation shall be submitted as required by the Department.

#### 5. Compliance Dates Notification

Within 14 days of every compliance date specified in this permit, the permittee shall submit a written notification to the Department indicating whether or not the particular requirement was accomplished. If the requirement was not accomplished, the notification shall include an explanation of the failure to accomplish the requirement, actions taken or planned by the permittee to correct the situation, and an estimate of when the requirement will be accomplished. If a written report is required to be submitted by a specified date and the permittee accomplishes this, a separate written notification is not required.

## PART II

### Section C. Reporting Requirements

#### 6. Noncompliance Notification

Compliance with all applicable requirements set forth in the Federal Act, Parts 31 and 41 of the Michigan Act, and related regulations and rules is required. All instances of noncompliance shall be reported as follows:

- a. 24-hour reporting - Any noncompliance which may endanger health or the environment (including maximum daily concentration discharge limitation exceedances) shall be reported, verbally, within 24 hours from the time the permittee becomes aware of the noncompliance. A written submission shall also be provided within five (5) days.
- b. other reporting - The permittee shall report, in writing, all other instances of noncompliance not described in a. above at the time monitoring reports are submitted; or, in the case of retained self-monitoring, within five (5) days from the time the permittee becomes aware of the noncompliance.

Written reporting shall include: 1) a description of the discharge and cause of noncompliance; and 2) the period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and the steps taken to reduce, eliminate and prevent recurrence of the noncomplying discharge.

#### 7. Spill Notification

The permittee shall immediately report any release of any polluting material which occurs to the surface waters or groundwaters of the state, unless the permittee has determined that the release is not in excess of the threshold reporting quantities specified in the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code), by calling the Department at the number indicated in the COC, or if the notice is provided after regular working hours call the Department's 24-hour Pollution Emergency Alerting System telephone number, 1-800-292-4706 (calls from out-of-state dial 1-517-373-7660).

Within ten (10) days of the release, the permittee shall submit to the Department a full written explanation as to the cause of the release, the discovery of the release, response (clean-up and/or recovery) measures taken, and preventive measures taken or a schedule for completion of measures to be taken to prevent reoccurrence of similar releases.

#### 8. Upset Noncompliance Notification

If a process "upset" (defined as an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee) has occurred, the permittee who wishes to establish the affirmative defense of upset, shall notify the Department by telephone within 24-hours of becoming aware of such conditions; and within five (5) days, provide in writing, the following information:

- a. that an upset occurred and that the permittee can identify the specific cause(s) of the upset;
- b. that the permitted wastewater treatment facility was, at the time, being properly operated; and
- c. that the permittee has specified and taken action on all responsible steps to minimize or correct any adverse impact in the environment resulting from noncompliance with this permit.

In any enforcement proceedings, the permittee, seeking to establish the occurrence of an upset, has the burden of proof.

**PART II****Section C. Reporting Requirements****9. Bypass Prohibition and Notification**

- a. Bypass Prohibition - Bypass is prohibited unless:
- 1) bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - 2) there were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass; and
  - 3) the permittee submitted notices as required under 9.b. or 9.c. below.
- b. Notice of Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least ten (10) days before the date of the bypass, and provide information about the anticipated bypass as required by the Department. The Department may approve an anticipated bypass, after considering its adverse effects, if it will meet the three (3) conditions listed in 9.a. above.
- c. Notice of Unanticipated Bypass - The permittee shall submit notice to the Department of an unanticipated bypass by calling the Department at the number indicated in the COC (if the notice is provided after regular working hours, use the following number: 1-800-292-4706) as soon as possible, but no later than 24 hours from the time the permittee becomes aware of the circumstances.
- d. Written Report of Bypass - A written submission shall be provided within five (5) working days of commencing any bypass to the Department, and at additional times as directed by the Department. The written submission shall contain a description of the bypass and its cause; the period of bypass, including exact dates and times, and if the bypass has not been corrected, the anticipated time it is expected to continue; steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass; and other information as required by the Department.
- e. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of 9.a., 9.b., 9.c., and 9.d., above. This provision does not relieve the permittee of any notification responsibilities under Part II.C.10. of this permit.
- f. Definitions
- 1) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
  - 2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

## PART II

### Section C. Reporting Requirements

#### 10. Notification of Changes in Discharge

The permittee shall notify the Department, in writing, within 10 days of knowing, or having reason to believe, that any activity or change has occurred or will occur which would result in the discharge of: 1) detectable levels of chemicals on the current Michigan Critical Materials Register, priority pollutants or hazardous substances set forth in 40 CFR 122.21, Appendix D, or the Pollutants of Initial Focus in the Great Lakes Water Quality Initiative specified in 40 CFR 132.6, Table 6, which were not acknowledged in the application or listed in the application at less than detectable levels; 2) detectable levels of any other chemical not listed in the application or listed at less than detection, for which the application specifically requested information; or 3) any chemical at levels greater than five times the average level reported in the complete application (see the COC for the date(s) the complete application was submitted). Any other monitoring results obtained as a requirement of this permit shall be reported in accordance with the compliance schedules.

#### 11. Changes in Facility Operations

Any anticipated action or activity, including but not limited to facility expansion, production increases, or process modification, which will result in new or increased loadings of pollutants to the receiving waters must be reported to the Department by a) submission of an increased use request (application) and all information required under Rule 323.1098 (Antidegradation) of the Water Quality Standards or b) by notice if the following conditions are met: 1) the action or activity will not result in a change in the types of wastewater discharged or result in a greater quantity of wastewater than currently authorized by this permit; 2) the action or activity will not result in violations of the effluent limitations specified in this permit; 3) the action or activity is not prohibited by the requirements of Part II.C.12.; and 4) the action or activity will not require notification pursuant to Part II.C.10. Following such notice, the permit may be modified according to applicable laws and rules to specify and limit any pollutant not previously limited.

#### 12. Bioaccumulative Chemicals of Concern (BCC)

Consistent with the requirements of Rules 323.1098 and 323.1215 of the Michigan Administrative Code, the permittee is prohibited from undertaking any action that would result in a lowering of water quality from an increased loading of a BCC unless an increased use request and antidegradation demonstration have been submitted and approved by the Department.

#### 13. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharge emanates, the permittee shall submit to the Department 30 days prior to the actual transfer of ownership or control a written agreement between the current permittee and the new permittee containing: 1) the legal name and address of the new owner; 2) a specific date for the effective transfer of permit responsibility, coverage and liability; and 3) a certification of the continuity of or any changes in operations, wastewater discharge, or wastewater treatment.

If the new permittee is proposing changes in operations, wastewater discharge, or wastewater treatment, the Department may propose modification of this permit in accordance with applicable laws and rules.

**PART II****Section D. Management Responsibilities****1. Duty to Comply**

All discharges authorized herein shall be consistent with the terms and conditions of this permit and the facility's COC. The discharge of any pollutant identified in this permit and/or the facility's COC more frequently than or at a level in excess of that authorized shall constitute a violation of the permit.

It is the duty of the permittee to comply with all the terms and conditions of this permit and the facility's COC. Any noncompliance with the Effluent Limitations, Special Conditions, or terms of this permit or the facility's COC constitutes a violation of the Michigan Act and/or the Federal Act and constitutes grounds for enforcement action; for COC termination, revocation and reissuance, or modification; or denial of an application for permit or COC renewal.

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**2. Operator Certification**

The permittee shall have the waste treatment facilities under direct supervision of an operator certified at the appropriate level for the facility certification by the Department, as required by Sections 3110 and 4104 of the Michigan Act.

**3. Facilities Operation**

The permittee shall, at all times, properly operate and maintain all treatment or control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures.

**4. Power Failures**

In order to maintain compliance with the effluent limitations of this permit and prevent unauthorized discharges, the permittee shall either:

- a. provide an alternative power source sufficient to operate facilities utilized by the permittee to maintain compliance with the effluent limitations and conditions of this permit; or
- b. upon the reduction, loss, or failure of one or more of the primary sources of power to facilities utilized by the permittee to maintain compliance with the effluent limitations and conditions of this permit, the permittee shall halt, reduce or otherwise control production and/or all discharge in order to maintain compliance with the effluent limitations and conditions of this permit.

**5. Adverse Impact**

The permittee shall take all reasonable steps to minimize any adverse impact to the surface waters or groundwaters of the state resulting from noncompliance with any effluent limitation specified in this permit including, but not limited to, such accelerated or additional monitoring as necessary to determine the nature and impact of the discharge in noncompliance.

## PART II

### Section D. Management Responsibilities

#### 6. Containment Facilities

The permittee shall provide facilities for containment of any accidental losses of polluting materials in accordance with the requirements of the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code). For a Publicly Owned Treatment Work (POTW), these facilities shall be approved under Part 41 of the Michigan Act.

#### 7. Waste Treatment Residues

Residuals (i.e. solids, sludges, biosolids, filter backwash, scrubber water, ash, grit, or other pollutants or wastes) removed from or resulting from treatment or control of wastewaters, including those that are generated during treatment or left over after treatment or control has ceased shall be disposed of in an environmentally compatible manner and according to applicable laws and rules. These laws may include, but are not limited to, the Michigan Act, Part 31 for protection of water resources, Part 55 for air pollution control, Part 111 for hazardous waste management, Part 115 for solid waste management, Part 121 for liquid industrial wastes, Part 301 for protection of inland lakes and streams, and Part 303 for wetlands protection. Such disposal shall not result in any unlawful pollution of the air, surface waters or groundwaters of the state.

#### 8. Right of Entry

The permittee shall allow the Department, any agent appointed by the Department or the Regional Administrator, upon the presentation of credentials:

- a. to enter upon the permittee's premises where an effluent source is located or in which any records are required to be kept under the terms and conditions of this permit; and
- b. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit; to inspect process facilities, treatment works, monitoring methods and equipment regulated or required under this permit; and to sample any discharge of pollutants.

#### 9. Availability of Reports

Except for data determined to be confidential under Section 308 of the Federal Act and Rule 2128 (Rule 323.2128 of the Michigan Administrative Code), all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department and the Regional Administrator. As required by the Federal Act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the Federal Act and Sections 3112, 3115, 4106 and 4110 of the Michigan Act.

**PART II****Section E. Activities Not Authorized by This Permit****1. Discharge to the Groundwaters**

This permit does not authorize any discharge to the groundwaters. Such discharge may be authorized by a groundwater discharge permit issued pursuant to the Michigan Act.

**2. Facility Construction**

This permit does not authorize or approve the construction or modification of any physical structures or facilities. Approval for such construction for a POTW must be by permit issued under Part 41 of the Michigan Act. Approval for such construction for a mobile home park, campground or marina shall be from the Water Resources Division, Michigan Department of Environmental Quality. Approval for such construction for a hospital, nursing home or extended care facility shall be from the Division of Health Facilities and Services, Michigan Department of Consumer and Industry Services upon request.

**3. Civil and Criminal Liability**

Except as provided in permit conditions on "Bypass" (Part II.C.9. pursuant to 40 CFR 122.41(m)), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance, whether or not such noncompliance is due to factors beyond the permittee's control, such as accidents, equipment breakdowns, or labor disputes.

**4. Oil and Hazardous Substance Liability**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee may be subject under Section 311 of the Federal Act except as are exempted by federal regulations.

**5. State Laws**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Federal Act.

**6. Property Rights**

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize violation of any federal, state or local laws or regulations, nor does it obviate the necessity of obtaining such permits, including any other Department of Environmental Quality permits, or approvals from other units of government as may be required by law.