

**CS Part 16. Power Transmission and Distribution
Detailed Comparison With
29 C.F.R. 1926 Subpart V – Power Transmission and Distribution
29 C.F.R. 1910**

- Rubber protective equipment certification; use and storage
- Head protection

The comparisons show only those provisions where MIOSHA rules are different than OSHA or where MIOSHA rules are not included in 29 C.F.R.

MIOSHA	OSHA												
<p>R 408.41632 Rubber protective equipment; certification; use and storage. Rule 1632 (1)**** (4) Rubber insulating sleeves and blankets shall be given a visual inspection and an electrical test by a trained employee or outside service within 12 months after purchase and not less than once each 12-month period thereafter. (5) Rubber insulating gloves shall be given an electrical test by a trained employee or outside service at intervals as prescribed in the American Society of Testing and Materials (ASTM) F496, 2004 edition, Standard Specifications for In-Service Care of Insulating Gloves and Sleeves, which is adopted by reference in R 408.41610. (6) The maximum interval for the electrical retesting of gloves required by ASTM F496, 2004 edition, is shown in table 3. (7) Table 3 reads as follows:</p> <div style="text-align: center; margin: 10px 0;"> <table border="1" style="margin: auto; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="background-color: #e0e0e0;">TABLE 3</th> </tr> <tr> <th colspan="2" style="background-color: #e0e0e0;">Electrical Retesting of Gloves</th> </tr> <tr> <th style="background-color: #e0e0e0;">Description</th> <th style="background-color: #e0e0e0;">Maximum Interval Between Tests</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1. Gloves, in use</td> <td style="text-align: center;">6 Months</td> </tr> <tr> <td style="text-align: center;">2. Gloves, in use by telecommunication industry</td> <td style="text-align: center;">9 Months</td> </tr> <tr> <td style="text-align: center;">3. Gloves, tested but not issues for service</td> <td style="text-align: center;">12 Months</td> </tr> </tbody> </table> </div> <p style="text-align: center; margin: 10px 0;">NOTE: THE INTERVAL BETWEEN TESTS SHOULD TAKE INTO CONSIDERATION WORK PRACTICES AND TEST EXPERIENCE.</p> <p>(8) The equipment shall be dated or coded with the date of purchase or issuance and the date of each periodic test. The electrical test shall be performed in accordance with the applicable American Society of Testing and Materials standard listed in table 2. (9) Equipment listed in table 2 shall be visually inspected for cracks, cuts, punctures, and thin spots before each use. Where insulating gloves are required and used, they shall be manually air tested daily before starting work.</p>	TABLE 3		Electrical Retesting of Gloves		Description	Maximum Interval Between Tests	1. Gloves, in use	6 Months	2. Gloves, in use by telecommunication industry	9 Months	3. Gloves, tested but not issues for service	12 Months	<p>1926.951(a) Protective equipment. 1926.951(a)(1)(i) Rubber protective equipment shall be in accordance with the provisions of the American National Standards Institute (ANSI), ANSI J6 series, as follows:</p> <p style="margin-left: 20px;">See Table</p> <p>1926.951(a)(1)(ii) Rubber protective equipment shall be visually inspected prior to use. 1926.951(a)(1)(iii) In addition, an "air" test shall be performed for rubber gloves prior to use. 1926.951(a)(1)(iv) Protective equipment of material other than rubber shall provide equal or better electrical and mechanical protection.</p>
TABLE 3													
Electrical Retesting of Gloves													
Description	Maximum Interval Between Tests												
1. Gloves, in use	6 Months												
2. Gloves, in use by telecommunication industry	9 Months												
3. Gloves, tested but not issues for service	12 Months												

MIOSHA	OSHA
<p>(10) Equipment not meeting the electrical test requirements, visual inspection, or manual air test for flaws, scuffs, snags, punctures, and foreign substances, such as oil, dirt, or grease, shall be removed from service.</p> <p>(11) An insulated blanket, glove, or sleeve shall be capable of withstanding the voltage to which it may be subjected.</p> <p>(12) Insulating gloves, sleeves, and blankets shall be kept as free as possible from ozone, chemicals, heat, oils, solvents, damaging vapors, fumes, electrical discharges, and sunlight. The gloves, sleeves, and blankets shall be stored in a bag, box, container, or compartment that is designed and used exclusively for their storage and shall not be folded, creased, or compressed.</p>	
<p>R 408.41633 Head protection.</p> <p>Rule 1633. (1) A class B helmet for the protection of an employee exposed to voltages of more than 600 volts shall bear a certification by the manufacturer that the helmet is as prescribed in the American National Standard Institute (ANSI) standard, Z89.2, 1971 edition, Industrial Protective Helmets for Electrical Workers, which is adopted by reference in R 408.41610.</p> <p>(2) A helmet, provided for and as prescribed in construction safety standard, Part 6 Personal Protective Equipment, R 408.40617 and R 408.40621, shall be used to protect the employee where a hazard or risk of injury exists from falling or flying objects or particles or from other harmful contacts or exposures.</p> <p>(3) Where there is exposure to electrical contact, helmet liners or wind guards shall not be in contact with the outside shell of the helmet.</p>	<p>1926.951(a)(2)</p> <p>Protective hats shall be in accordance with the provisions of ANSI Z89.2-1971 Industrial Protective Helmets for Electrical Workers, Class B, and shall be worn at the jobsite by employees who are exposed to the hazards of falling objects, electric shock, or burns.</p>

Disclaimer:

Documents available from this server were prepared as a courtesy for informal guidance and assistance. This information is not intended to replace or supercede the actual MIOSHA standard or rule requirement. Please reference the specific MIOSHA standard or rule for the actual rule requirement language.

All information published online by MIOSHA is subject to change without notice. Every effort is made to ensure that the information provided at this site is accurate and up-to-date, but no legal responsibility is accepted for any errors, omissions, or misleading statement.