

CERTIFICATE OF ACCEPTABILITY

NO. 1595-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 PA 230, being Section 125.1521 of the Michigan Compiled Laws, on the recommendation of the Board of Mechanical Rules.

MANUFACTURER: The Melting Pot Restaurants, Inc.
8810 Twin Lakes Blvd.
Tampa, FL 33614


PRODUCT: Cooktek induction cooktop, Mosshaim infrared cooktop and Bon Chef Pot.

CONDITIONS OF USE AND INSTALLATION:

- 1 The additional heat and moisture loads generated by such appliances shall be accounted for in the design of the HVAC system.
- 2 For the purpose of determining the floor area required to be ventilated, each individual appliance that is not required to be installed under a hood shall be considered as occupying not less than 100 square feet for determination of ventilation capacity, inclusive of ventilation capacity required prior to consideration of unhooded appliances.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission



Irvin J. Poke, AIA
Executive Director



Tennison B. Barry, Chief, Mechanical Division

Effective Date: January 9, 2009