



JENNIFER M. GRANHOLM
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENERGY, LABOR & ECONOMIC GROWTH
LANSING

STANLEY "SKIP" PRUSS
DIRECTOR

July 15, 2009

Mr. Jeff Thomas
Diversified Products & Research Inc.
dba Future Tools
13591 Cable Road
Pataskala, OH 43062

Dear Mr. Thomas:

At the Construction Code Commission meeting on July 1, 2009, the Plumbing Division presented your request for approval of the Go Aerosol Spray Weld, Spray on solvent weld cement for PVC.

The Construction Code Commission, upon recommendation of the State Plumbing Board, approved the use of the Go Aerosol Spray Weld, Spray on solvent weld cement for PVC with the following conditions:

1. Shall not be acceptable between different types of plastic materials, such as PVC to ABS.
2. Shall be utilized in accordance with manufacturer's instructions.
3. Shall only be utilized for PVC drainage and vent applications, schedule 40 and 80 up to 6 inches.

Should any change be made in the design or designation of these products, the modified products must be submitted to this office and a new acceptance obtained.

In accordance with Section 21 of 1972 PA 230, neither this letter nor the Certificate of Acceptability may be used for advertising or promotional purposes.

A Certificate of Acceptability is enclosed.

Sincerely,

Irvin J. Poke, AIA
Director

RGK/mkr
Enclosure

cc: Duane Branch, Chairperson, State Plumbing Board

Providing for Michigan's Safety in the Built Environment

BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254 • LANSING, MICHIGAN 48909
Telephone (517) 241-9330 • Fax (517) 373-8547
www.michigan.gov/dleg

DELEG is an equal opportunity employer/program.
Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.

MICHIGAN DEPARTMENT OF ENERGY, LABOR & ECONOMIC GROWTH
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1599-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division.

MANUFACTURER:

Diversified Products & Research Inc. dba Future Tools

PRODUCT:

Go Aerosol Spray Weld, Spray on solvent weld cement for PVC

MANUFACTURER DESIGNATION:

13591 Cable Road
Pataskala, Ohio 43062

CONDITIONS OF USE AND INSTALLATION:

1. Shall not be acceptable between different types of plastic materials, such as PVC to ABS.
2. Shall be utilized in accordance with manufacturer's instructions.
3. Shall only be utilized for PVC drainage, waste and vent applications, schedule 40 and 80 up to 6 inches.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission



Irvin J. Poke, AIA, Director

Robert Konyndyk - Chief, Plumbing Division

Effective Date: