MICHIGAN DEPARTMENT OF ENERGY, LABOR & ECONOMIC GROWTH
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY

PRODUCT APPROVAL

1614-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division. This product was reviewed to the 2006 Michigan Mechanical Code.

MANUFACTURER:
Mueller Industries

PRODUCT:
Stream Tech Structural Adhesive

MANUFACTURER DESIGNATION:
82285 Tournament Drive
Memphis, TN 38125

CONDITIONS OF USE AND INSTALLATION:

1. Must be installed to the Michigan Plumbing Code. The potable water distribution system utilizing the Stream Tech Structural Adhesive fitting must be pressure tested and inspected in accordance with MPC section 312.5, IRC section P2503.6 as applicable.
2. Must be installed to the Michigan Mechanical Code. Hydronic piping must be pressure tested in accordance with MMC section 1208, IRC section 1208, IRC section M2101.10, M2103.3 or M2105 as applicable.
3. The structural adhesive joining system has a maximum pressure rating of 250 psi and 108 degrees F.
4. When soldering nearby, installers must stay at least three pipe diameters from a Stream Tech connector and use a wet rag or other heat sink.
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Mechanical Code.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Tennison Barry –Chief, Mechanical Division

Effective Date: 07/07/2010