MICHIGAN DEPARTMENT OF ENERGY, LABOR & ECONOMIC GROWTH
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL
1617-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2006 Michigan Plumbing Code.

MANUFACTURER:

Invacare Continuing Care, Inc.

PRODUCT:

Invacare, Models Access 3602GXL, 3652G, 3752G, 3802G, 6302G, and 6302GADH hydro-therapy whirlpool tubs.

MANUFACTURER DESIGNATION:

One Invacare Way
Elyria, Ohio 44035

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing and Electrical Codes shall be applicable.
2. Installations shall be in accordance with the manufacturer's specifications.
3. Requests from hospital or care institutions must be approved by the Health Department having jurisdiction.
4. Both hot and cold water supplies shall be protected by and approved for reduced pressure principle backflow preventer.
5. The unit shall discharge into an approved waste receptor.
6. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Robert Konyndyk – Chief, Plumbing Division

Effective Date: October 6, 2010

BCC-978 (Rev. 10/10)