


SECTION 4.3 – ASBESTOS HOMOGENEOUS AREAS REPORT



**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 1
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Michigan Mart
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Mud Compound Joint and Fitting Insulation on Glass Domestic Water Lines	1	F	ND	T	None Detected	---	25 Joints	25 Joints
Grey, Fine Weave Vibration Dampening Cloth	2	NF	ND	M	None Detected	---	8 Sq. Ft.	8 Sq. Ft.
Roof Shingles - Black	3	NF	ND	M	None Detected	---	NQ	NQ
Drywall	4	NF	ND	M	None Detected	---	NQ	NQ

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 2
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: West Mall
Date: 16-May-09

Homogeneous Material Report

Homogeneous


Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Drywall	1	NF	ND	M	None Detected	---	NQ	NQ

Legend: Friable/Non-Friable
F = Friable
NF = Non-Friable

Asbestos Presence
K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification
T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity
NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563

Building No.: 3

Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center

Building: Agriculture Building

Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Window Caulk	1	NF	K	M	Chrysotile	3%	7320 Lin. Ft.	7320 Lin. Ft.
1' x 2' Block Flooring Material - Black	2	NF	K	M	Chrysotile	10%	24990 Sq. Ft.	24990 Sq. Ft.
Cork Insulation Board	3	NF	ND	M	None Detected	---	550 Sq. Ft.	550 Sq. Ft.
Fire Door	4	NF	A	M	Assumed	---	18 Door(s)	18 Door(s)
Plaster	5	NF	ND	S	None Detected	---	NQ	NQ
4" Black Vinyl Cove Base	6	NF	ND	M	None Detected	---	Lin. Ft	338 Lin. Ft

Legend: Friable/Non-Friable

F = Friable

NF = Non-Friable

Asbestos Presence

K = known to contain asbestos

A = assumed to contain asbestos

ND = asbestos not detected by laboratory analysis

NA = material identified as non-asbestos
by inspector

Classification


T = thermal system insulation

S = surfacing material

M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563

Building No.: 5

Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center

Building: Coliseum

Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Aircell Pipe Insulation	3	F	K	T	Chrysotile	35%	1497 Lin. Ft.	1448 Lin. Ft.
Mud Compound Joint and Fitting Insulation on Aircell Pipe Insulation	4	F	K	T	Chrysotile	35%	118 Joints	97 Joints
Tank Insulation	5	F	K	T	Chrysotile Amosite	40% 20%	264 Sq. Ft.	322 Sq. Ft.
Boiler Insulation	6	F	K	T	Amosite Chrysotile	35% 10%	672 Sq. Ft.	366 Sq. Ft.
Interior Boiler Materials	7	F	A	T	Assumed	---	NQ	NQ
Boiler Duct Insulation	8	F	K	T	Amosite Crocidolite Chrysotile	20% 5% 3%	242 Sq. Ft.	242 Sq. Ft.
Fire Door	9	NF	A	M	Assumed	---	12 Door(s)	12 Door(s)
Drywall	10	NF	ND	M	None Detected	---	NQ	NQ

Legend: Friable/Non-Friable

F = Friable

NF = Non-Friable

Asbestos Presence

K = known to contain asbestos

A = assumed to contain asbestos

ND = asbestos not detected by laboratory analysis

NA = material identified as non-asbestos

by inspector

Classification


T = thermal system insulation

S = surfacing material

M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563

Building No.: 5

Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center

Building: Coliseum

Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
9" x 9" Floor Tile - Tan with Brown and White Streaks	11	NF	K	M	Chrysotile	3%	109 Sq. Ft.	109 Sq. Ft.
3' x 3' Vinyl Sheet Flooring - Off-White with Light Grey Streaks	12	NF	ND	M	None Detected	---	3458 Sq. Ft.	3458 Sq. Ft.
4" Black Cove Base	13	NF	ND	M	None Detected	---	1072 Sq. Ft.	1072 Sq. Ft.
2' x 2' Ceiling Tile - White with Random Pits and Pinholes	14	F	ND	M	None Detected	---	6189 Sq. Ft.	6189 Sq. Ft.
Mud Compound Joint and Fitting Insulation on Glass Domestic Water Lines	15	F	ND	T	None Detected	---	397 Joints	397 Joints
2' x 2' Ceiling Tile - White - Smooth	16	F	ND	M	None Detected	---	30 Sq. Ft.	30 Sq. Ft.
3' x 3' Vinyl Flooring - Teal with White Streaks	17	NF	ND	M	None Detected	---	1993 Sq. Ft.	1993 Sq. Ft.
2' x 2' Ceiling Tile - White with Lateral Grooves and Random Pinholes	18	F	ND	M	None Detected	---	1788 Sq. Ft.	1788 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable

NF = Non-Friable

Asbestos Presence

K = known to contain asbestos

A = assumed to contain asbestos

ND = asbestos not detected by laboratory analysis

NA = material identified as non-asbestos

by inspector

Classification


T = thermal system insulation

S = surfacing material

M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563

Building No.: 5

Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center

Building: Coliseum

Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Window Caulk	19	NF	ND	M	None Detected	---	2508 Lin. Ft.	2508 Lin. Ft.
2' x 2' Ceiling Tile - White with Random Pits and Pinholes - Recessed	20	F	ND	M	None Detected	---	1444 Sq. Ft.	1444 Sq. Ft.
2' x 4' Ceiling Tile - White - Smooth	21	F	ND	M	None Detected	---	209 Sq. Ft.	209 Sq. Ft.
2' x 4' Ceiling Tile - White - Textured	22	F	ND	M	None Detected	---	322 Sq. Ft.	322 Sq. Ft.
2' x 4' Ceiling Tile - White - Lateral Pits and Random Pinholes	23	F	ND	M	None Detected	---	336 Sq. Ft.	336 Sq. Ft.
Textured Paint	24	NF	ND	M	None Detected	---	NQ	NQ
2' x 4' Ceiling Tile - White - Random Pits and Pinholes	25	F	ND	M	None Detected	---	192 Sq. Ft.	192 Sq. Ft.
2' x 2' Ceiling Tile - White - Long Lateral Grooves and Pinholes	26	F	ND	M	None Detected	---	351 Sq. Ft.	351 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable

NF = Non-Friable

Asbestos Presence

K = known to contain asbestos

A = assumed to contain asbestos

ND = asbestos not detected by laboratory analysis

NA = material identified as non-asbestos

by inspector

Classification


T = thermal system insulation

S = surfacing material

M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 5
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Coliseum
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
12" x 12" Floor Tile - Tan and Light Brown - Square Pattern	27	NF	ND	M	None Detected	---	559 Sq. Ft.	559 Sq. Ft.
Black Fine Weave Vibration Dampening Cloth	28	NF	ND	M	None Detected	---	8 Sq. Ft.	8 Sq. Ft.
Tank Wrap on Domestic Hot Water	29	F	ND	T	None Detected	---	168 Sq. Ft.	168 Sq. Ft.
Dark Green Rubber Flooring	30	NF	ND	M	None Detected	---	240 Sq. Ft.	240 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 6
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Dairy Cattle Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Window Caulk	1	NF	ND	M	None Detected	---	4253 Lin. Ft.	4253 Lin. Ft.
Fire Door	2	NF	A	M	Assumed	---	1 Door(s)	1 Door(s)
Drywall	3	NF	ND	M	None Detected	---	NQ	NQ

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 9
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Main Horse Barn
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Window Caulk	1	NF	K	M	Chrysotile	5%	720 Lin. Ft.	720 Lin. Ft.
Transite Panels - Corrugated	2	NF	K	M	Chrysotile	30%	360 Sq. Ft.	360 Sq. Ft.

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784


Job No.: 081563
Building No.: 11
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Grand Champion Barn
Date: 16-May-09

Homogeneous Material Report

Homogeneous					
Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type
Roof Shingles - Green	1	NF	ND	M	None Detected

					1664 Sq. Ft.
					1664 Sq. Ft.

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable NF = Non-Friable	K = known to contain asbestos A = assumed to contain asbestos ND = asbestos not detected by laboratory analysis NA = material identified as non-asbestos by inspector	T = thermal system insulation S = surfacing material M = miscellaneous material	NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 12
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Mult-Livestock Barn
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
12" x 12" Floor Tile - Tan, Brown and Cream Mottling	1	NF	ND	M	None Detected	---	648 Sq. Ft.	648 Sq. Ft.
2' x 2' Ceiling Tile - White - Random Large and Small Holes	2	F	ND	M	None Detected	---	2586 Sq. Ft.	2594 Sq. Ft.
2' x 2' Ceiling Tile - White - Lateral Grooves and Random Pinholes	3	F	ND	M	None Detected	---	108 Sq. Ft.	100 Sq. Ft.
4" Brown Cove Base	4	NF	ND	M	None Detected	---	406 Sq. Ft.	406 Sq. Ft.

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 13
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Whitehall
Date: 16-May-09

Homogeneous Material Report

Homogeneous


Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Plaster	1	NF	ND	S	None Detected	---	NQ	NQ
Window Caulk	2	NF	ND	M	None Detected	---	3520 Lin. Ft.	3520 Lin. Ft.
Roofing Material	3	NF	K	M	Chrysotile	10%	12480 Sq. Ft.	12480 Sq. Ft.

Legend: Friable/Non-Friable
F = Friable
NF = Non-Friable

Asbestos Presence
K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification
T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity
NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563

Building No.: 14

Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center

Building: Volunteer Headquarters

Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Mud Compound Joint and Fitting Insulation on Glass Domestic Water Lines	1	F	K	T	Chrysotile	45%	13 Joints	9 Joints
Aircell Pipe Insulation	2	F	K	T	Chrysotile	40%	155 Lin. Ft.	132 Lin. Ft.
Mud Compound Joint and Fitting Insulation on Aircell Pipe Insulation	3	F	K	T	Chrysotile	20%	19 Joints	17 Joints
12" x 12" Ceiling Tile - White - Uniformed Pencil Holes - Glued On	4	F	ND	M	None Detected	---	1659 Sq. Ft.	1659 Sq. Ft.
12" x 12" Ceiling Tile - White - Random Pinholes - Nailed On	5	F	ND	M	None Detected	---	185 Sq. Ft.	185 Sq. Ft.
Plaster	6	NF	ND	S	None Detected	---	NQ	NQ
9" x 9" Floor Tile - Tan with White and Brown Streaks	7	NF	K	M	Chrysotile	1 - 2%	134 Sq. Ft.	100 Sq. Ft.
4" Brown Cove Base	8	NF	ND	M	None Detected	---	66 Sq. Ft.	60 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable

NF = Non-Friable

Asbestos Presence

K = known to contain asbestos

A = assumed to contain asbestos

ND = asbestos not detected by laboratory analysis

NA = material identified as non-asbestos

by inspector

Classification


T = thermal system insulation

S = surfacing material

M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 14
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Volunteer Headquarters
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Roofing Materials	9	NF	A	M	Assumed	---	2625 Sq. Ft.	2625 Sq. Ft.
2' x 4' Ceiling Tile, White	10	F	ND	M	None Detected	-----	Sq. Ft.	1844 Sq. Ft.

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos
by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 15
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Band Shell
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
4" Black Cove Base	1	NF	ND	M	None Detected	---	120 Lin. Ft.	120 Lin. Ft.
2' x 2' Ceiling Tile - White with Lateral Grooves and Random Pinholes	2	F	ND	M	None Detected	---	288 Sq. Ft.	288 Sq. Ft.
3" Brown Cove Base	3	NF	ND	M	None Detected	---	46 Sq. Ft.	46 Sq. Ft.
2' x 4' Ceiling Tile - White with Lateral Grooves and Random Pinholes	4	F	ND	M	None Detected	---	132 Sq. Ft.	132 Sq. Ft.
Roof Flashing	5	NF	ND	M	None Detected	---	NQ	NQ
Roof Shingles	6	NF	ND	M	None Detected	---	NQ	NQ
Roofing Tar Paper	7	NF	K	M	Chrysotile	60%	7088 Sq. Ft.	7088 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 16
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Dodge Pavilion
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
12" x 12" Ceiling Tile - White - Glued-On - Lateral Grooves and Pinholes	1	F	K	M	Chrysotile	3%	3383 Sq. Ft.	3383 Sq. Ft.
Woolfelt Pipe Insulation on Domestic Water Lines	2	F	K	T	Chrysotile	40%	253 Lin. Ft.	253 Lin. Ft.
Mud Compound Joint and Fitting Insulation on Woolfelt Pipe Insulation on Domestic Water Lines	3	F	K	T	Chrysotile	30%	50 Joints	53 Joints
Drywall	4	NF	ND	M	None Detected	---	NQ	NQ
Magnesium Silicate Pipe Insulation on Heat Exchanger	5	F	K	T	Chrysotile Amosite	35% 5%	32 Lin. Ft.	32 Lin. Ft.
Magnesium Silicate Pipe Insulation on Heating Lines	6	F	K	T	Chrysotile Amosite	40% 5%	20 Lin. Ft.	20 Lin. Ft.
Mud Compound Joint and Fitting Insulation on Magnesium Silicate Pipe Insulation Heating Lines	7	F	K	T	Chrysotile	40%	16 Joints	16 Joints
Magnesium Silicate Pipe Insulation on Duct Insulation	8	F	K	T	Amosite	30%	32 Sq. Ft.	32 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**


693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 16
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Dodge Pavilion
Date: 16-May-09

Homogeneous Material Report

Homogeneous						
Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage
Fire Door	9	NF	A	M	Assumed	---
Boiler Materials	10	NF	K	M	Chrysotile	80%
9" x 9" Floor Tile - Grey with Black and White Streaks	11	NF	K	M	Chrysotile	3%
9" x 9" Floor Tile - Red with White Streaks	12	NF	K	M	Chrysotile	5%
						1 Door(s)
						1 Door(s)
						30 Lin. Ft.
						54 Sq. Ft.
						27 Sq. Ft.

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable	K = known to contain asbestos	T = thermal system insulation	NQ = Not Quantified
	NF = Non-Friable	A = assumed to contain asbestos	S = surfacing material	
		ND = asbestos not detected by laboratory analysis	M = miscellaneous material	
		NA = material identified as non-asbestos by inspector		



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 17
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Grants House
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Plaster	1	NF	ND	S	None Detected	---	NQ	NQ
12" x 12" Floor Tile - Off-White - Octagon Pattern	2	NF	K	M	Chrysotile	3%	89 Sq. Ft.	89 Sq. Ft.
2' x 2' Ceiling Tile - White with Lateral Grooves and Random Pinholes	3	F	ND	M	None Detected	---	51 Sq. Ft.	51 Sq. Ft.
Drywall	4	NF	ND	M	None Detected	---	NQ	NQ
12" x 12" Floor Tile with Blue Marbling	5	NF	ND	M	None Detected	---	Sq. Ft.	123 Sq. Ft.
12" x 12" Floor Tile with Tan Marbling	6	NF	ND	M	None Detected	---	Sq. Ft.	25 Sq. Ft.

Legend: Friable/Non-Friable

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified




**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 18
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Administration Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material		Asbestos Presence	Classification	Asbestos Type	Percentage	1999		2009	
Friable/Non-Friable	Material Number	Friable/Non-Friable	Material Number					Quantity	Quantity	Quantity	Quantity
2' x 4' Ceiling Tile - White - Lateral Grooves and Random Pinholes	1	F	1	ND	M	None Detected	---	5840 Sq. Ft.	5840 Sq. Ft.	5744 Sq. Ft.	5744 Sq. Ft.
12" x 12" Floor Tile - Off-White with Black Textured Streaks	2	NF	2	ND	M	None Detected	---	608 Sq. Ft.	608 Sq. Ft.	574 Sq. Ft.	574 Sq. Ft.
4" Grey Cove Base	3	NF	3	ND	M	None Detected	---	897 Lin. Ft.	897 Lin. Ft.	205 Lin. Ft.	205 Lin. Ft.
Plaster	4	NF	4	ND	S	None Detected	---	NQ	NQ	NQ	NQ
4" Brown Cove Base	5	NF	5	ND	M	None Detected	---	362 Lin. Ft.	362 Lin. Ft.	534 Lin. Ft.	534 Lin. Ft.
Mud Compound Joint and Fitting Insulation on Glass Heating Lines	6	F	6	K	T	Chrysotile	20%	88 Joints	88 Joints	84 Joints	84 Joints
4" Black Cove Base	7	NF	7	ND	M	None Detected	---	102 Lin. Ft.	102 Lin. Ft.	102 Lin. Ft.	102 Lin. Ft.
Drywall	8	NF	8	ND	S	None Detected	---	NQ	NQ	NQ	NQ

Legend:		Asbestos Presence		Classification		Quantity	
Friable/Non-Friable		K = known to contain asbestos		T = thermal system insulation		NQ = Not Quantified	
F = Friable		A = assumed to contain asbestos		S = surfacing material			
NF = Non-Friable		ND = asbestos not detected by laboratory analysis		M = miscellaneous material			
		NA = material identified as non-asbestos by inspector					



**Materials
Testing
Consultants, INC.**


693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 18
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Administration Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous						
Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage
Fire Door	9	NF	A	M	Assumed	---
12" x 12" White - Random Grooves and Pinholes	10	F	ND	M	None Detected	---
12" x 12" Floor Tile, Gray with White and Black Flecks	11	NF	ND	M	None Detected	---
Sheet Roofing	12	NF	ND	M	None Detected	---
						3 Door(s)
						5 Door(s)
						96 Sq. Ft.
						120 Sq. Ft.
						Sq. Ft.
						200 Sq. Ft.
						NQ

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable	K = known to contain asbestos	T = thermal system insulation	NQ = Not Quantified
	NF = Non-Friable	A = assumed to contain asbestos	S = surfacing material	
		ND = asbestos not detected by laboratory analysis	M = miscellaneous material	
		NA = material identified as non-asbestos by inspector		



**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 19
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Community Arts Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Aircell Pipe Insulation on Heating Lines	1	F	K	T	Chrysotile	40%	1060 Lin. Ft.	1224 Lin. Ft.
Aircell Pipe Insulation on Joints on Heating Lines	2	F	K	T	Chrysotile	10%	251 Joints	268 Joints
Mud Compound Joint and Fitting Insulation on Glass Heating Lines	3	F	ND	T	None Detected	---	43 Joints	43 Joints
Boiler Insulation/Wrap	4	F	K	T	Chrysotile Amosite	10 - 45% 35%	56 Sq. Ft.	168 Sq. Ft.
Boiler Duct Insulation	5	F	K	T	Chrysotile Amosite	10 - 45% 35%	168 Sq. Ft.	96 Sq. Ft.
Magnesium Silicate Pipe Insulation on Heat Exchanger	6	F	K	T	Chrysotile Amosite	10 - 45% 35%	21 Sq. Ft.	21 Sq. Ft.
Fire Door	7	NF	A	M	Assumed	---	14 Door(s)	16 Door(s)
Woolfelt Pipe Insulation on Domestic Cold Water	8	F	K	T	Chrysotile	40%	1170 Lin. Ft.	1097 Lin. Ft.

Legend: Friable/Non-Friable

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified




**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 19
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Community Arts Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Mud Compound Joint and Fitting Insulation on Woolfelt Pipe Insulation		9	F	K	T	Chrysotile	10%	299 Joints	284 Joints
Plaster		10	NF	ND	S	None Detected	---	Sq. Ft.	Sq. Ft.
2' x 2' Ceiling Tile - White with Lateral Grooves and Random Pinholes		11	NF	ND	M	None Detected	---	23364 Sq. Ft.	23364 Sq. Ft.
4" Black Cove Base		12	NF	ND	M	None Detected	---	832 Lin. Ft.	558 Lin. Ft.
9" x 9" Floor Tile - Tan with Brown and White Streaks		13	NF	K	M	Chrysotile	3%	6479 Sq. Ft.	6625 Sq. Ft.
Green - Fine Weave Vibration Dampening Cloth		14	NF	ND	M	None Detected	---	192 Sq. Ft.	160 Sq. Ft.
12" x 12" Ceiling Tile - White with Lateral Grooves and Random Pinholes - Glued On		15	F	ND	M	None Detected	---	3054 Sq. Ft.	3054 Sq. Ft.
9" x 9" Floor Tile - Green with White Streaks		16	NF	K	M	Chrysotile	5%	694 Sq. Ft.	694 Sq. Ft.

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable NF = Non-Friable	K = known to contain asbestos A = assumed to contain asbestos ND = asbestos not detected by laboratory analysis NA = material identified as non-asbestos by inspector	T = thermal system insulation S = surfacing material M = miscellaneous material	NQ = Not Quantified




**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 19
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Community Arts Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Drywall		17	NF	ND	M	None Detected	---	NQ	NQ
9" x 9" Floor Tile - Red with White Streaks		18	NF	K	M	Chrysotile	5%	280 Sq. Ft.	280 Sq. Ft.
12" x 12" Ceiling Tile - White with Random Holes and Pinholes - Glued On		19	F	ND	M	None Detected	---	1040 Sq. Ft.	800 Sq. Ft.
4" Brown Cove Base		20	NF	ND	M	None Detected	---	688 Sq. Ft.	688 Sq. Ft.
Sprayed On Acoustical Material		21	F	K	S	Chrysotile	15%	6088 Sq. Ft.	6108 Sq. Ft.
Roof Flashing		23	NF	K	M	Chrysotile	3%	2276 Sq. Ft.	2276 Sq. Ft.
Roofing Tar		24	NF	A	M	Assumed	---	34724 Sq. Ft.	34724 Sq. Ft.
Internal Boiler Material		25	NF	A	T	Assumed	---	Each	1 Each

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable	K = known to contain asbestos	T = thermal system insulation	NQ = Not Quantified
	NF = Non-Friable	A = assumed to contain asbestos	S = surfacing material	
		ND = asbestos not detected by laboratory analysis	M = miscellaneous material	
		NA = material identified as non-asbestos by inspector		




**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 19
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Community Arts Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material		Friable/Non-Friable		Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
4" Grey Vinyl Cove Base		Material Number	26	NF	NF	ND	M	None Detected	---	126 Lin. Ft.	206 Lin. Ft.

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable	K = known to contain asbestos	T = thermal system insulation	NQ = Not Quantified
	NF = Non-Friable	A = assumed to contain asbestos	S = surfacing material	
		ND = asbestos not detected by laboratory analysis	M = miscellaneous material	
		NA = material identified as non-asbestos by inspector		



**Materials
Testing
Consultants, INC.**


693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 23
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Exhibit Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material				Asbestos		Percentage		Quantity	
Homogeneous Material (HM)	Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage		1999 Quantity	2009 Quantity
Window Caulk	1	NF	ND	M	None Detected	---		44 Sq. Ft.	44 Sq. Ft.

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable NF = Non-Friable	K = known to contain asbestos A = assumed to contain asbestos ND = asbestos not detected by laboratory analysis NA = material identified as non-asbestos by inspector	T = thermal system insulation S = surfacing material M = miscellaneous material	NQ = Not Quantified



**Materials
Testing
Consultants, INC.**


693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 24
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: Poultry Building
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material		Asbestos Presence	Classification	Asbestos Type	Percentage	1999		2009	
Friable/Non-Friable	Number	Friable/Non-Friable	Number					Quantity	Type	Quantity	Type
2' x 2' Ceiling Tile - White - Smooth	1	F	1	ND	M	None Detected	---	705 Sq. Ft.		705 Sq. Ft.	
Fire Door	2	NF	2	A	M	Assumed	---	4 Door(s)		4 Door(s)	
12" x 12" Floor Tile - Dark Red with Red and Tan Streaks	3	NF	3	K	M	Chrysotile	3%	85 Sq. Ft.		85 Sq. Ft.	
Roof Shingles - Brown	4	NF	4	ND	M	None Detected	---	NQ		NQ	

Legend:		Asbestos Presence		Classification		Quantity	
Friable/Non-Friable		K = known to contain asbestos		T = thermal system insulation		NQ = Not Quantified	
F = Friable		A = assumed to contain asbestos		S = surfacing material			
NF = Non-Friable		ND = asbestos not detected by laboratory analysis		M = miscellaneous material			
		NA = material identified as non-asbestos by inspector					



**Materials
Testing
Consultants, INC.**


693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 25
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Milk House
Date: 16-May-09

Homogeneous Material Report

Homogeneous									
Homogeneous Material (HM)		Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Transite Panels		1	NF	K	M	Chrysotile	30%	24 Sq. Ft.	24 Sq. Ft.
Window Caulk		2	NF	ND	M	None Detected	---	240 Lin. Ft.	240 Lin. Ft.
Roof Shingles - Red/Grey		3	NF	ND	M	None Detected	---	Sq. Ft.	Sq. Ft.

Legend:		Asbestos Presence		Classification		Quantity	
Friable/Non-Friable		K = known to contain asbestos		T = thermal system insulation		NQ = Not Quantified	
F = Friable		A = assumed to contain asbestos		S = surfacing material			
NF = Non-Friable		ND = asbestos not detected by laboratory analysis		M = miscellaneous material			
		NA = material identified as non-asbestos by inspector					




**Materials
Testing
Consultants, INC.**
693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 26
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Red Brick Comfort Station
Date: 16-May-09

Homogeneous Material Report

Homogeneous Material (HM)		Homogeneous Material		Asbestos Presence	Classification	Asbestos Type	Percentage		Quantity	
Friable/Non-Friable	Number	Friable/Non-Friable	Number				1999	2009	1999	2009
Window Caulk	1	NF	NF	ND	M	None Detected	--	--	820 Lin. Ft.	820 Lin. Ft.
Roof Tar on Flashing	2	NF	NF	K	M	Chrysotile	5%	5%	1870 Sq. Ft.	1870 Sq. Ft.

Legend:		Asbestos Presence		Classification		Quantity	
Friable/Non-Friable		Asbestos Presence		Classification		Quantity	
F = Friable		K = known to contain asbestos		T = thermal system insulation		NQ = Not Quantified	
NF = Non-Friable		A = assumed to contain asbestos		S = surfacing material			
		ND = asbestos not detected by laboratory analysis		M = miscellaneous material			
		NA = material identified as non-asbestos by inspector					



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 28
Project: Updated Survey of Asbestos and Limited Lead Based Paint for Michigan State Fairgrounds & Exhibition Center
Building: Restrooms (North)
Date: 16-May-09

Homogeneous Material Report

Homogeneous


Homogeneous Material (HM)	Material Number	Friable/Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999 Quantity	2009 Quantity
Mud Compound Joint and Fitting Insulation on Glass Domestic Waqter Lines	1	F	ND	T	None Detected	---	164 Joints	164 Joints
Fire Door	2	NF	A	M	Assumed	---	1 Door(s)	1 Door(s)
Black, Fine Weave Vibration Dampening Cloth	3	NF	ND	M	None Detected	---	12 Sq. Ft.	12 Sq. Ft.
Drywall	4	NF	ND	M	None Detected	---	NQ	NQ
Roof Shingles - Brown	5	NF	ND	M	None Detected	---	NQ	NQ

Legend: Friable/Non-Friable
F = Friable
NF = Non-Friable

Asbestos Presence
K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification
T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity
NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 30
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: White Brick Comfort Station
Date: 16-May-09

Homogeneous Material Report

Homogeneous

Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classification	Asbestos Type	Percentage	1999	2009
							Quantity	Quantity
Roofing Material - Upper Layer - Reddish Brown	1	NF	ND	M	None Detected	---	1920 Sq. Ft.	1920 Sq. Ft.
Roofing Material - Lower Layer - Silver	2	NF	K	M	Chrysotile	3%	1920 Sq. Ft.	1920 Sq. Ft.

Legend:

F = Friable
NF = Non-Friable

Asbestos Presence


K = known to contain asbestos
A = assumed to contain asbestos
ND = asbestos not detected by laboratory analysis
NA = material identified as non-asbestos by inspector

Classification

T = thermal system insulation
S = surfacing material
M = miscellaneous material

Quantity

NQ = Not Quantified



**Materials
Testing
Consultants, INC.**

693 Plymouth NE • Grand Rapids, MI 49505
(616) 456-5469 • FAX (616) 456-5784

Job No.: 081563
Building No.: 31
Project: Updated Survey of Asbestos and Limited Lead Based Paint for
Michigan State Fairgrounds & Exhibition Center
Building: White Electrical Shack
Date: 16-May-09

Homogeneous Material Report

Homogeneous						
Homogeneous Material (HM)	Material Number	Friable/ Non-Friable	Asbestos Presence	Classifi- cation	Asbestos Type	Percentage
Roof Shingles	1	NF	K	M	Chrysotile	3%
Transite Sheets	2	NF	K	M	Chrysotile	15%
Fire Door	3	NF	A	M	Assumed	---
						220 Sq. Ft.
						220 Sq. Ft.
						36 Sq. Ft.
						1 Door(s)

Legend:	Friable/Non-Friable	Asbestos Presence	Classification	Quantity
	F = Friable	K = known to contain asbestos	T = thermal system insulation	NQ = Not Quantified
	NF = Non-Friable	A = assumed to contain asbestos	S = surfacing material	
		ND = asbestos not detected by laboratory analysis	M = miscellaneous material	
		NA = material identified as non-asbestos by inspector		