



Fluoridation & Chlorination WSSN 2310 May-17

D A T E	Fluoride Applied F mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
					Chlorine App. Mg/l	Chlorine (prior to filtration) mg/L OCl ⁻	Post Chlorine mg/L	Sta II	Dort	3MG Well	Tap				
		Free	Free	Free					Free						
		14	15	16	17	18	19	20	21	22	23	24	25	26	27
1		0.63		1.15				0.9						1.8	
2		0.75		1.14				0.9						1.8	
3		0.83		1.12				0.9						1.9	
4		0.84		1.17				0.9						1.9	
5		0.80		1.15				0.8						1.8	
6		0.87		1.15				0.9						1.9	
7		0.86		1.14				0.9						1.9	
8		0.79		1.16				0.9						1.7	
9		0.82		1.22				0.9						1.8	
10		0.86		1.14				0.9						1.8	
11		0.83		1.16				0.9						1.8	
12		0.74		1.07				0.9						1.8	
13		0.76		1.11				0.9						1.9	
14		0.77		1.07				0.9						1.9	
15		0.75		1.12				0.9						1.8	
16		0.82		1.15				0.9						1.7	
17		0.80		1.11				1.0						1.8	
18		0.79		1.10				0.9						1.7	
19		0.88		1.06				0.9						1.8	
20		0.83		1.16				0.9						1.9	
21		0.77		1.13				0.9						1.8	
22		0.83		1.08				0.8						1.8	
23		0.83		1.05				0.9						1.7	
24		0.80		1.11				0.8						1.8	
25															
26															
27															
28															
29															
30															
31															
AVG		0.80		1.13				0.9						1.8	
MAX		0.88		1.22				1.0						1.9	
MIN		0.63		1.05				0.8						1.7	



Chemical Analyses WSSN 2310 May-17

D A T E	pH		Total Hardness as CaCO ₃ mg/l		Total Alkalinity as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l		Iron mg/L		Calcium Ca ²⁺ mg/l		Magnesium as Mg ²⁺ mg/l		Chloride as Cl ⁻ mg/l	
	CSII	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1	7.31	7.36		98		68		30		0.01		29.7		5.8		13
2	7.26	7.24		98		74		24		0.01		30.5		5.3		12
3	7.21	7.33		96		70		26		0.01		31.3		4.4		12
4	7.27	7.31		100		70		30		0.01		32.1		4.9		12
5	7.31	7.39		96		72		24		0.01		29.7		5.3		13
6	7.29	7.37		94		74		20		0.00		30.5		4.4		12
7	7.27	7.37		96		74		22		0.00		30.5		4.9		12
8	7.31	7.40		96		72		24		0.01		29.7		5.3		12
9	7.28	7.32		100		70		30		0.02		30.5		5.8		13
10	7.36	7.37		100		72		28		0.01		31.3		5.3		13
11	7.36	7.33		98		70		28		0.01		32.1		4.4		13
12	7.32	7.31		96		68		28		0.01		29.7		5.3		12
13	7.39	7.41		98		68		30		0.01		32.1		4.4		12
14	7.45	7.40		98		68		30		0.01		31.3		4.9		13
15	7.40	7.44		98		72		26		0.01		30.5		5.3		13
16	7.26	7.29		98		74		24		0.01		31.3		4.9		12
17	7.31	7.30		96		72		24		0.02		32.1		3.9		13
18	7.32	7.30		98		70		28		0.01		30.5		5.3		12
19	7.35	7.37		96		72		24		0.01		30.5		4.9		13
20	7.25	7.29		98		74		24		0		29.7		5.8		13
21	7.33	7.40		96		70		26		0.01		31.3		4.4		13
22	7.38	7.37		96		70		26		0.01		30.5		4.9		13
23	7.39	7.31		98		76		22		0.02		30.5		5.3		13
24	7.28	7.31		98		74		24		0.01		32.1		4.4		13
25																
26																
27																
28																
29																
30																
31																
AVG	7.32	7.35		97		71		26		0.01		30.8		5.0		13
MAX	7.45	7.44		100		76		30		0.02		32.1		5.8		13.0
MIN	7.21	7.24		94		68		20		0.00		29.7		3.9		12.0



WSSN 2310

May-17

D A T E	Total Coliform						66	Standard Plate Count		Conductivity (mS)	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			71	72	73	74
			Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1					2/0	2/0			0.21	7.6					
2					2/0	2/0		<2	0.21	7.9					
3					2/0	2/0			0.21	7.2					
4					2/0	2/0			0.21	7.5					
5					1/0	1/0			0.21	7.5					
6					2/0	2/0			0.20	7.9					
7					2/0	2/0			0.20	7.6					
8					2/0	2/0			0.21	8.1					
9					2/0	2/0		<2	0.21	7.9					
10					2/0	2/0			0.21	7.8					
11					2/0	2/0			0.21	8.0					
12					2/0	2/0			0.21	8.1					
13					2/0	2/0			0.21	8.2					
14					2/0	2/0			0.22	8.4					
15					2/0	2/0			0.22	8.3					
16					2/0	2/0		2	0.21	8.8					
17					2/0	2/0			0.21	9.6					
18					2/0	2/0			0.21	9.4					
19					2/0	2/0			0.21	9.6					
20					2/0	2/0			0.20	9.4					
21					2/0	2/0			0.21	9.3					
22					2/0	2/0			0.21	9.4					
23					2/0	2/0			0.21	9.6					
24									0.21	10.1					
25															
26															
27															
28															
29															
30															
31															
AVG									0.21	8.5					
MAX									0.22	10.1					
MIN									0.20	7.2					



Distribution System Monitoring WSSN 2310

May-17

DATE	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Number of Samples				
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	21	22	23	24	25					
1	1.35	1.26	1.52	1.45	1.44	1.31															1.18					7				
2							1.45	1.72	1.12	1.66		1.21											1.32			6				
3													1.18	1.58	1.06	1.51	1.50	1.00					1.80			7				
4					1.20	1.24						1.57												1.33		6				
5													1.09	1.02	0.99	1.57	1.42	1.11		0.97	1.43				1.37	7				
6																										0				
7																										0				
8	1.34	1.23	1.49	1.54	1.68	1.01																1.20				7				
9							1.52	1.67	1.64	1.70		1.24											1.11			6				
10													0.96	1.16	1.31	1.53	1.60	1.14						1.81		7				
11							1.41	1.68	1.62	1.69										0.99	1.32			1.44		7				
12	1.36	1.48	1.40	1.35																	1.39				1.33	6				
13																										0				
14																										0				
15	1.36	1.24	1.47	1.43	1.76	1.15																1.14				7				
16							1.32	1.57	1.44	1.37		1.57											1.28			6				
17													0.99	1.03	1.20	1.65	1.58	1.16						1.69		7				
18					1.39	1.30						1.55													1.48	6				
19													1.04	1.53	0.93	1.56	1.58	0.99	1.12	1.29					1.37	7				
20																										0				
21																										0				
22	1.29	0.88	1.43	1.36	1.31	1.15																				6				
23							1.32	1.59	1.66	1.59		1.33										1.20				6				
24													1.08	0.73	1.05	1.50	1.63	1.02						1.69		7				
25																										0				
26																										0				
27																										0				
28																										0				
29																										0				
30																										0				
31																										0				
Monthly Cl₂ Avg.				1.35		**Westside reservoir will not be sampled until repairs are finished																								
Total Samples				118																										



Distribution System Monitoring

WSSN 2310

May-17

DATE	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l																									Number of Samples				
	1	2	3	4	CS	6	7	8	9	10	WR**	12	13	14	15	16	17	18	19	20	21	22	23	24	25					
1	1.48	1.40	1.62	1.61	1.56	1.41															1.34					7				
2							1.56	1.82	1.28	1.77		1.34										1.45				6				
3													1.28	1.74	1.21	1.67	1.65	1.17					1.94			7				
4					1.49	1.43						1.65							1.07	1.52				1.48		6				
5													1.22	1.13	1.18	1.73	1.64	1.25							1.47	7				
6																										0				
7																										0				
8	1.46	1.33	1.66	1.64	1.80	1.24															1.34					7				
9							1.68	1.79	1.86	1.80		1.43											1.25			6				
10													1.18	1.29	1.44	1.69	1.73	1.31						1.89		7				
11							1.56	1.77	1.83	1.81									1.14	1.47				1.55		7				
12	1.50	1.61	1.60	1.58																1.47					1.48	6				
13																										0				
14																										0				
15	1.48	1.38	1.58	1.54	1.86	1.28															1.28					7				
16							1.45	1.78	1.70	1.56		1.71										1.45				6				
17													1.15	1.14	1.44	1.75	1.72	1.27						1.90		7				
18					1.51	1.47						1.66							1.23	1.42				1.58		6				
19													1.17	1.72	1.08	1.71	1.71	1.09							1.49	7				
20																										0				
21																										0				
22	1.45	1.04	1.54	1.56	1.48	1.30																				6				
23							1.61	1.80	1.80	1.75		1.51										1.30				6				
24													1.23	0.88	1.25	1.62	1.74	1.17						1.81		7				
25																										0				
26																										0				
27																										0				
28																										0				
29																										0				
30																										0				
31																										0				
Monthly Cl₂ Avg.					1.50	****Westside reservoir will not be sampled until repairs are finished																								
Total Samples					118																									



ROUTINE POSITIVE DISTRIBUTION SAMPLES

May-17

Total number of positive routine samples:				Total Coliform: <u>0</u>			E.coli Bacteria: <u>0</u>		Chlorine Residual (mg/L)	
Date	Monitoring Station	Total Coliform	E.coli Bacteria	Date	Time	Retest of Station, Upstream & Downstream	Total Coliform	E.coli Bacteria	Free	Total
Total number of routine distribution samples analyzed:				118						
Total number of routine distribution samples required:				100						