

**Summary of City of Flint (City) Actions
In Response to the
EPA Emergency Administrative Order
Updated: January 7, 2017**

Chapters 52, 57, 59a & 59b: Weekly Conference Call Regarding Flint Water Plant Operations January 7, 2017.

EPA Order Due Date: Weekly

MDEQ and the Flint Water Treatment Plant Supervisor held a teleconference meeting on January 7th to review and discuss the summary of water quality and corrosion control parameters reported on the City's December Operation Report and January Operation Report, completed to date, and a summary of water quality parameters collected the week of January 1st from the 10 sites monitored weekly. Data review (from the MOR) covers December 29, 2016 – January 6, 2017. Enhanced weekly distribution system data covers samples collected January 2 – 7, 2017. NOTE: *SITE NAME* is still being sampled while West Side Reservoir is unavailable.

The following observations were noted:

- The supplemental phosphate dosage was consistent and ranged between 2.43 and 2.61 milligrams per liter (mg/l). The phosphate residuals measured at the plant tap ranged from 3.6 to 3.8 mg/l entering the distribution system.
- All pH measurements were greater than 7.0 at all 10 of the Enhanced Water Quality Monitoring (EWQM) sites and the Point of Entry (Control Station #2) to the system. The pH levels ranged from 7.22 to 7.42 in the water received from Great Lakes Water Authority (GLWA) and from 7.17 to 7.39 at the 10 distribution system sites.
- The phosphate residual at the ten established, weekly distribution system sites ranged between 3.2 and 3.8 mg/l.
- Iron levels at EWQM sites ranged from 0.01 to 0.07 mg/l. Plant tap iron concentrations measured 0.01 mg/l in the last week.
- The supplemental chlorine feed at Control Station #2 ranged from 0.94 to 0.99 mg/l and the plant tap free chlorine residuals ranged from 1.6 to 1.9 mg/l.
- The free chlorine residuals at the City's 27 monitoring sites in the distribution system ranged from 0.51 to 1.67 mg/l. The low residual was at *SITE #19*, and the high residual was at *SITE #9*.