



## WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS									
Distribution System Location #	Sample Point Name & Address	Sample Week	Tech	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO <sub>3</sub> )	Calcium (mg/L Ca <sup>2+</sup> )	Hardness (mg/L CaCO <sub>3</sub> )	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl <sup>-</sup> )	Ortho phosphate (mg/L PO <sub>4</sub> )
#1	Davison Rd.	Feb. 14		13.5	0.17	7.16	72	35.3	100	0.246	0.03	11	3.32
#2	E Court St	Feb. 14		8.1	0.15	7.13	68	36.9	102	0.178	0.02	12	3.53
#3	S. Dort Hwy	Feb. 14		14.1	0.17	7.11	70	32.9	96	0.137	0.01	10	3.56
#4	Corunna Rd.	Feb. 14		8.1	0.15	7.14	70	32.1	100	0.169	0.05	12	3.49
#5	Flushing Rd.	Feb. 14		7.9	0.15	7.11	72	32.1	96	0.129	0.05	12	3.44
#6	MLK Blvd.	Feb. 14		10.7	0.19	7.28	74	32.9	100	0.162	0.07	12	3.20
#7	Clio Rd. 48504	Feb. 14		11.0	0.16	7.13	72	38.5	100	0.302	0.07	11	3.57
#8	N. Saginaw St.	Feb. 14		13.8	0.17	7.12	70	33.7	100	0.132	0.03	11	3.60
#9	N. Dort Hwy.	Feb. 14		4.3	0.22	7.34	72	31.3	102	0.067	0.01	11	1.14
CS	Cedar Street Reservoir & Pump Station	Feb. 14		8.1	0.15	7.16	72	32.1	104	0.127	0.06	12	3.73
WS	West Side Reservoir & Pump Station	Feb. 14		6.4	0.14	7.19	72	38.5	100	0.157	0.03	12	3.64