



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS									
Distribution System Location #	Sample Point Name & Address	Sample Week	Tech	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Ortho phosphate (mg/L PO ₄)
#1	3742 Davison Rd.	Feb. 28		15.9	0.20	7.50	82	36.1	104	0.087	0.01	11	3.99
#2	2838 E Court St	Feb. 28		10.3	0.17	7.28	74	34.5	100	0.085	0.02	11	3.52
#3	3302 S. Dart Hwy	Feb. 28		14.3	0.19	7.28	72	35.3	102	0.125	0.03	11	3.50
#4	3606 Corunna Rd.	Feb. 28		9.6	0.18	7.34	74	36.1	102	0.216	0.04	11	3.58
#5	2501 Flushing Rd.	Feb. 28		7.8	0.18	7.30	72	35.3	100	0.147	0.04	11	3.46
#6	3216 MLK Blvd.	Feb. 28		12.1	0.19	7.30	74	32.1	104	0.148	0.05	11	3.29
#7	5018 Clia Rd. 48504	Feb. 28		9.7	0.17	7.31	76	32.9	102	0.096	0.02	10	3.59
#8	6204 N. Saginaw St.	Feb. 28		14.0	0.19	7.25	74	36.1	102	0.081	0.00	11	3.53
#9	4500 N. Dart Hwy.	Feb. 28		3.9	0.22	7.22	72	33.7	102	0.073	0.01	10	1.32
CS		Feb. 28		7.8	0.19	7.31	74	32.9	100	0.142	0.03	13	3.42
WS		Feb. 28		5.8	0.18	7.28	75	32.9	100	0.124	0.04	13	3.63