



WEEKLY ENHANCED WATER QUALITY PARAMETER MONITORING

SAMPLE POINT IDENTIFICATION				PARAMETERS AND RESULTS										PRIOR WEEK RESULTS	
Distribution System Location #	Sample Point Name & Address	Sample Week	Tech	Temperature (°C)	Conductivity (mS)	pH (su)	Total Alkalinity (mg/L CaCO ₃)	Calcium (mg/L Ca ²⁺)	Hardness (mg/L CaCO ₃)	Turbidity (NTU)	Iron (mg/L)	Chloride (mg/L Cl ⁻)	Ortho phosphate (mg/L PO ₄)		Lead (µg/L Pb)
SOURCE	Control Station #2 4500 N. Dort Hwy.	Mar. 27	SB / CW	6.3	0.22	7.21	72	32.9	98	0.061	0.00	11	1.12		N/A
#1	Admiral Gas Station 3802 Davison Rd.	Mar. 27	SB / CW	8.9	0.20	7.23	72	34.5	100	0.083	0.03	10	3.47		ND
#2	Rite - Aid 2838 E Court St	Mar. 27	SB / CW	10.1	0.20	7.26	72	36.1	100	0.106	0.02	11	3.55		ND
#3	Liquor Palace 3302 S. Dort Hwy	Mar. 27	SB / CW	10.5	0.20	7.20	72	34.5	100	0.120	0.02	11	3.53		ND
#4	Taco Bell 3606 Corunna Rd.	Mar. 27	SB / CW	8.6	0.20	7.24	72	36.1	98	0.229	0.06	12	3.61		ND
#5	University Market 1069 Chevrolet Ave.	Mar. 27	SB / CW	14.5	0.20	7.29	74	38.5	100	0.154	0.04	10	3.42		ND
#6	Salem Housing 3216 MLK Blvd.	Mar. 27	SB / CW	13.4	0.20	7.37	72	32.9	98	0.122	0.03	10	3.34		1.00
#7	Rite-Aid 5018 Clio Rd. 48504	Mar. 27	SB / CW	12.2	0.20	7.27	72	35.3	100	0.152	0.03	11	3.54		ND
#8	N. Flint Automotive 6204 N. Saginaw St.	Mar. 27	SB / CW	15.3	0.20	7.26	72	32.9	100	0.084	0.01	10	3.57		ND
CS	Cedar Street Reservoir & Pump Station	Mar. 27	SB / CW	6.1	0.21	7.31	74	34.5	98	0.171	0.02	13	3.53		ND
WS	West Side Reservoir & Pump Station	Mar. 27	SB / CW	6.4	0.20	7.27	72	32.9	98	0.147	0.02	12	3.66		ND