

# POST-FILTER INSTALLATION SAMPLING RESULTS REPORT

Alleree Billings Daycare



October 12, 2016

## INTRODUCTION

During the month of April, 2016, the Department of Licensing and Regulatory Affairs (DLARA) completed replacement of drinking water fixtures at Alleree Billings Daycare. These fixture replacements were required because testing results indicated that the older fixtures at most schools were imparting lead to the drinking water. After the fixtures were replaced, a more thorough flushing of the plumbing lines was completed to remove any remaining material from the building's water supply system.

In March, 2016, Alleree Billings Daycare installed a whole house filtration system.

On Wednesday, August 10, 2016, the Department of Environmental Quality conducted a post-filter installation sampling assessment of the plumbing system at the facility.

### Water Main Description

An inspection from inside the building yielded a three quarter inch copper main with a brass curbstop. After the meter, the building had three quarter inch copper throughout.

## SAMPLING METHODS

### Fixture Sampling

There are three drinking water fixtures that were identified at the facility. After a minimum six-hour stagnation period, four samples were collected at each of the fixtures identified. Two initial samples were collected immediately after turning on the tap. The water was then flushed for 30 seconds and a third sample was collected. Finally, the water was flushed for another two minutes, and the fourth sample was collected. These samples were used to determine the impact of any lead sources in and around each specific fixture and its connecting plumbing.

### Deep Plumbing Sampling

A different sampling method is used to determine the impact of any lead sources located deep in the supply plumbing of the building. During this method, ten bottles are collected in a row (consecutively). These bottles are one liter in size, which is larger than those used for the fixture sampling method.

## Sampling Notes

- Twelve samples from three fixtures were collected and sent to the lab for analysis.
- Ten samples from one specific fixture were collected and sent to the lab for analysis for deeper plumbing assessment.
- Upon inspection, all aerators were found clean of debris.

## SAMPLING RESULTS

### Post-Filter Replacement

August 10, 2016  
Of the 22 samples:

- Lead Range: Non-Detected (ND) to 1 part per billion (ppb)
- Copper Range: ND to 120 ppb

\* Where the result is non-detected for lead it means that the amount of lead in the water was less than 1 ppb.

\* Where the result is non-detected for copper it means that the amount of copper in the water was less than 50 ppb.

Alleree Billings Daycare  
August 10, 2016

Lead	Result (ppb)	Sample Description	Site Code	Copper	Result (ppb)
Lead	ND	B01BF001 BASEMENT BATH	P1	Copper	110
Lead	ND	B01BF001 BASEMENT BATH	P2	Copper	120
Lead	ND	B01BF001 BASEMENT BATH	F01	Copper	ND
Lead	ND	B01BF001 BASEMENT BATH	F02	Copper	ND
Lead	1	01BF002 FIRST FLOOR BATH	P1	Copper	60
Lead	1	01BF002 FIRST FLOOR BATH	P2	Copper	50
Lead	ND	01BF002 FIRST FLOOR BATH	F01	Copper	ND
Lead	ND	01BF002 FIRST FLOOR BATH	F02	Copper	ND
Lead	ND	01KC003 KITCHEN	P1	Copper	ND
Lead	ND	01KC003 KITCHEN	P2	Copper	ND
Lead	ND	01KC003 KITCHEN	F01	Copper	ND
Lead	ND	01KC003 KITCHEN	F02	Copper	ND
Lead	ND	01KC003 KITCHEN	CA1	Copper	ND
Lead	ND	01KC003 KITCHEN	CA2	Copper	ND
Lead	ND	01KC003 KITCHEN	CA3	Copper	ND
Lead	ND	01KC003 KITCHEN	CA4	Copper	ND
Lead	ND	01KC003 KITCHEN	CA5	Copper	ND
Lead	ND	01KC003 KITCHEN	CA6	Copper	ND
Lead	ND	01KC003 KITCHEN	CA7	Copper	ND
Lead	ND	01KC003 KITCHEN	CA8	Copper	ND
Lead	ND	01KC003 KITCHEN	CA9	Copper	ND
Lead	ND	01KC003 KITCHEN	CA10	Copper	ND

Non-detected (ND) means; for lead the amount in water is less than 1 pbb,  
and for copper the amount in water is less than 50 pbb.