Department of Licensing and Regulatory Affairs, Bureau of Fire Services, Storage Tank Division
P.O. Box 30033, Lansing, Michigan 48909
Phone 517-335-7211, Fax 517-332-1428

LIQUEFIED PETROLEUM GAS INSPECTION CHECKLIST

INSTRUCTIONS: The Hazardous Materials Storage Inspector shall complete this checklist and attach it to an inspection report, one to be retained in the Region file and one for the Main Office file. All boxes shall be completed inserting N/A where non-applicable.	
FACILITY NAME:	FACILITY ID NUMBER:
CONTACT PERSON ON SITE:	FACILITY TYPE:

FACILITY SECTION

SECTION		CODE	VIO	PASS	SECTION		CODE	VIO	PASS
1.9.1	DEPARTMENT APPROVAL BEFORE INSTALLED	L126			6.8.7.2	FLEXIBLE CONNECTORS/HOSE MAX 36”	L62		
4.3.2	NOTIFY DEPARTMENT OF TEMP INSTALLS	L10			6.10.8.1	BULKHEADS OF STEEL OR CONCRETE	L66		
4.4.1	PERSONAL TRAINING	L128			6.10.1	ESV INSTALLED	L134		
4.4.2	PERSONAL TRAINING AT DISPENSER STATIONS	L130			6.11	HYDROSTATIC RELIEF FOR PIPING	L68		
5.2.6.1	CYLS ON DOCK OR IN TRANSIT ARE CAPPED	L132			6.15.5	PUMP & METER INSTALLATION	L70		
5.7.7	VALVES MUST COMPLY WITH TABLES	L22			6.16.5	TAMPERING PROTECTION	L80		
5.8.1.5	LIQUID & VAPOR LABELING FOR PIPING	L54			6.20.2.1	ELECTRICAL INSPECTOR APPROVAL	L90		
5.10.4	ESV W/REMOTE & THERMAL SHUTOFF	L30			6.22.3.5	HOSE PROTECTION-ESV, BACK CHECK, EXCESS FLOW	L38		
5.8.6.4	APPROVED HOSE (PROPERLY MARKED)	L32			6.22.4.2	SELF SERVE BREAKAWAY	L78		
6.15.4	STRAINER INSTALLED AND ABLE TO CLEAN	L36			6.23.4.2	FIRE EXTINGUISHER 18#	L96		
6.5.4	POINT OF TRANSFER BY TABLE 6.5.3	L104			5.2.6.1	VALVE PROTECTION @ DIST POINTS	L112		
6.4.5.2	COMBUSTIBLE MATERIALS WITHIN 10’	L46			6.3.1	EXCHANGE CYL LOCATION TO BLDS	L142		
6.8.3.5	THREADED PIPING MUST BE SCHEDULE 80	L58			10.2.2	CYL FILL BUILDING VENT SIZES	L120		
6.8.3.10	PIPING SUPPORTED & PROTECTED	L60				OTHER			

TANK SECTION

SECTION		CODE	VIO	PASS	SECTION		CODE	VIO	PASS
5.2.8.3	CONTAINER DESIGN/MARKING	L18			6.7.2.4	RAIN CAPS	L50		
5.7.2.1	PRESSURE RELIEF DEVICES FOR TANKS	L20			6.7.2.7	7’ RELIEF STACKS ON 2000 GAL TANKS	L52		
5.7.8.3	FIXED LIQUID LEVEL GAUGE 12/31/65	L24			5.7.7.4	PRESSURE GAUGE OVER 2000 GAL	L56		
5.7.8.9	VARIABLE LIQUID GAUGE	L26			6.14.1(d)	CATHODIC PROTECTION RECORDS	L136		
6.3.1	LOCATION OF CONTAINER	L44			6.14.1	CATHODIC PROTECTION UNDERGROUND	L136		
6.6.1.7	CONTAINER PROTECTION 4” SCH 40 W/CONCRETE 5’ ON CTR	L122			7.2.2.5.1(a)	3” NO SMOKING – NO OPEN FLAMES	L138		
6.6.3.1	CONTAINER SUPPORTS & PROTECTION	L48			7.2.2.5.1(b)	WARNING LABEL FOR NON-FILL CYLS	L140		
6.6.1.4	LPG containers shall be kept properly painted.	L144			7.2.3.2 (F)(G)	TANK SIGNAGE BOTH SIDES, "Flammable Gas" and "No Smoking Within 25 Feet"	L139		
5.7.7.4	VENT INSPECTED, 4,000 GALLON OR CONTAINER FILL – EVERY 10 YEARS	L55			1941 PA 207	Miscellaneous violation	L51		

COMMENTS:_____

_____

_____

INSPECTOR: _____ DATE _____