

**MICHIGAN STATE PLUMBING BOARD
BUREAU OF CONSTRUCTION CODES**
2501 Woodlake Circle
Okemos, Michigan 48864

Appeal Docket No.
CCC-PLBG-11-009

Petitioner, Mr. Zachary S. Voogt, Moore & Bruggink, Inc., 2020 Monroe Ave. N.W., Grand Rapids, Michigan 49505 for Orchard View Schools, 35 S. Sheridan, Muskegon.

vs

Respondent, Department of Licensing and Regulatory Affairs, Bureau of Construction Codes

MEMORANDUM OF TRANSMITTAL

The attached FINAL AGENCY ORDER of the MICHIGAN STATE PLUMBING BOARD is issued pursuant to 1969 PA 306, the Administrative Procedures Act, MCL 24.281, et seq.


DECISION AND ORDER

The Michigan State Plumbing Board adopted the Findings of Fact, Conclusion and Recommendation of Staff in the matter Mr. Zachary S. Voogt, Moore & Bruggink, Inc., 2020 Monroe Ave. N.W., Grand Rapids, Michigan 49505 for Orchard View Schools, 35 S. Sheridan, Muskegon; APPEAL Docket No. CCC-PLBG-11-009, at their meeting on September 20, 2011. The appeal request was to utilize manholes at greater distances than code required cleanouts for sewer installations at Orchard Schools.


FINDINGS AND CONCLUSIONS

Following a review and discussion, a **MOTION** was made by Board Member Howard and supported by Board Member Jones to approve the appeal request for Orchard View Schools with the following condition: A camera must be used to create video documentation for review to confirm that backfall conditions are not present. **MOTION CARRIED.**

THEREFORE, the Board grants the appeal request with conditions.



Robert G. Konyndyk, Chief
Plumbing Division



Date