

**MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
BARRIER FREE DESIGN BOARD
2501 Woodlake Circle
Okemos, MI 48864**

Project No. 103322
Exception No. 12-001034-BCC
Use Group: I2

23332 Red Arrow Highway
Mattawan, Michigan
Van Buren County

ORDER OF THE MICHIGAN BARRIER FREE DESIGN BOARD

On September 14, 2012 the Barrier Free Design Board reviewed the Report of the Administrative Law Judge dated July 18, 2012. All supplemental materials received before the Board meeting were reviewed. Copies were sent to all parties. This order is issued pursuant to Section 5(6)(a) of 1966 P.A. 1, as amended; 1972 P.A. 230, as amended; and Section 81 of 1969 of P.A. 306, as amended, and Rule R 125.1016.

FINDINGS AND CONCLUSIONS: The Board adopted the report of the Administrative Law Judge. The Board concurs with the Conclusions of Law and Recommendation.

THEREFORE, it is the order of the Board to grant relief from the following sections in the rehab spa room no. 333 and long term spa room no. 643:

2003 ICC/ANSI A 117.1, Section 604.2 for the water closet location.

2003 ICC/ANSI A 117.1, Section 604.5 for rear and side wall grab bars provided the applicant will install the swing up grab bars.

The Board can only grant or deny exceptions to Michigan's barrier free design requirements. The Board has no authority over the federal standards contained in the Americans with Disabilities Act of 1990, 42 U.S.C. 12204.



Todd Y. Cordill, NCARB
Chief, Plan Review Division for the
Barrier Free Design Board

September 24, 2012

**THE ORDER SHALL BE DISPLAYED IN A CONSPICUOUS LOCATION FOR
PUBLIC EXAMINATION AS A CONDITION OF THE EXCEPTION.**