

MICHIGAN DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
BARRIER FREE DESIGN BOARD  
2501 Woodlake Circle  
Okemos, MI 48864

Project No. 105933  
Exception No. 13-009173-BCC  
Use Group: F1

703 Leonard Street NW  
Grand Rapids, Michigan 49501  
Kent County

**ORDER OF THE MICHIGAN BARRIER FREE DESIGN BOARD**

On January 17, 2014 the Barrier Free Design Board reviewed the Report of the Administrative Law Judge dated October 2, 2013. All supplemental materials received before the Board meeting were reviewed. Copies were sent to all parties. This order is issued pursuant to Section 5(6)(a) of 1966 P.A. 1, as amended; 1972 P.A. 230, as amended; and Section 81 of 1969 of P.A. 306, as amended, and Rule R 125.1016.

**FINDINGS AND CONCLUSIONS:** The Board adopted the report of the Administrative Law Judge. The Board concurs with the Conclusions of Law and Recommendation.

THEREFORE, it is the order of the Board to grant relief from the 2003 ICC/ANSI A 117.1, Section 404.2.3.1 for the latch side maneuvering clearance for the toilet doors of the relocated toilets, provided the applicant will install automatic door openers for these doors.

The Board can only grant or deny exceptions to Michigan's barrier free design requirements. The Board has no authority over the federal standards contained in the Americans with Disabilities Act of 1990, 42 U.S.C. 12204.

  
\_\_\_\_\_  
Todd Y. Cordill, NCARB  
Chief, Plan Review Division for the  
Barrier Free Design Board

January 30, 2014

**THE ORDER SHALL BE DISPLAYED IN A CONSPICUOUS LOCATION FOR  
PUBLIC EXAMINATION AS A CONDITION OF THE EXCEPTION.**