

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: General Housing- West Plant 4650 E Wilder Bay City, MI 48706	COMPLIANCE ASSURANCE PROGRAM NO.:
	276
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108556
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 30' x 84' Office 102914			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 10 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 23.1 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 30 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9368

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing – 2012 MPC
----------------------------	------------------------------	------------------------------	----------------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 27, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 29, 2015

cc: State of Michigan

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: CMH Mfg West Inc - Crest #981 437 N Main Street PO Box 1218 Middlebury, IN 46540	COMPLIANCE ASSURANCE PROGRAM NO.: 138
	BUILDING SYSTEM APPROVAL REPORT NO.: 108597
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 6028-522 60'-0" x 27'-0" Ranch with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8/ 77 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75/ 100 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8499

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 27, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 29, 2015

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: General Housing- West Plant 4650 E Wilder Bay City, MI 48706	COMPLIANCE ASSURANCE PROGRAM NO.:
	276
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108577
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Rehabilitation Home 52407			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 6 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: On Site By Others PSF		FLOOR LIVE LOAD: 90 PSF	GROUND SNOW LOAD: 60 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9368

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:




 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 20, 2015

AGENCY OFFICIAL:



 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

January 23, 2015

cc: State of Michigan

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Adventure Homes 1119 Fuller Drive Garrett, IN 46738	COMPLIANCE ASSURANCE PROGRAM NO.: 555
	BUILDING SYSTEM APPROVAL REPORT NO.: 108690
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Ranch-MOD2856-1-4862 with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 30.8 PSF	FLOOR LIVE LOAD: 30 PSF		GROUND SNOW LOAD: 40 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6791

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':
HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
January 20, 2015

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
January 22, 2015

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive P. O. Box 577 Goshen, IN 46528	COMPLIANCE ASSURANCE PROGRAM NO.: <div style="text-align: center;">395</div>
	BUILDING SYSTEM APPROVAL REPORT NO.: <div style="text-align: center;">108748</div>
	TYPE OF APPROVAL: <div style="text-align: center;">New System</div>

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RX 844-A9 30'-0" x 40'-0" Ranch with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:		GROUND SNOW LOAD:
30.8 PSF	40 PSF		40 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6499

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 16, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 20, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Rochester Homes Inc 1345 N Lucas Street PO Box 587 Rochester, IN 46975	COMPLIANCE ASSURANCE PROGRAM NO.:
	128
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108734
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: SAR - 24 Ranch 26'2"x37'4"/42'0" with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
38.5/ 53.9 PSF		40 PSF	50/ 70 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	7573

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured: HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.			

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 15, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

January 20, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Par-Kut International Inc 40961 Production Drive Harrison Township, MI 48045	COMPLIANCE ASSURANCE PROGRAM NO.: <div style="text-align: center;">317</div>
	BUILDING SYSTEM APPROVAL REPORT NO.: <div style="text-align: center;">108728</div>
	TYPE OF APPROVAL: <div style="text-align: center;">New System</div>

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model 14-321-MI 4' x 6' Guard House			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 1 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 17.5 PSF	FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 25 PSF	
WIND SPEED: 115 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6232

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 14, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 16, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Par-Kut International Inc 40961 Production Drive Harrison Township, MI 48045	COMPLIANCE ASSURANCE PROGRAM NO.: 317
	BUILDING SYSTEM APPROVAL REPORT NO.: 108733
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model 14-352-MI 6' x 10' Steel Guard House			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 1 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 14 PSF	FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 20 PSF	
WIND SPEED: 115 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6232

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 14, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 16, 2015

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI, Inc. 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.: 416
	BUILDING SYSTEM APPROVAL REPORT NO.: 108603
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: VSR 8797 56'-0" x 44'-5" Ranch with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6939


APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 13, 2015

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

January 15, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: AAH of Indiana, LLC 1418 S 13th Street Decatur, IN 46733	COMPLIANCE ASSURANCE PROGRAM NO.:
	136
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108689
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: M 3862 B #01988 with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 20.8 PSF	FLOOR LIVE LOAD: 40 PSF		GROUND SNOW LOAD: 30 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 17 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6940

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 12, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 14, 2015

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI, Inc. 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.:
	416
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108641
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: VSC 8798 44'-0" x 27'-4" Cape Cod with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 29.6/ 44.4 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6783

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------


LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured":
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 12, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 14, 2015

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI, Inc. 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.: 416
	BUILDING SYSTEM APPROVAL REPORT NO.: 108703
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: VSR 8799 56'0" x 33'11" Ranch with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF		FLOOR LIVE LOAD: 40 PSF	
		GROUND SNOW LOAD: 50/ 75 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6515

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:




 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 12, 2015

AGENCY OFFICIAL:



 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

January 15, 2015

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Medical Coaches Inc 399 County Highway 58 PO Box 129 Oneonta, NY 13820	COMPLIANCE ASSURANCE PROGRAM NO.: 315
	BUILDING SYSTEM APPROVAL REPORT NO.: 108699
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Mobile CT Trailer Siemens Biograph MCT			
USE GROUP: B	CONSTRUCTION TYPE: IIB	OCCUPANT LOAD: 4 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: NA PSF		FLOOR LIVE LOAD: NA PSF	GROUND SNOW LOAD: NA PSF
WIND SPEED: NA MPH	ROOF DEAD LOAD: NA PSF	FLOOR DEAD LOAD: NA PSF	HEATING DEGREE DAYS: NA

APPLICABLE STATE CODES

Building –	Electrical – 2011 NEC	Mechanical –	Plumbing –
-------------------	------------------------------	---------------------	-------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
January 8, 2015

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
January 14, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked.	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
----------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Stratford Hms Ltd Partnership 402 S Weber Avenue PO Box 37 Stratford, WI 54484	COMPLIANCE ASSURANCE PROGRAM NO.:
	209
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108559
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 28'x50' "C" Ranch with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 59.2 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 14 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8593

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION


REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 7, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

January 9, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: AAH of Indiana, LLC 1418 S 13th Street Decatur, IN 46733	COMPLIANCE ASSURANCE PROGRAM NO.:
	136
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108558
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: ALMV 4064 B #01579 with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 32 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 60 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 20 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6230

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 7, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 January 12, 2015

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Par-Kut International Inc 40961 Production Drive Harrison Township, MI 48045	COMPLIANCE ASSURANCE PROGRAM NO.: 317
	BUILDING SYSTEM APPROVAL REPORT NO.: 108589
	TYPE OF APPROVAL: New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 14-280-MI 9'x8' Prefabricated Steel Guard House			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 2 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 35 PSF		FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 25 PSF
WIND SPEED: 115 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6232

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing –
----------------------------	------------------------------	------------------------------	-------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
January 7, 2015

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
January 12, 2015

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Safety Storage, Inc. 855 N. 5th Street Charleston, IL 61920	COMPLIANCE ASSURANCE PROGRAM NO.:
	340
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108637
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Safety Storage Model 0808FSE 8'x8'x9'			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
H2	IIB	2 Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
40 PSF	500 PSF	20 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
110 MPH	16 PSF	16 PSF	7729

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing –
----------------------------	------------------------------	------------------------------	-------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 30, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 February 3, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.:
	164
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108796
	TYPE OF APPROVAL:
	Modification

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF2460 118-13 Modular Office (24'-0"x60'-0") (105215) Modified			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
B	VB	13 Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
46.2 PSF		50 PSF	60 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6167

APPLICABLE STATE CODES

Building – 2012 MBC	Electrical – 2011 NEC	Mechanical – 2012 MMC	Plumbing –
----------------------------	------------------------------	------------------------------	-------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION


REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

January 30, 2015

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

February 3, 2015

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Unibilt Industries Inc 8005 Johnson Station Road PO Box 373 Vandalia, OH 45377	COMPLIANCE ASSURANCE PROGRAM NO.:
	305
	BUILDING SYSTEM APPROVAL REPORT NO.:
	108764
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Custom Ranch CR31 27'-4" x 50'-0" with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 23.1 PSF	FLOOR LIVE LOAD: 40 PSF		GROUND SNOW LOAD: 30 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 7 PSF	HEATING DEGREE DAYS: 6737

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------


LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks are subject to the approval of the local enforcing agency, and are not part of this approval.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 January 30, 2015

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 February 3, 2015