

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Rochester Homes Inc 1345 N Lucas Street PO Box 587 Rochester, IN 46975	COMPLIANCE ASSURANCE PROGRAM NO.: 128
	BUILDING SYSTEM APPROVAL REPORT NO.: 102671
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: STS-16 Two Story 27'-10" x 47'-0" with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7573


APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION


REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 3, 2012

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 5, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	COMPLIANCE ASSURANCE PROGRAM NO.: 167
	BUILDING SYSTEM APPROVAL REPORT NO.: 102713
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 6402-MI-01 Ranch 27'-4"x 64'-0" with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8356

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:			

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 5, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 9, 2012

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Stratford Hms Ltd Partnership 402 S Weber Avenue PO Box 37 Stratford, WI 54484	COMPLIANCE ASSURANCE PROGRAM NO.: 209
	BUILDING SYSTEM APPROVAL REPORT NO.: 102782
	TYPE OF APPROVAL: New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 28'x50' "C" River Valley Ranch with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 59.7 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 14 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9567

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 17, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 19, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.: 391
	BUILDING SYSTEM APPROVAL REPORT NO.: 102861
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 48x60 Stock Office (4) 11'-9"x56'-0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 26 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
----------------------------	------------------------------	------------------------------	----------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 19, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 23, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.:
	391
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102863
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 84x60 Stock Office (7) 11'-9"x56'0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 46 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330

APPLICABLE STATE CODES


Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 19, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 23, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.: 391
	BUILDING SYSTEM APPROVAL REPORT NO.: 102862
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 24x60 Stock Office (2) 11'-9"x56'-0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 13 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
----------------------------	------------------------------	------------------------------	----------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 19, 2012

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 23, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.: 416
	BUILDING SYSTEM APPROVAL REPORT NO.: 102771
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: CCR 8657 27'-4"x64'-0" & 27'-4"x13'-8" with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7479

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 19, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 23, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive PO Box 729 Goshen, IN 46526	COMPLIANCE ASSURANCE PROGRAM NO.: 395
	BUILDING SYSTEM APPROVAL REPORT NO.: 102821
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RG 733-A1 26'-8" x 56'-0" Ranch with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 30.8 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 40 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 8 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6999

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------


LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured":

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 18, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 20, 2012

cc: RADCO

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commercial Structures Corporation 655 N Tomahawk Trail PO Box 225 Nappanee, IN 46550	COMPLIANCE ASSURANCE PROGRAM NO.:
	204
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102763
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: SS810 7'-9"x10'-0"			
USE GROUP: U	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 0 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 40 PSF	FLOOR LIVE LOAD: NA PSF	GROUND SNOW LOAD: 50 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: NA PSF	HEATING DEGREE DAYS: 5400-7200

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
----------------------------	------------------------------	------------------------------	-------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 19, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 23, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Systems Control Div of Northern Star Industries 3201 E Industrial Drive Iron Mountain, MI	COMPLIANCE ASSURANCE PROGRAM NO.: 532
	BUILDING SYSTEM APPROVAL REPORT NO.: 102667
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Mackinac Substation- Channel Frame Metal Enclosure 24'x60'x10'-8"			
USE GROUP: S2	CONSTRUCTION TYPE: IIB	OCCUPANT LOAD: 3 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 40 PSF	FLOOR LIVE LOAD: 250 PSF	GROUND SNOW LOAD: 60 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 40 PSF	FLOOR DEAD LOAD: 15 PSF	HEATING DEGREE DAYS: 9000-12600


APPLICABLE STATE CODES

Building – 2009 MBC	Electrical –	Mechanical –	Plumbing –
---------------------	--------------	--------------	------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 18, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 20, 2012

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River Housing, Inc. 66700 State Road 19 PO Box 406 Wakarusa, IN 46573	COMPLIANCE ASSURANCE PROGRAM NO.: 461
	BUILDING SYSTEM APPROVAL REPORT NO.: 102736
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model M710 with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6973

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 17, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 20, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: CMH Mfg West Inc - Crest #981 437 N Main Street PO Box 1218 Middlebury, IN 46540	COMPLIANCE ASSURANCE PROGRAM NO.: 138
	BUILDING SYSTEM APPROVAL REPORT NO.: 102857
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 5228-9007 52'-0" x 27'-0" Ranch with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8499

APPLICABLE STATE CODES

Building -- 2009 MRC/B	Electrical -- 2009 MRC/E	Mechanical -- 2009 MRC/M	Plumbing -- 2009 MRC/P
------------------------	--------------------------	--------------------------	------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 19, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 23, 2012

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River Housing, Inc. 66700 State Road 19 PO Box 406 Wakarusa, IN 46573	COMPLIANCE ASSURANCE PROGRAM NO.: 461
	BUILDING SYSTEM APPROVAL REPORT NO.: 102847
	TYPE OF APPROVAL: New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: Model: M120B-21 with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: Na Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7684

APPLICABLE STATE CODES


Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured'.
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 18, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 20, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Unibilt Industries Inc 8005 Johnson Station Road PO Box 373 Vandalia, OH 45377	COMPLIANCE ASSURANCE PROGRAM NO.:
	305
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102877
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Custom Jackson RDH9a 27'4" x 52'			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 23.1 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 30 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 7 PSF	HEATING DEGREE DAYS: 6979

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 20, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 24, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	COMPLIANCE ASSURANCE PROGRAM NO.: 167
	BUILDING SYSTEM APPROVAL REPORT NO.: 102856
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 5615/5616 27'-4" x 56'-0" Ranch with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8356

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 20, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 24, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.: 391
	BUILDING SYSTEM APPROVAL REPORT NO.: 102865
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 108x60 Stock Office (9) 11'-9"x56'-0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 59 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
----------------------------	------------------------------	------------------------------	----------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 30, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 May 3, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive PO Box 729 Goshen, IN 46526	COMPLIANCE ASSURANCE PROGRAM NO.:
	395
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102715
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RG 715-AB17 26'-8" x 60'-0" Ranch with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
30.8 PSF		40 PSF	40 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	8 PSF	10 PSF	7639

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive PO Box 729 Goshen, IN 46526	COMPLIANCE ASSURANCE PROGRAM NO.:
	395
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102748
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RG7 16A-13 Ranch 26'-8"x64'-0" with Crawlspace			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
30.8 PSF		40 PSF	40 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	8 PSF	10 PSF	8499

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	--------------------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Whitley Manufacturing Co Inc 201 W First Street PO Box 496 South Whitley, IN 46787	COMPLIANCE ASSURANCE PROGRAM NO.:
	241
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102620
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Model #6905 2 Classroom Module with 2 Restrooms			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
E	VB	60 Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
40 PSF		50 PSF	50 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6580

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:			

CERTIFICATION

REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 24, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.: 164
	BUILDING SYSTEM APPROVAL REPORT NO.: 102831
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 848-063-12 Press Box 8'-0" x 48'-0"			
USE GROUP: AS	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 25 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 100 PSF	GROUND SNOW LOAD: 25 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6737

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical –	Plumbing –
---------------------	-----------------------	--------------	------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Hi-Tech Housing Inc 1103 S Maple Street Bristol, IN 46507	COMPLIANCE ASSURANCE PROGRAM NO.:
	201
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102753
	TYPE OF APPROVAL:
	New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 2640-Y05 Custom Ranch with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 30.8/ 53.9 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 40/ 70 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7436

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical –	Plumbing – 2009 MRC/P
------------------------------	--------------------------------	---------------------	------------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.:
	164
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102741
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1264T 12'-0"x64'-0" Mobile Office			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
B	VB	7 Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	GROUND SNOW LOAD:
50 PSF		50 PSF	50 PSF
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	10 PSF	10 PSF	6167

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
----------------------------	------------------------------	------------------------------	----------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.:
	164
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102742
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1252T 12'-0"x52'-0" Mobile Office			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
B	VB	6 Persons	Modular
ROOF LIVE/SNOW LOAD:		FLOOR LIVE LOAD:	
50 PSF		50 PSF	
WIND SPEED:		GROUND SNOW LOAD:	
90 MPH		50 PSF	
ROOF DEAD LOAD:		FLOOR DEAD LOAD:	
10 PSF		10 PSF	
		HEATING DEGREE DAYS:	
		6167	

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
----------------------------	------------------------------	------------------------------	----------------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 24, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.: 391
	BUILDING SYSTEM APPROVAL REPORT NO.: 102866
	TYPE OF APPROVAL: New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: 72x60 Stock Office (6) 11'-9"x56'0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 40 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF		FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330

APPLICABLE STATE CODES


Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 20, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 24, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Forest River, Inc. 2801 Oakland Avenue Elkhart, IN 46517	COMPLIANCE ASSURANCE PROGRAM NO.: 391
	BUILDING SYSTEM APPROVAL REPORT NO.: 102867
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 36x60 Stock Office (3) 11'-9"x56'-0"			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 20 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 42 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 54 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 7 PSF	FLOOR DEAD LOAD: 20 PSF	HEATING DEGREE DAYS: 7330


APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION


REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 20, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 24, 2012

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Commodore Corporation, The 1902 Century Drive PO Box 729 Goshen, IN 46526	COMPLIANCE ASSURANCE PROGRAM NO.:
	395
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102668
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: RG 705-A11 26'-8" x 44'-0" Ranch with Crawlspace			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 30.8 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 40 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 8 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7038

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 24, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 26, 2012

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.:
	164
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102918
	TYPE OF APPROVAL:
	Modification

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF830-043-12 8'-0"x30'-0" Pressbox (102567) Modified
--


USE GROUP: A5	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 16 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 100 PSF	GROUND SNOW LOAD: 20 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6737

APPLICABLE STATE CODES

Building –	Electrical – 2008 NEC	Mechanical –	Plumbing –
-------------------	------------------------------	---------------------	-------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

ISSUED DATE:
April 23, 2012

PUBLISHED DATE:
April 25, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.: 164
	BUILDING SYSTEM APPROVAL REPORT NO.: 102746
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1036 10'-0"x36'-0" Mobile Office			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 3 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF		FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 50 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6167

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION


REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 6, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 11, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.: 164
	BUILDING SYSTEM APPROVAL REPORT NO.: 102745
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1044 10'-0"x44'-0" Mobile Office			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 4 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 50 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6167

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':


CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 6, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 11, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.: 164
	BUILDING SYSTEM APPROVAL REPORT NO.: 102744
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1252 12'-0"x52'-0" Mobile Office			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 6 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF		FLOOR LIVE LOAD: 50 PSF	
WIND SPEED: 90 MPH		GROUND SNOW LOAD: 50 PSF	
ROOF DEAD LOAD: 10 PSF		FLOOR DEAD LOAD: 10 PSF	
		HEATING DEGREE DAYS: 6167	

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------


LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 6, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 11, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mobile Facility Engineering Inc 306 W State Street PO Box 387 Cassopolis, MI 49031	COMPLIANCE ASSURANCE PROGRAM NO.: 164
	BUILDING SYSTEM APPROVAL REPORT NO.: 102743
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: MF 1264 12'-0"x64'-0" Mobile Office			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 7 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 50 PSF	GROUND SNOW LOAD: 50 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 6167

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing --
---------------------	-----------------------	-----------------------	-------------


LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 6, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
April 11, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ventaire LLC - Sagebrush Bldg Sys LLC 909 N Wheeling Avenue Tulsa, OK 74110	COMPLIANCE ASSURANCE PROGRAM NO.:
	491
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102661
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: Service Station Kiosk Building With No Restroom			
USE GROUP: B	CONSTRUCTION TYPE: IIB	OCCUPANT LOAD: 2 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 50 PSF	FLOOR LIVE LOAD: 100 PSF	GROUND SNOW LOAD: 70 PSF	
WIND SPEED: 130 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 35 PSF	HEATING DEGREE DAYS: 6167/ 7749

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing –
---------------------	-----------------------	-----------------------	------------


LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:

 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 9, 2012

AGENCY OFFICIAL:

 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 April 11, 2012

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
 Michigan Department of Licensing and Regulatory Affairs
 Bureau of Construction Codes
 Plan Review Division
 P.O. Box 30254
 Lansing, MI 48909
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Hi-Tech Housing Inc 1103 S Maple Street Bristol, IN 46507	COMPLIANCE ASSURANCE PROGRAM NO.:
	201
	BUILDING SYSTEM APPROVAL REPORT NO.:
	102665
	TYPE OF APPROVAL:
	New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 5628-C140-M Custom Cape with Basement, Crawlspace and Various Options			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 30.8/ 53.9 PSF		FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 40/ 70 PSF
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 7684


APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical –	Plumbing – 2009 MRC/P
-----------------------	-------------------------	--------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

CERTIFICATION

REVIEWED BY:




 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 3, 2012

AGENCY OFFICIAL:



 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

April 5, 2012

cc: TR Arnold & Associates Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Dickinson Homes Inc 1500 W Breitung Avenue PO Box 2245 Kingsford, MI 49802	COMPLIANCE ASSURANCE PROGRAM NO.: 123
	BUILDING SYSTEM APPROVAL REPORT NO.: 102735
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 60x12x17 OCS			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 123 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 53.9 PSF	FLOOR LIVE LOAD: 50/ 110 PSF	GROUND SNOW LOAD: 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 15 PSF	FLOOR DEAD LOAD: 12 PSF	HEATING DEGREE DAYS: 7200-9000


APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION


REVIEWED BY:


Sheila Hartfield, Plan Reviewer

ISSUED DATE:

April 27, 2012

AGENCY OFFICIAL:


Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

May 1, 2012

cc: PFS Corporation

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Ritz-Craft Corporation of MI Inc 118 Deal Parkway Jonesville, MI 49250	COMPLIANCE ASSURANCE PROGRAM NO.: 416
	BUILDING SYSTEM APPROVAL REPORT NO.: 102891
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: HR 8666 27'4" x 52'-0" with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 57.8 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 75 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 8350

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
LIMITATIONS OF APPROVAL (IF ANY) *The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured: HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.			

CERTIFICATION

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

ISSUED DATE:
April 27, 2012

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
May 1, 2012

cc: NTA Inc

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Mark Line Industries 51687 CR 133 PO Box 277 Bristol, IN 46507	COMPLIANCE ASSURANCE PROGRAM NO.: 160
	BUILDING SYSTEM APPROVAL REPORT NO.: 102919
	TYPE OF APPROVAL: New System

DESIGN DATA


DESCRIPTION OF MANUFACTURED MODEL: Model 2868			
USE GROUP: B	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: 18 Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 40 PSF	FLOOR LIVE LOAD: 50/ 100 PSF	GROUND SNOW LOAD: 50 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 7 PSF	HEATING DEGREE DAYS: 7026

APPLICABLE STATE CODES

Building – 2009 MBC	Electrical – 2008 NEC	Mechanical – 2009 MMC	Plumbing – 2009 MPC
---------------------	-----------------------	-----------------------	---------------------


LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:
 April 27, 2012

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:
 May 1, 2012

cc: TR Arnold & Associates Inc