

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	COMPLIANCE ASSURANCE PROGRAM NO.: 167
	BUILDING SYSTEM APPROVAL REPORT NO.: 100040
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: DT 8503 / DT 8504 Ranch 26'0"x52'0" with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options
--

USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 38.5/ 53.9 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 50/ 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 10 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 9316

APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

CERTIFICATION


REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

October 27, 2011

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

November 1, 2011

BUILDING SYSTEM APPROVAL REPORT
Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes
Plan Review Division
P.O. Box 30254
Lansing, MI 48909
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

MANUFACTURER DATA

MANUFACTURER: Stratford Hms Ltd Partnership 402 S Weber Avenue PO Box 37 Stratford, WI 54484	COMPLIANCE ASSURANCE PROGRAM NO.: 209
	BUILDING SYSTEM APPROVAL REPORT NO.: 99813
	TYPE OF APPROVAL: New System

DESIGN DATA

DESCRIPTION OF MANUFACTURED MODEL: 30'x42' x 60' Colorado "C" with Basement			
USE GROUP: R3	CONSTRUCTION TYPE: VB	OCCUPANT LOAD: NA Persons	TYPE OF UNIT: Modular
ROOF LIVE/SNOW LOAD: 59.2 PSF	FLOOR LIVE LOAD: 40 PSF	GROUND SNOW LOAD: 70 PSF	
WIND SPEED: 90 MPH	ROOF DEAD LOAD: 14 PSF	FLOOR DEAD LOAD: 10 PSF	HEATING DEGREE DAYS: 10003


APPLICABLE STATE CODES

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

LIMITATIONS OF APPROVAL (IF ANY) 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

CERTIFICATION

REVIEWED BY:


 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

October 13, 2011

AGENCY OFFICIAL:


 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

October 17, 2011

cc: NTA Inc