

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Licensing and Regulatory Affairs  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

<b>MANUFACTURER DATA</b>							
<b>MANUFACTURER:</b>  Fairmont Homes Inc 502 S Oakland - Plant 2 PO Box 27 Nappanee, IN 46550	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 2px;">COMPLIANCE ASSURANCE PROGRAM NO.:</td> <td style="text-align: center; padding: 2px;">451</td> </tr> <tr> <td style="padding: 2px;">BUILDING SYSTEM APPROVAL REPORT NO.:</td> <td style="text-align: center; padding: 2px;">99248</td> </tr> <tr> <td style="padding: 2px;">TYPE OF APPROVAL:</td> <td style="text-align: center; padding: 2px;">Modification</td> </tr> </table>	COMPLIANCE ASSURANCE PROGRAM NO.:	451	BUILDING SYSTEM APPROVAL REPORT NO.:	99248	TYPE OF APPROVAL:	Modification
COMPLIANCE ASSURANCE PROGRAM NO.:	451						
BUILDING SYSTEM APPROVAL REPORT NO.:	99248						
TYPE OF APPROVAL:	Modification						

<b>DESIGN DATA</b>			
<b>DESCRIPTION OF MANUFACTURED MODEL:</b> 92028 30'8"x56'-0" with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options (48848) Modified			
USE GROUP:	CONSTRUCTION TYPE:	OCCUPANT LOAD:	TYPE OF UNIT:
R3	VB	NA Persons	Modular
ROOF LIVE/SNOW LOAD:	FLOOR LIVE LOAD:	GROUND SNOW LOAD:	
38.5/ 53.9 PSF	40 PSF	50/70 PSF	
WIND SPEED:	ROOF DEAD LOAD:	FLOOR DEAD LOAD:	HEATING DEGREE DAYS:
90 MPH	14 PSF	10 PSF	9316

<b>APPLICABLE STATE CODES</b>			
Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P

<b>LIMITATIONS OF APPROVAL (IF ANY)</b> The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:
---

**CERTIFICATION**

REVIEWED BY:  
  
 \_\_\_\_\_  
 Sheila Hartfield, Plan Reviewer

ISSUED DATE:  
 November 17, 2011

AGENCY OFFICIAL:  
  
 \_\_\_\_\_  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:  
 November 21, 2011

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Licensing and Regulatory Affairs  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Forest River Housing, Inc. 66700 State Road 19 PO Box 406 Wakarusa, IN 46573	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b>
	461
	<b>BUILDING SYSTEM APPROVAL REPORT NO.:</b>
	100017
	<b>TYPE OF APPROVAL:</b>
	New System

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> System Manual			
<b>USE GROUP:</b> R3	<b>CONSTRUCTION TYPE:</b> VB	<b>OCCUPANT LOAD:</b> NA Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> Model Specific PSF	<b>FLOOR LIVE LOAD:</b> 40 PSF		<b>GROUND SNOW LOAD:</b> Model Specific PSF
<b>WIND SPEED:</b> Model Specific MPH	<b>ROOF DEAD LOAD:</b> 10 PSF	<b>FLOOR DEAD LOAD:</b> 10 PSF	<b>HEATING DEGREE DAYS:</b> Model Specific

**APPLICABLE STATE CODES**

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

**LIMITATIONS OF APPROVAL (IF ANY)** 'The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured':

**CERTIFICATION**

REVIEWED BY:

  
 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

November 16, 2011

AGENCY OFFICIAL:

  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

November 21, 2011

cc: NTA Inc

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Licensing and Regulatory Affairs  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	LARA is an equal opportunity employer/program. Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Fairmont Homes Inc 502 S Oakland - Plant 2 PO Box 27 Nappanee, IN 46550	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b>  451
	<b>BUILDING SYSTEM APPROVAL REPORT NO.:</b>  99247
	<b>TYPE OF APPROVAL:</b>  Modification

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> 92700 30'-8"x38'-0" with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options (90758) Modified			
<b>USE GROUP:</b>  R3	<b>CONSTRUCTION TYPE:</b>  VB	<b>OCCUPANT LOAD:</b>  NA Persons	<b>TYPE OF UNIT:</b>  Modular
<b>ROOF LIVE/SNOW LOAD:</b>  38.5/ 53.9 PSF	<b>FLOOR LIVE LOAD:</b>  40 PSF	<b>GROUND SNOW LOAD:</b>  50/ 70 PSF	
<b>WIND SPEED:</b>  90 MPH	<b>ROOF DEAD LOAD:</b>  17 PSF	<b>FLOOR DEAD LOAD:</b>  10 PSF	<b>HEATING DEGREE DAYS:</b>  9316

**APPLICABLE STATE CODES**

Building – 2009 MRC/B	Electrical – 2009 MRC/E	Mechanical – 2009 MRC/M	Plumbing – 2009 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

**LIMITATIONS OF APPROVAL (IF ANY)** "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

**CERTIFICATION**

REVIEWED BY:  
  
 Sheila Hartfield, Plan Reviewer

ISSUED DATE:  
 November 17, 2011

AGENCY OFFICIAL:  
  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:  
 November 21, 2011

**BUILDING SYSTEM APPROVAL REPORT**  
Michigan Department of Energy, Labor & Economic Growth  
Bureau of Construction Codes  
Plan Review Division  
P.O. Box 30254  
Lansing, MI 48909  
(517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Energy, Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  PDC Facilities Inc 700 Walnut Ridge Drive Hartland, WI 53029	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b>  365
	<b>BUILDING SYSTEM APPROVAL REPORT NO.:</b>  95103
	<b>TYPE OF APPROVAL:</b>  New System

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> 28'W x 45'L x 12'7"H MRI Diagnostic Imaging Bldg			
<b>USE GROUP:</b> I2	<b>CONSTRUCTION TYPE:</b> IIB	<b>OCCUPANT LOAD:</b> 10 Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> 25.2 PSF	<b>FLOOR LIVE LOAD:</b> 100 PSF	<b>GROUND SNOW LOAD:</b> 30 PSF	
<b>WIND SPEED:</b> 120 MPH	<b>ROOF DEAD LOAD:</b> 20 PSF	<b>FLOOR DEAD LOAD:</b> 40 PSF	<b>HEATING DEGREE DAYS:</b> 6979

**APPLICABLE STATE CODES**

Building – 2006 MBC	Electrical – 2008 NEC	Mechanical – 2006 MMC	Plumbing – 2006 MPC
---------------------	-----------------------	-----------------------	---------------------

**LIMITATIONS OF APPROVAL (IF ANY)** The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

**CERTIFICATION**

REVIEWED BY:

Sheila Hartfield, Plan Reviewer

AGENCY OFFICIAL:

Todd Y. Cordill, NCARB, Chief, Plan Review Division

ISSUED DATE:

November 24, 2010

PUBLISHED DATE:

December 7, 2010

cc: TR Arnold & Associates Inc

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Energy, Labor & Economic Growth  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Energy, Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b>  167
	<b>BUILDING SYSTEM APPROVAL REPORT NO.:</b>  96039
	<b>TYPE OF APPROVAL:</b>  New System

**DESIGN DATA**


<b>DESCRIPTION OF MANUFACTURED MODEL:</b> RM 3005-MI-01 Cape Cod 27'4"x60'0" with Basement			
<b>USE GROUP:</b> R3	<b>CONSTRUCTION TYPE:</b> VB	<b>OCCUPANT LOAD:</b> NA Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> 44.5/ 62.3 PSF	<b>FLOOR LIVE LOAD:</b> 40 PSF	<b>GROUND SNOW LOAD:</b> 50/ 70 PSF	
<b>WIND SPEED:</b> 90 MPH	<b>ROOF DEAD LOAD:</b> 10 PSF	<b>FLOOR DEAD LOAD:</b> 10 PSF	<b>HEATING DEGREE DAYS:</b> 8356


**APPLICABLE STATE CODES**

Building – 2006 MRC/B	Electrical – 2006 MRC/E	Mechanical – 2006 MRC/M	Plumbing – 2006 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

**LIMITATIONS OF APPROVAL (IF ANY)** The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:  
 HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.

**CERTIFICATION**

**REVIEWED BY:**  
  
 Sheila Hartfield, Plan Reviewer

**AGENCY OFFICIAL:**  
  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

**ISSUED DATE:**  
November 22, 2010

**PUBLISHED DATE:**  
November 24, 2010

cc: PFS Corporation

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Energy, Labor & Economic Growth  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Energy, Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b>
	167
	<b>BUILDING SYSTEM APPROVAL REPORT NO.:</b>
	96158
	<b>TYPE OF APPROVAL:</b>
	New System

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> 6017-MI-01 Ranch 30'0"x64'0" with Basement			
<b>USE GROUP:</b> R3	<b>CONSTRUCTION TYPE:</b> VB	<b>OCCUPANT LOAD:</b> NA Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> 57.8/ 80.9 PSF		<b>FLOOR LIVE LOAD:</b> 40 PSF	<b>GROUND SNOW LOAD:</b> 50/ 70 PSF
<b>WIND SPEED:</b> 90 MPH	<b>ROOF DEAD LOAD:</b> 10 PSF	<b>FLOOR DEAD LOAD:</b> 10 PSF	<b>HEATING DEGREE DAYS:</b> 8356

**APPLICABLE STATE CODES**

Building – 2006 MRC/B	Electrical – 2006 MRC/E	Mechanical – 2006 MRC/M	Plumbing – 2006 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

**LIMITATIONS OF APPROVAL (IF ANY)** The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured:

**CERTIFICATION**


REVIEWED BY:

  
 Sheila Hartfield, Plan Reviewer

ISSUED DATE:

November 18, 2010

AGENCY OFFICIAL:

  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

PUBLISHED DATE:

November 24, 2010

cc: PFS Corporation

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Energy, Labor & Economic Growth  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Energy, Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b> <div style="text-align: center; border-top: 1px solid black; border-bottom: 1px solid black;">167</div> <b>BUILDING SYSTEM APPROVAL REPORT NO.:</b> <div style="text-align: center; border-top: 1px solid black; border-bottom: 1px solid black;">96244</div> <b>TYPE OF APPROVAL:</b> <div style="text-align: center; border-top: 1px solid black; border-bottom: 1px solid black;">New System</div>
---	---

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> RM 07 / RM 08 26'0"x56'0" Ranch with Basement, Reverse Basement, Crawlspace, Reverse Crawlspace and Various Options
--

<b>USE GROUP:</b> R3	<b>CONSTRUCTION TYPE:</b> VB	<b>OCCUPANT LOAD:</b> NA Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> 57.8/ 80.9 PSF	<b>FLOOR LIVE LOAD:</b> 40 PSF	<b>GROUND SNOW LOAD:</b> 50/ 70 PSF	
<b>WIND SPEED:</b> 90 MPH	<b>ROOF DEAD LOAD:</b> 10 PSF	<b>FLOOR DEAD LOAD:</b> 10 PSF	<b>HEATING DEGREE DAYS:</b> 8356

**APPLICABLE STATE CODES**


Building – 2006 MRC/B	Electrical – 2006 MRC/E	Mechanical – 2006 MRC/M	Plumbing – 2006 MRC/P
-----------------------	-------------------------	-------------------------	-----------------------

<b>LIMITATIONS OF APPROVAL (IF ANY)</b> "The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured". HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.
---

**CERTIFICATION**

**REVIEWED BY:**  
  
 \_\_\_\_\_  
 Sheila Hartfield, Plan Reviewer

**ISSUED DATE:**  
 November 30, 2010

**AGENCY OFFICIAL:**  
  
 \_\_\_\_\_  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

**PUBLISHED DATE:**  
 December 9, 2010

cc: PFS Corporation

**BUILDING SYSTEM APPROVAL REPORT**  
 Michigan Department of Energy, Labor & Economic Growth  
 Bureau of Construction Codes  
 Plan Review Division  
 P.O. Box 30254  
 Lansing, MI 48909  
 (517) 241-9328

Authority: 1972 PA 230 Completion: Mandatory Penalty: Approval shall be revoked	The Michigan Department of Energy, Labor & Economic Growth will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, disability, or political belief. If you need help with reading, writing, hearing, etc., under the Americans with Disabilities Act, you may make your needs known to this agency.
---	--

This document shall be considered the building system approval report by the construction code commission and shall be accepted by any jurisdiction within the state of Michigan subject to that jurisdiction's determination of compliance with the state construction code.

**MANUFACTURER DATA**

<b>MANUFACTURER:</b>  Champion Home Builders Inc 308 Sheridan Drive PO Box 95 Topeka, IN 46571	<b>COMPLIANCE ASSURANCE PROGRAM NO.:</b> <p style="text-align: center;">167</p> <b>BUILDING SYSTEM APPROVAL REPORT NO.:</b> <p style="text-align: center;">96025</p> <b>TYPE OF APPROVAL:</b> <p style="text-align: center;">New System</p>
---	--

**DESIGN DATA**

<b>DESCRIPTION OF MANUFACTURED MODEL:</b> RM 2640 MI 01 26'0"x40'0" Ranch with Crawlspace, various options			
<b>USE GROUP:</b> R3	<b>CONSTRUCTION TYPE:</b> VB	<b>OCCUPANT LOAD:</b> N/A Persons	<b>TYPE OF UNIT:</b> Modular
<b>ROOF LIVE/SNOW LOAD:</b> 57.8, 80.9 PSF	<b>FLOOR LIVE LOAD:</b> 40 PSF	<b>GROUND SNOW LOAD:</b> 50, 70 PSF	
<b>WIND SPEED:</b> 90 MPH	<b>ROOF DEAD LOAD:</b> 10 PSF	<b>FLOOR DEAD LOAD:</b> 10 PSF	<b>HEATING DEGREE DAYS:</b> 8356


**APPLICABLE STATE CODES**

Building – 2006 MRC/B	Electrical – 2006 MRC/E	Mechanical – 2006 MRC/M	Plumbing – 2006 MRC/P
<b>LIMITATIONS OF APPROVAL (IF ANY)</b> *The specific options must be shown as a part of the approved set of plans and shall be identified for each unit manufactured: HVAC equipment and main duct work trunks is subject to the approval of the local enforcing agency.			

**CERTIFICATION**

**REVIEWED BY:**  
  
 Sheila Hartfield, Plan Reviewer

**ISSUED DATE:**  
 November 15, 2010

**AGENCY OFFICIAL:**  
  
 Todd Y. Cordill, NCARB, Chief, Plan Review Division

**PUBLISHED DATE:**  
 November 19, 2010

cc: PFS Corporation