

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1627-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2009 Michigan Plumbing Code.

MANUFACTURER:

Triangle Tube

PRODUCT:

Triangle Tube Challenger Combination Boiler and/or Water Heater Models CC85, CC105, and CC125

MANUFACTURER DESIGNATION:

Freeway Centers
1 Triangle Tube Lane
Blackwood, NJ 08012

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Electrical, Mechanical, and Plumbing Codes shall be applicable.
2. Installed in accordance with manufacturer's installation instructions.
3. An acceptable pressure and temperature protection shall be provided with the correct BTU rating for the domestic hot water supply.
4. When an antifreeze solution is used it shall be of an essentially nontoxic transfer fluid in accordance with Section 608.16.3 of the code.
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code or a change in design/designation occurs.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Robert G. Konyndyk - Chief Plumbing Division

Effective Date: April 4, 2012