

**MICHIGAN DEPARTMENT OF LABOR AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909**

**CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL**

1628-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

MANUFACTURER:

Omega Flex Inc.

PRODUCT:

TracPipe Counterstrike CSST Gas Piping System with AutoFlare fittings.

MANUFACTURER DESIGNATION:


213 Court Street Suite 701
Middletown, CT 06457

CONDITIONS OF USE AND INSTALLATION:

1. Must be installed to the Michigan Mechanical & Residential Codes.
2. Must be installed to the International Fuel Gas Code.
3. Must be installed in accordance with the Omega Flex Design and Installation Guide.
4. Not approved for operating pressures above 25-PSI.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission



Irvin J. Poke, AIA, Director

Kevin Kalakay, Chief, Mechanical Division

Effective Date: 4/4/2012