

MICHIGAN DEPARTMENT OF LABOR AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
P.O. BOX 30254  
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY  
PRODUCT APPROVAL

1631-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

**MANUFACTURER:**

Uponor, Inc.

**PRODUCT:**

Uponor AquaSAFE Looped Fire Sprinkler System for residential applications.


**MANUFACTURER DESIGNATION:**

5925 148<sup>th</sup> Street West  
Apple Valley, MN 55124

**CONDITIONS OF USE AND INSTALLATION:**

1. All requirements of the Michigan Mechanical and Plumbing Codes most recent editions shall be applicable.
2. Installation shall be in accordance with the manufacturer's installation guide, NFPA, 13D, and installed as loop system.
3. The system shall be designed and certified by the manufacturer.
4. Installers shall have obtained a manufacturer's certification by attending the manufacturer's training and certification program.
5. Permits for installations shall be obtained by a firm that is a licensed mechanical contractor with the "Fire Suppression" classification and a licensed plumbing contractor, or separate contractors appropriately licensed in each discipline. A mechanical permit and a plumbing permit shall be obtained to assure safe installation and code compliance. The installers shall be licensed plumbers and such systems shall be designed as alternative design methods and require plan review for the installations.
6. This approval shall become void if the product no longer conforms to the current mechanical and plumbing codes.

**THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.**



By Direction of the Construction Code Commission

*Irvin J. Poke*  
Irvin J. Poke, AIA, Director

*Kevin Kalakay*  
Kevin Kalakay, Chief, Mechanical Division

Effective Date: July 9, 2012

BCC-978 (Rev. 02/11)