

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
P.O. BOX 30254  
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY  
PRODUCT APPROVAL

1636-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2009 Michigan Plumbing Code.

**MANUFACTURER:**

ProSet Systems, Inc.

**PRODUCT:**

Trap Guard Device, Barrier Type Floor Drain Trap Seal Protection Device, models TG22 and TG33

**MANUFACTURER DESIGNATION:**

ProSet Systems, Inc.  
1355 Capital Circle  
Lawrenceville, GA 30043

**CONDITIONS OF USE AND INSTALLATION:**

1. All requirements of the Michigan Plumbing Code shall be applicable.
2. Installed in accordance with manufacturer's installation instructions.
3. The device shall have product labeling in compliance with ASSE 1072, Section 4.2.1 on the product, that being the name and application design.
4. The installation shall be for 2" and 3" floor drains in accordance with the flow capacities of ASSE 1072, Barrier Type Floor Drain Trap Seal Protection Devices, Section I, 1.2.3
5. Not acceptable for use in wood floors, floors subject to wax, or floors subject to grease laden waste.
6. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code or a change in design/designation occurs.
7. These devices shall not replace the need for a trap.

**THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.**



By Direction of the Construction Code Commission

  
Irvin J. Poke, AIA, Director

  
Robert G. Konyndyk -Chief, Plumbing Division

Effective Date: January 9, 2013