DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1638-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2009 Michigan Plumbing Code.

MANUFACTURER:

Apollo Corporation

PRODUCT:

Essence Bathing System, WP7 and AS7 health care bathing tubs (7000 series)

MANUFACTURER DESIGNATION:

Apollo Corporation
450 Main Street
P.O. Box 219
Somerset, WI 54025

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing and Electrical Codes shall be applicable.
2. Installations shall be in accordance with the manufacturer's specifications.
3. Requests from hospital or care institutions must be approved by the Health Department having jurisdiction.
4. Both hot and cold water supplies shall be protected by and approved for reduced pressure principle backflow preventer.
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code or a change in design/designation occurs.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Robert G. Konyndyk – Chief, Plumbing Division

Effective Date: January 9, 2013