

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
P.O. BOX 30254  
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY  
PRODUCT APPROVAL

1640-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

**MANUFACTURER:**

Gastite Division

**PRODUCT:**

FlashShield CSST flexible fuel gas piping system in sizes ½", ¾", 1" and 1 ¼".

**MANUFACTURER DESIGNATION:**

1116 Vaughn Parkway  
Portland, Tennessee 37148

**CONDITIONS OF USE AND INSTALLATION:**

1. All requirements of the Michigan Mechanical, Michigan Residential and International Fuel Gas Codes most current editions shall apply, except the code provisions for CSST bonding.
2. Installations shall be in accordance with the Gastite Design and Installation Guide.
3. All installations must pass inspection by the authority having jurisdiction prior to being placed into service.
4. Not approved for pressure above 5 PSI.

**THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.**



By Direction of the Construction Code Commission

*Irvin J. Poke*  
Irvin J. Poke, AIA, Director

*Kevin D. Kalakay*  
Kevin D. Kalakay, Chief, Mechanical Division

Effective Date: 4/3/13