

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1643-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

MANUFACTURER:

Omega Flex, Inc.

PRODUCT:

Tracpipe PS II.


MANUFACTURER DESIGNATION:

213 Court Street, Suite 1001
Middletown, Connecticut 06457

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Residential and the International Fuel Gas Code. Most current editions shall apply.
2. Installations shall be in accordance with the manufacturer's installation instructions.
3. Shall only be installed by a qualified person who has been trained through the Tracpipe Gas Piping Installation Program.
4. The ability of the system to withstand the superimposed loads shall be documented to the code official for each installation.
5. Not approved for pressures above 5-PSI.
6. This approval shall become void if the product no longer conforms to the current Michigan Mechanical or Michigan Residential codes.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission

Irvin J. Poke
Irvin J. Poke, AIA, Director

Kevin D. Kalakay
Kevin D. Kalakay, Chief, Mechanical Division

Effective Date: 7/15/13