

MICHIGAN DEPARTMENT OF LABOR AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1645-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

MANUFACTURER:

Ward Manufacturing LLC

PRODUCT:

Wardflex II.


MANUFACTURER DESIGNATION:

117 Gillick Street
Blossburg, PA 16912

CONDITIONS OF USE AND INSTALLATION:


1. All requirements of the Michigan Residential and the International Fuel Gas Codes most current editions shall apply, except the code requirement for CSST bonding.
2. Must be installed per the manufacturer's installation instructions.
3. Shall only be installed by a qualified person who has been trained through the Wardflex Gas Piping Installation Program.
4. Not approved for pressures above 5-PSI.
5. This approval shall become void if the product no longer conforms to the current Michigan Mechanical, Michigan Residential and International Fuel Gas codes.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission


Irvin J. Poke, AIA, Director


Kevin Kalakay, Chief, Mechanical Division

Effective Date: October 2, 2013

BCC-978 (Rev. 02/11)