

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1648-MA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Mechanical Division.

MANUFACTURER:
REHAU Construction LLC.


PRODUCT:
REHAU RAUPEX 10.1mm Crosslink Polyethylene Tubing

MANUFACTURER DESIGNATION:
1501 Edwards Ferry Rd
Leesburg, Virginia 20176


CONDITIONS OF USE AND INSTALLATION:


1. All applicable requirements of the Michigan Residential and the Michigan Mechanical Code most current editions shall apply.
2. Installation shall be in accordance with the manufacturer's installation instructions.
3. Shall only be installed by a properly licensed State of Michigan mechanical contractor who has been properly trained by the manufacturer.
4. All installations shall be pressure tested in the presence of the code official.
5. This approval shall become void if the product no longer conforms to the current Michigan Mechanical and Michigan Residential codes.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission


Irvin J. Poke, AIA, Director


Kevin Kalakay, Chief, Mechanical Division

Effective Date: April 3, 2014