

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1651-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2012 Michigan Plumbing Code.

MANUFACTURER:

Custom Building Products, Inc.

PRODUCT:

Custom 9240 Waterproofing and Anti-Fracture Membrane, models C9240K, C9240L and C9240F

MANUFACTURER DESIGNATION:

Custom Building Products, Inc.
13001 Seal Beach Blvd.
Seal Beach, CA 90740

CONDITIONS OF USE AND INSTALLATION:


1. All requirements of the Michigan Plumbing Code and Michigan Residential Code shall be applicable.
2. Shall be installed in accordance with manufacturer's installation instructions.
3. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code, Michigan Residential Code or a change in design/designation occurs.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission


Irvin J. Poke, AIA, Director


Joseph T. Madziar, Chief, Plumbing Division



Effective Date: April 2, 2014