

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1654-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2012 Michigan Plumbing Code.

MANUFACTURER:

MIFAB, Inc.

PRODUCT:

Floor Drain Trap Seal Protection Devices, models MI-GARD-2, MI-GARD-3, MI-GARD-35, and MI-GARD-4

MANUFACTURER DESIGNATION:

MIFAB, Inc.
1321 W. 119th Street
Chicago, IL 60643

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing Code shall be applicable.
2. Shall be installed in accordance with manufacturer's installation instructions.
3. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code or a change in design/designation occurs.
4. These devices shall not replace the need for a trap.
5. These devices are approved to take the place of a trap seal primer valve.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.



By Direction of the Construction Code Commission


Irvin J. Poke, AIA, Director


Joseph T. Madziar, Chief, Plumbing Division

Effective Date: October 1, 2014