DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1657-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2012 Michigan Plumbing Code.

MANUFACTURER:

Liquid Breaker

PRODUCT:

GD 102, GD 103, GD 103.5 and GD 104

MANUFACTURER DESIGNATION:

335 North Puente Street Suite F
Brea, California 92821

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing Code shall be acceptable.
2. Shall be installed in accordance with the manufacturers installation instructions.
3. These devices shall not replace the need for a trap.
4. These devices are approved to take the place of a trap seal primer valve
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Joseph T. Madziar – Chief, Plumbing Division

Effective Date: July 27, 2015

BCC-978 (Rev. 10/10)