

DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
BUREAU OF CONSTRUCTION CODES  
P.O. BOX 30254  
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY  
PRODUCT APPROVAL

1658-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2012 Michigan Plumbing Code.

**MANUFACTURER:**

Norcom

**PRODUCT:**

RG9 Hydromassage Bathing Tub

**MANUFACTURER DESIGNATION:**

155 Norcom Way  
Sparta, Tennessee 38583

**CONDITIONS OF USE AND INSTALLATION:**

1. All requirements of the Michigan Plumbing and Electrical Codes shall be applicable.
2. Installations shall be in accordance with the manufacturer's installation instructions.
3. Requests from Hospitals or Care Institutions must be approved by the Health Department having jurisdiction.
4. Both hot and cold water supplies shall be protected by an approved reduced pressure principle backflow preventer.
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

**THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.**

By Direction of the Construction Code Commission



*Irvin J. Poke*  
Irvin J. Poke, AIA, Director

*Joseph T. Madziar*  
Joseph T. Madziar - Chief, Plumbing Division

Effective Date: July 27, 2015