DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF CONSTRUCTION CODES
P.O. BOX 30254
LANSING, MI 48909

CERTIFICATE OF ACCEPTABILITY
PRODUCT APPROVAL

1659-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2009 Michigan Plumbing Code.

MANUFACTURER:

Norcom

PRODUCT:

RR7-ll Atlantic Hydromassage Bathing Tub

MANUFACTURER DESIGNATION:

155 Norcom Way
Sparta, Tennessee 38583

CONDITIONS OF USE AND INSTALLATION:

1. All requirements of the Michigan Plumbing and Electrical Codes shall be applicable.
2. Installations shall be in accordance with the manufacturer's installation instructions.
3. Requests from Hospitals or Care Institutions must be approved by the Health Department having jurisdiction.
4. Both hot and cold water supplies shall be protected by an approved reduced pressure principle backflow preventer
5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

By Direction of the Construction Code Commission

Irvin J. Poke, AIA, Director

Joseph T. Madziar –Chief, Plumbing Division

Effective Date: July 27, 2015