

**SCOPE OF SERVICES
CONSTRUCTION SERVICES – QUESTIONS & ANSWERS No. 2**

Underground Storage Tank Removal

Question 1: Will the UST removal contractors be required to pay prevailing wages to their employees?

Answer 1: Yes

Question 2: Is waste characterization analysis of the residual liquid and sludge in a tank necessary if there is still some gasoline or diesel in the tank?

Answer 2: Waste characterization analysis of the contents of an UST is not necessary for hauling and disposal when there is sufficient knowledge of the composition of the tank residual liquid. When the tank contents are unknown, waste characterization analysis is necessary. For the pay items and quantities to be added together to get a total price for the bid for each region, assume the tank contents are unknown.