

Specialty Services for Car Pool Lot Solar Array Installation in the Grand Region
Requisition #552 QA3
3/16/11

- Q) Can you tell me if MDOT has a minimum height required for car ports/ structures?
- A) **The proposal initially stated “..with consideration of maneuverability and under clearance for snow removal vehicles. Typical snow removal vehicle consists of a full size pickup truck...” It has been determined that there is a potential for larger equipment to clear this lot. As such, the minimum height requirement for under clearance should be 12 feet.**