

ADULT FOSTER CARE LICENSING () Original
FIRE SAFETY WORKSHEET - GROUP HOMES/FAMILY HOME 1-6 () Renewal
APPLICATION DATE: ON OR BEFORE 3/27/80

Facility : _____ License #: _____ Date of Inspection: _____

FIRE SAFETY: ON OR BEFORE 3/27/80		YES	NO	COMMENTS
R231	All occupied rooms are of standard lath and plaster construction, or equivalent.			
R233	Basement bedrooms are 50% or more above grade with 2 acceptable means of egress.			
R242	Interior finishes are not made from highly flammable material such as paper, cardboard, etc.			
R243(1)	Means of egress, that is the entire passage to safe ground outside, is kept unobstructed.			
R243(1)	Basements used for resident activity have 2 acceptable means of egress.			
R243(1)	Doors which form required means of egress must have positive latching non-locking against egress hardware, and must be at least 30", or 36" if new construction.			
R243(1)	Exit doors insure adequate egress for residents who use wheelchairs, and have ramps, where needed.			
R243(2)	1 st floor has 2 separate and independent means of egress leading to the outside.			
R243(3)	New or remodeled homes – corridors lead directly to the outside or to required stairways that lead to the outside at grade level. (No dead end corridors).			
R243(4)	Exterior doors and doors of occupied rooms have positive latching, non-locking against egress hardware.			
R243(5)	If accommodating residents who use wheelchairs, has two ramps and primary and secondary exits, with no more than 1 foot of rise in 12 feet of run.			
R244(1)	Is heated by an approved heating plant.			
R244(1)	If heating plant is in the basement, floor separation between the basement and 1 st floor is provided and includes a 1 3/4" solid wood core door, or equivalent.			

ADULT FOSTER CARE LICENSING () Original
FIRE SAFETY WORKSHEET - GROUP HOMES/FAMILY HOME 1-6 () Renewal
APPLICATION DATE: ON OR BEFORE 3/27/80

FIRE SAFETY: ON OR BEFORE 3/27/80		YES	NO	COMMENTS
R244(1)	If heating plant is on the same level as resident, the furnace room is separated from the rest of the building with a minimum 1-hour protected enclosure.			
R244(1)	Furnace room has a permanent, non-closable outside vent for combustion air.			
R244(1)	Home does not use space heaters.			
R244(2)	Has approved, permanent, fixed type electrical heating, such as baseboard heat.			
R244(2)	Has AGA approved sealed combustion wall heater installed per manufacturer's recommendations and on outside wall, with combustion air directly from outside and vented directly to the outside.			
R244(3)	Has flame producing water heater that is installed with the same protection as a heating plant.			
244(4)	Combustible materials are not stored in rooms containing the heating plant, water heater or incinerator.			
R245	Has one 5 lb. multi-purpose (2A10 BC) fire extinguisher, or equivalent, on each occupied floor and in the basement.			
R246	Electrical service is maintained in safe condition.			
R246	Electrical inspection needed? If so, done by qualified inspection service and copy submitted to department?			
Group R403(8) Family R247(1)	Interior and exterior stairways have sturdy, securely fastened handrails that are between 30"-34" above upper tread surface.			
Group R403(8) Family R247(1)	Exterior stairways and porches have handrails on all open sides.			
Group R403(10) Family R247(2)	Scatter or throw rugs have nonskid backings.			
Group R403(11) Family R247(3)	Bath and shower areas have handrails and nonskid surfacing/strips.			

ADULT FOSTER CARE LICENSING () Original
FIRE SAFETY WORKSHEET - GROUP HOMES/FAMILY HOME 1-6 () Renewal
APPLICATION DATE: ON OR BEFORE 3/27/80

Group R403(12) Family R247(4)	Sidewalks, fire escape routes and entrances are free of hazards.			
Group R402(6) Family R426(12)	Cooking appliances are installed in accordance with approved safety practices.			
Group R402(6) Family R426(12)	Metal canopies are equipped with filters and are clean and maintained in good condition.			
Group R318 (3) Family R261(1)	Has a telephone.			
Group R318 (3) Family R261(2)	Emergency numbers posted next to phone			
Group R318 (1) Family R261(1)(2)	Has written emergency procedure and evacuation plan.			
Group R318 (2) Family R261(2)	Evacuation plan minimally include a floor plan.			
Group R318 (4) Family 261(1)	Employees and residents familiar with emergency and evacuation procedures.			
Group R318 (5)	Practice emergency and evacuation procedures during daytime, evening, and sleeping hours at least once per quarter.			
Family 261(2)	At least 4 fire drills per year			
Group R318 (5)	A record of practices be maintained and available for review.			
Group R318 (6)	Availability of emergency transportation.			