



\*When a routine sample is positive for total coliform or *E. coli*, collect samples from repeat sites in the distribution system. Groundwater supplies must also sample all raw water sources (wells) for each positive routine sample result. With EGLE approval, source water collection may be limited to those wells that were in use at any time within the 72-hour period prior to the collection of the routine positive sample. Supplies that purchase their water must notify their water supplier within 24 hours of a positive routine sample result. Surface water supplies are not required to sample their source water.