

**PERMIT NO. MI0048453**

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY  
AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Water Pollution Control Act, as amended, (33 U.S.C. 1251 et seq; the "Federal Act"), Michigan Act 451, Public Acts of 1994, as amended (the "Michigan Act"), Parts 31 and 41, and Michigan Executive Orders 1991-31, 1995-4 and 1995-18,

Pall Corporation  
600 South Wagner Road  
Ann Arbor, Michigan 48103

is authorized to discharge from the groundwater remediation treatment facility located at

600 South Wagner Road  
Ann Arbor, Michigan 48103

**designated as Pall Life Sciences Inc**

to the receiving water named the unnamed tributary of Honey Creek in accordance with effluent limitations, monitoring requirements and other conditions set forth in this permit.

Unless specified otherwise, all contact with the Michigan Department of Environmental Quality (the "Department") required by this permit shall be made to the Jackson District Supervisor of the Water Bureau. The Jackson District Office is located at 301 East Louis Glick Highway, Jackson, Michigan 49201-1556, telephone: 517-780-7690, fax: 517-780-7855.

In accordance with Section 324.3120 of the Michigan Act, the permittee shall make payment of an annual permit fee to the Department for each October 1 the permit is in effect regardless of occurrence of discharge. The permittee shall submit the fee in response to the Department's annual notice. The fee shall be postmarked by January 15 for notices mailed by December 1. The fee is due no later than 45 days after receiving the notice for notices mailed after December 1. Fees paid in accordance with the Michigan Act are not refundable.

In accordance with Section 324.3118 of the Michigan Act, the permittee shall make payment of an annual storm water fee to the Department for each January 1 the permit is in effect regardless of occurrence of discharge. The permittee shall submit the fee in response to the Department's annual notice. The fee shall be postmarked by March 15 for notices mailed by February 1. The fee is due no later than 45 days after receiving the notice for notices mailed after February 1. Fees paid in accordance with the Michigan Act are not refundable.

Any person who is aggrieved by this permit may file a sworn petition with the Office of Administrative Hearings of the Michigan Department of Environmental Quality, setting forth the conditions of the permit which are being challenged and specifying the grounds for the challenge. The Department may reject any petition filed more than 60 days after issuance as being untimely.

This permit is based on a complete application submitted on March 31, 2004, as amended through August 5, 2005.

This permit takes immediate effect on the date of issuance. The provisions of this permit are severable. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term in accordance with applicable laws and rules. On its effective date this permit shall supersede NPDES Permit No. MI0048453, expiring October 1, 2004, and Certificate of Coverage No. MIS410028, which is hereby revoked upon the effective date of this permit.

This permit and the authorization to discharge shall expire at midnight, October 1, 2009. In order to receive authorization to discharge beyond the date of expiration, the permittee shall submit an application which contains such information, forms, and fees as are required by the Department by April 1, 2009.

Issued \_\_\_\_\_.

Original Permit Signed by William Creal  
William Creal, Chief  
Permits Section  
Water Bureau

**PART I**

**Section A. Effluent Limitations And Monitoring Requirements**

**1. Final Effluent Limitations, Monitoring Point 001A**

During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee is authorized to discharge a maximum of 1.872 MGD of treated groundwater from Monitoring Point 001A through Outfall 001. Outfall 001 discharges to an unnamed tributary of Honey Creek. Such discharge shall be limited and monitored by the permittee as specified below.

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>			<u>Maximum Limits for Quality or Concentration</u>			<u>Frequency of Analysis</u>	<u>Sample Type</u>
	<u>Monthly</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>Daily</u>	<u>Units</u>		
<b><u>INFLUENT MONITORING AND REPORTING</u></b>								
1,4-Dioxane	---	---	---	---	(report)	mg/l	Weekly	Grab
<b><u>DISCHARGE LIMITATIONS, MONITORING AND REPORTING</u></b>								
Flow	(report)	(report)	MGD	---	---	---	Daily	Report Total Daily Flow
1,4-Dioxane (see Part I.A.1.e., page 3)								
through December 31, 2005	---	---	---	7	22	µg/l	5×Weekly	3-Portion Composite
beginning January 1, 2006	---	---	---	7	22	µg/l	5×Weekly	24-Hr Composite
Bromate								
through December 31, 2005	---	---	---	10	(report)	µg/l	5×Weekly	3-Portion Composite
beginning January 1, 2006	---	---	---	10	(report)	µg/l	5×Weekly	24-Hr Composite
Hydrogen Peroxide	---	---	---	---	180	µg/l	5×Weekly	Grab
Chronic Toxicity	---	---	---	1.0	---	TU <sub>C</sub>	Monthly	24-Hr Composite
Oxalic Acid	---	---	---	---	(report)	µg/l	Monthly	Grab
Sodium Bisulfite Dose Rate	---	---	---	---	(report)	mg/l	2×Weekly	Calculation
Equipment Inspection	(report)	---	---	---	---	---	2×Weekly	Visual
Outfall Observation	(report)	---	---	---	---	---	Weekly	Visual
				<b><u>Minimum</u></b>	<b><u>Maximum</u></b>			
				<b><u>Daily</u></b>	<b><u>Daily</u></b>			
pH	---	---	---	6.5	9.0	S.U.	Monthly	Grab

- a. **BAT Treatment**  
This permit is based on the permittee providing chemical oxidation treatment through use of either UV/hydrogen peroxide treatment technology or ozone/hydrogen peroxide treatment technology. If treatment other than UV/hydrogen peroxide treatment technology or ozone/hydrogen peroxide treatment technology is proposed, the permittee shall amend the application received on March 31, 2004, as amended through August 5, 2005. The permit may then be modified to include additional effluent limitations to protect water quality in accordance with applicable rules and regulations.
- b. **Monitoring Locations**  
Samples, measurements, and observations taken in compliance with the monitoring requirements above shall be taken prior to treatment for all influent monitoring and after treatment but prior to mixing with any other waste stream for all effluent monitoring.

## PART I

### Section A. Effluent Limitations And Monitoring Requirements

- c. Narrative Standard  
The receiving water shall contain no unnatural turbidity, color, oil films, floating solids, foams, settleable solids, suspended solids, or deposits as a result of this discharge.
- d. Outfall Observation  
Any unusual characteristics of the discharge (i.e., unnatural turbidity, color, oil film, floating solids, foams, settleable solids, suspended solids, or deposits) shall be reported within 24 hours to the Department followed with a written report within five (5) days detailing the findings of the investigation and the steps taken to correct the condition.
- e. Compliance Monitoring and Sampling for 1,4-Dioxane  
Through December 31, 2005, compliance with the effluent limitations for 1,4-dioxane contained in Part I.A.1. of this permit shall be determined based upon 3-portion composite samples. Beginning January 1, 2006, compliance with the effluent limitations for 1,4-dioxane contained in Part I.A.1. of this permit shall be determined based upon 24-hour composite samples. Following collection of the composite samples, the samples shall immediately be refrigerated at 4°C or less, while not allowing the sample to freeze. Refrigeration is not required, if the sample will be immediately analyzed upon collection. In addition, the analytical results of any grab samples taken of the effluent for 1,4-dioxane shall be reported as an attachment to the monthly Discharge Monitoring Report forms.
- f. Quantification Level for Bromate  
The quantification level for bromate shall be 5 µg/l unless a higher level is appropriate due to sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination.
- g. Whole Effluent Toxicity Requirements  
Test species shall include fathead minnow **and** either *Daphnia magna* or *Ceriodaphnia dubia*. Testing and reporting procedures shall follow procedures contained in EPA/600/4-91/002, "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms," for fathead minnow and *Ceriodaphnia*, and ASTM E1193-97 "Standard Guide for Conducting *Daphnia magna* Life-Cycle Toxicity Tests" for *D. magna* as modified by the Water Bureau ("WD modifications to ASTM E1193-97"). The acute toxic unit value (TU<sub>A</sub>) and chronic toxic unit value (TU<sub>C</sub>) for **each species tested** shall be reported on the Discharge Monitoring Report (DMR). If multiple chronic toxicity tests for the same species are performed during the month, the maximum TU<sub>A</sub> value and monthly average TU<sub>C</sub> value for the species shall be reported. For **each species not tested**, the permittee shall enter "**\*W**" on the DMR. Completed toxicity test reports for each test conducted shall be retained by the permittee in accordance with the requirements of Part II.B.5. of this permit and shall be available for review by the department upon request. After one (1) year of toxicity testing and upon approval of the Department, the chronic toxicity tests may be performed using the more sensitive species selected from the chronic toxicity database. If a more sensitive species cannot be identified, the chronic toxicity tests shall be performed with both species. Toxicity test data acceptability is contingent upon the validation of the test method by the testing laboratory. Such validation shall be submitted to the Department upon request. In addition, after six (6) months of toxicity testing (i.e., six tests) and upon approval of the Department, the monitoring frequency may be reduced if the test data indicate that the toxicity requirements of Rule 323.1219 of the Michigan Administrative Code are consistently being met. Upon receipt of written approval and consistent with such approval, the permittee may reduce the monitoring frequency indicated in Part I.A.1. of this permit. The Department may revoke the approval for reduced monitoring at any time upon notification to the permittee.

If the final effluent limitation of 1.0 chronic toxic units (TU<sub>C</sub>) for Monitoring Point 001A is not being met, the permittee shall immediately terminate the discharge from Monitoring Point 001A and notify the Department of this action. At least 14 days prior to resuming discharge, the permittee shall notify the Department that measures have been taken to consistently achieve the final effluent limitation of 1.0 TU<sub>C</sub> for Monitoring Point 001A.

**PART I****Section A. Effluent Limitations And Monitoring Requirements**

## h. Limits below the Quantification Level for Hydrogen Peroxide

The water quality-based effluent limitation for hydrogen peroxide is less than the quantification level using the specified analytical method. Any discharge of hydrogen peroxide at or above the quantification level is a specific violation of this permit. If an effluent sample is less than the quantification level, the Michigan Department of Environmental Quality will consider the permittee to be in compliance with the final effluent limitation for this pollutant for the period that the sample represents. This paragraph does not authorize the discharge of hydrogen peroxide at levels which are injurious to the designated uses of the waters of the state or which constitute a threat to the public health or welfare.

The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for hydrogen peroxide shall be in accordance with the colorimetric method as approved by the Department. The quantification level shall not exceed 200 µg/l unless higher levels are appropriate because of sample matrix interference. Other analytical methods may be used upon approval of the Department.

## i. Water Treatment Additives

This permit does not authorize the discharge of water additives without approval from the Department. Approval of water additives is authorized under separate correspondence. Water additives include any material that is added to water used at the facility or to a wastewater generated by the facility to condition or treat the water.

In the event a permittee proposes to discharge water additives, including an increased discharge concentration of a previously approved water additive, the permittee shall submit a request to the Department for approval. Such requests shall be sent to the Surface Water Assessment Section, Water Bureau, Department of Environmental Quality, P.O. Box 30273, Lansing, Michigan 48909, with a copy to the Department contact listed on the cover page of this permit. Instructions to submit a request electronically may be obtained via the Internet (<http://www.michigan.gov/deq> and on the left side of the screen click on Water, Water Quality Monitoring, and Assessment of Michigan Waters; then click on the Water Treatment Additive List which is under the Information banner). Written approval from the Department to discharge such additives at specified levels shall be obtained prior to discharge by the permittee. Additional monitoring and reporting may be required as a condition for the approval to discharge the additive.

A request to discharge water additives shall include all of the following water additive usage and discharge information:

- 1) Material Safety Data Sheet;
- 2) the proposed water additive discharge concentration;
- 3) the discharge frequency (i.e., number of hours per day and number of days per year);
- 4) product function (i.e. microbiocide, flocculant, etc.);
- 5) the type of removal treatment, if any, that the water additive receives prior to discharge;
- 6) a 48-hour LC<sub>50</sub> or EC<sub>50</sub> for a North American freshwater planktonic crustacean (either *Ceriodaphnia sp.*, *Daphnia sp.*, or *Simocephalus sp.*); and
- 7) the results of a toxicity test for one other North American freshwater aquatic species (other than a planktonic crustacean) that meets a minimum requirement of Rule 323.1057(2) of the Water Quality Standards.

Prior to submitting the request, the permittee may contact the Surface Water Assessment Section by telephone at 517-335-1180 or via the Internet at the address given above to determine if the Department has the product toxicity data required by items 6) and 7) above. If the Department has the data, the permittee will not need to submit product toxicity data.

## j. Monitoring Frequency Reduction for Oxalic Acid

After the submittal of twelve (12) months of data (i.e., twelve analyses), the permittee may request, in writing, Department approval of a reduction in monitoring frequency for oxalic acid. This request shall contain an explanation as to why the reduced monitoring is appropriate. Upon receipt of written approval and consistent with such approval, the permittee may reduce the monitoring frequency indicated in Part I.A.1. of this permit. The monitoring frequency for oxalic acid shall not be reduced to less than quarterly. The Department may revoke the approval for reduced monitoring at any time upon notification to the permittee.

## PART I

### Section A. Effluent Limitations And Monitoring Requirements

#### 2. Discharge to the Groundwaters

This site is a known source of groundwater pollution. The reissuance of this permit does not authorize any discharge to the groundwaters or venting of contaminated groundwaters to the surface waters, nor does it constitute a release of liability for any groundwater contamination at or around the site. The state reserves its rights to seek remedies to abate any groundwater contamination.

#### 3. Operations and Maintenance Manual

The permittee shall provide the Department a copy of the Operations and Maintenance Manual for the treatment systems to be used in achieving compliance with this permit's effluent limitations and monitoring requirements. Changes in the operation or maintenance of the treatment system shall be submitted to the Department as amendments to the Operations and Maintenance Manual prior to implementation of the changes. The Department reserves the authority to provide comment and require modification to the Operations and Maintenance Manual and any subsequent amendments submitted by the permittee.

#### 4. Treatment System Operation

The treatment system must be operated in such a manner that the mineralization of 1,4-dioxane is maximized. Treatment parameters, including chemical feed rates, equipment maintenance, etc., all must be optimized to maximize the mineralization of 1,4-dioxane. However, maximized operation does not require that flow rates be reduced nor that treated water be recirculated through the treatment system. The Department may determine what shall be included in maximized operation and may request the submittal of operational data in order to review the parameters affecting treatment optimization.

#### 5. Facility Contact

The "Facility Contact" was specified in the application. The permittee may replace the facility contact at any time, and shall notify the Department in writing within 10 days after replacement (including the name, address and telephone number of the new facility contact).

- a. The facility contact shall be (or a duly authorized representative of this person):
  - for a corporation, a principal executive officer of at least the level of vice president, or a designated representative, if the representative is responsible for the overall operation of the facility from which the discharge described in the permit application or other NPDES form originates,
  - for a partnership, a general partner,
  - for a sole proprietorship, the proprietor, or
  - for a municipal, state, or other public facility, either a principal executive officer, the mayor, village president, city or village manager or other duly authorized employee.
- b. A person is a duly authorized representative only if:
  - the authorization is made in writing to the Department by a person described in paragraph a. of this section; and
  - the authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the facility (a duly authorized representative may thus be either a named individual or any individual occupying a named position).

Nothing in this section obviates the permittee from properly submitting reports and forms as required by law.

**PART I**

**Section A. Effluent Limitations And Monitoring Requirements**

**6. Short Term Waste Characterization Study**

As a condition of this permit, the permittee shall monitor the discharge from Monitoring Point 001A for acetic acid, formic acid, formaldehyde, and acetaldehyde at the frequency and duration specified below. This monitoring is designed to determine whether these constituents are discharged at levels that violate Water Quality Standards. On or before November 1, 2005, the permittee shall commence the 12 week monitoring period.

<u>Constituent</u>	<u>Sample Type</u>	<u>Sample Frequency</u>	<u>Sample Duration</u>	<u>Quantification Level</u>
Acetic Acid	Grab	Weekly	12 Weeks	≤ 1,000 µg/L
Formic Acid	Grab	Weekly	12 Weeks	≤ 1,000 µg/L
Formaldehyde	Grab	Weekly	12 Weeks	100 µg/L
Acetaldehyde	Grab	Weekly	12 Weeks	100 µg/L

**7. Storm Water Pollution Prevention Plan**

The permittee is authorized to discharge storm water associated with industrial activities as defined in 40 CFR 122.26(b)(14). These storm water discharges shall be controlled in accordance with the requirements of this special condition. The permittee has developed and implemented a Storm Water Pollution Prevention Plan (plan). The permittee shall continue implementation of the plan for maximum control of significant materials (as defined in Part II.A.) so that storm water discharges will not cause a violation of the Water Quality Standards. The plan shall be routinely reviewed and updated in accordance with the requirements of this section.

a. Source Identification

To identify potential sources of significant materials that can enter storm water and subsequently be discharged from the facility, the plan shall, at a minimum, include the following:

1) A site map identifying the following: buildings and other permanent structures; storage or disposal areas for significant materials; secondary containment structures; storm water discharge outfalls (numbered for reference); location of storm water inlets contributing to each outfall; location of NPDES permitted discharges other than storm water; outlines of the drainage areas contributing to each outfall; structural runoff controls or storm water treatment facilities; areas of vegetation; areas of exposed and/or erodible soils; impervious surfaces (roofs, asphalt, concrete); name and location of receiving water(s); and areas of known or suspected impacts on surface waters as designated under Part 201 (Environmental Response) of the Michigan Act.

2) A list of all significant materials that could enter storm water. For each material listed, the plan shall include the following descriptions:

a) ways in which each type of material has been or has reasonable potential to become exposed to storm water (e.g., spillage during handling; leaks from pipes, pumps, and vessels; contact with storage piles; waste handling and disposal; deposits from dust or overspray, etc.);

b) identification of the outfall or outfalls through which the material may be discharged if released;

c) a listing of spills and leaks of polluting materials in quantities reportable under the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code) that occurred at areas that are exposed to precipitation or that otherwise discharge to a point source at the facility. The listing shall include spills and leaks that occurred over the three (3) years prior to the completion of the plan or latest update of the plan; the date, volume and exact location of release; and the action taken to clean up the material and/or prevent exposure to storm water runoff or contamination of surface waters of the state. Any release that occurs after the plan has been developed shall be controlled in accordance with the plan and is cause for the plan to be updated as appropriate within 14 calendar days of obtaining knowledge of the spill or loss; and

**PART I****Section A. Effluent Limitations And Monitoring Requirements**

- d) If there is a Total Maximum Daily Load (TMDL) established by the Department for the receiving waters, which restricts the discharge of any of the identified significant materials or constituents of those materials, then the SWPPP shall identify the level of control for those materials necessary to comply with the TMDL, and an estimate of the current annual load of those materials via storm water discharges to the receiving stream.
  - 3) An evaluation of the reasonable potential for contribution of significant materials to runoff from at least the following areas or activities: loading, unloading, and other material handling operations; outdoor storage, including secondary containment structures; outdoor manufacturing or processing activities; significant dust or particulate generating processes; discharge from vents, stacks and air emission controls; on-site waste disposal practices; maintenance and cleaning of vehicles, machines and equipment; sites of exposed and/or erodible soil; sites of environmental contamination listed under Part 201 (Environmental Response) of the Michigan Act; areas of significant material residue; and other areas where storm water may contact significant materials.
  - 4) a summary of existing storm water discharge sampling data (if available) describing pollutants in storm water discharges associated with industrial activity at the facility. This summary shall be accompanied by a description of the suspected source(s) of the pollutants detected.
- b. Preventive Measures and Source Controls, Non-Structural
- To prevent significant materials from contacting storm water at the source, the plan shall, at a minimum, include the following non-structural controls:
- 1) Description of a program for routine preventive maintenance which includes requirements for inspection and maintenance of storm water management and control devices (e.g., cleaning of oil/water separators and catch basins) as well as inspecting and testing plant equipment and systems to uncover conditions that could cause breakdowns or failures resulting in discharges of pollutants to surface waters. A log of the inspection and corrective actions shall be maintained on file by the permittee, and shall be retained in accordance with Record Keeping, below.
  - 2) A schedule for comprehensive site inspection to include visual inspection of equipment, plant areas, and structural pollution prevention and treatment controls to be performed at least once every six (6) months. A report of the results of the comprehensive site inspection shall be prepared and retained in accordance with Record Keeping, below. The report shall identify any incidents of non-compliance with the plan. If there are no reportable incidents of non-compliance, the report shall contain a certification that the facility is in compliance with this plan.
  - 3) A description of good housekeeping procedures to maintain a clean, orderly facility.
  - 4) A description of material handling procedures and storage requirements for significant materials. Equipment and procedures for cleaning up spills shall be identified in the plan and made available to the appropriate personnel. The procedures shall identify measures to prevent the spilled materials or material residues on the outside of containers from being discharged into storm water. The plan may include, by reference, requirements of either a Pollution Incident Prevention Plan (PIPP) prepared in accordance with the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code); a Hazardous Waste Contingency Plan prepared in accordance with 40 CFR 264 and 265 Subpart D, as required by Part 111 of the Michigan Act; or a Spill Prevention Control and Countermeasure (SPCC) plan prepared in accordance with 40 CFR 112.
  - 5) Identification of areas that, due to topography, activities, or other factors, have a high potential for significant soil erosion. The plan shall also identify measures used to control soil erosion and sedimentation.
  - 6) A description of employee training programs which will be implemented to inform appropriate personnel at all levels of responsibility of the components and goals of the plan. The plan shall identify periodic dates for such training.

**PART I****Section A. Effluent Limitations And Monitoring Requirements**

- 7) Identification of actions to limit the discharge of significant materials in order to comply with TMDL requirements.
  - 8) Identification of significant materials expected to be present in storm water discharges following implementation of non-structural preventative measures and source controls.
- c. **Structural Controls for Prevention and Treatment**  
Where implementation of the measures required by Preventive Measures and Source Controls, Non-Structural; above; does not control storm water discharges in accordance with Water Quality Standards, below, the plan shall provide a description of the location, function, and design criteria of structural controls for prevention and treatment. Structural controls may be necessary:
- 1) to prevent uncontaminated storm water from contacting or being contacted by significant materials, and/or
  - 2) if preventive measures are not feasible or are inadequate to keep significant materials at the site from contaminating storm water. Structural controls shall be used to treat, divert, isolate, recycle, reuse or otherwise manage storm water in a manner that reduces the level of significant materials in the storm water and provides compliance with the Water Quality Standards, below.
- d. **Keeping Plans Current**
- 1) The permittee shall review the plan on or before June 1 of each year, and maintain written summaries of the reviews. Based on the review, the permittee shall amend the plan as needed to ensure continued compliance with the terms and conditions of this permit.
  - 2) The plan shall also be updated or amended whenever changes or spills at the facility increase or have the potential to increase the exposure of significant materials to storm water, or when the plan is determined by the permittee or the Department to be ineffective in achieving the general objectives of controlling pollutants in storm water discharges associated with industrial activity. Updates based on increased activity at the facility shall include a description of how the permittee intends to control any new sources of significant materials or respond to and prevent spills in accordance with the requirements of Source Identification; Preventive Measures and Source Controls, Non-Structural; and Structural Controls for Prevention and Treatment; above.
  - 3) The Department or authorized representative may notify the permittee at any time that the plan does not meet minimum requirements. Such notification shall identify why the plan does not meet minimum requirements. The permittee shall make the required changes to the plan within 30 days after such notification from the Department or authorized representative, and shall submit to the Department a written certification that the requested changes have been made.
- e. **Certified Storm Water Operator Update**  
If the certified operator has changed or an additional certified storm water operator is added, the permittee shall provide the name and certification number of the new operator to the Department. The new operator shall review and sign the plan.
- f. **Signature and Plan Review**
- 1) The plan shall be signed by the certified storm water operator and by either the permittee or an authorized representative in accordance with 40 CFR 122.22. The plan shall be retained on site of the facility that generates the storm water discharge.
  - 2) The permittee shall make plans, reports, log books, runoff quality data, and supporting documents available upon request to the Department or authorized representative.
- g. **Record Keeping**  
The permittee shall maintain records of all inspection and maintenance activities. Records shall also be kept describing incidents such as spills or other discharges that can affect the quality of storm water runoff. All such records shall be retained for three (3) years.



**PART I****Section A. Effluent Limitations And Monitoring Requirements**

## h. Water Quality Standards

At the time of discharge, there shall be no violation of the Water Quality Standards in the receiving waters as a result of this discharge. This requirement includes, but is not limited to, the following conditions:

1) In accordance with Rule 323.1050 of the Water Quality Standards, the receiving waters shall not have any of the following unnatural physical properties in quantities which are or may become injurious to any designated use: unnatural turbidity, color, oil film, floating solids, foams, settleable solids, suspended solids, or deposits as a result of this discharge.

2) Any unusual characteristics of the discharge (i.e., unnatural turbidity, color, oil film, floating solids, foams, settleable solids, suspended solids, or deposits) shall be reported within 24 hours to the Department followed with a written report within five (5) days detailing the findings of the investigation and the steps taken to correct the condition.

3) Any pollutant for which a level of control is specified to meet a Total Maximum Daily Load (TMDL) established by the Department shall be controlled at the facility so that its discharge is reduced by the amount specified in the waste load allocation of the TMDL. Any reduction achieved through implementation of the non-structural controls or structural controls in accordance with Preventive Measures and Source Controls, Non-Structural; and Structural Controls for Prevention and Treatment; above; shall count toward compliance with the TMDL.

## i. Prohibition of Non-storm Water Discharges

Discharges of material other than storm water shall be in compliance with an NPDES permit issued for the discharge. Storm water shall be defined to include the following non-storm water discharges provided pollution prevention controls for the non-storm water component are identified in the plan: discharges from fire hydrant flushing, potable water sources including water line flushing, fire system test water, irrigation drainage, lawn watering, routine building wash down which does not use detergents or other compounds, pavement wash water where spills or leaks of toxic or hazardous materials have not occurred (unless all spilled material have been removed) and where detergents are not used, air conditioning condensate, springs, uncontaminated groundwater, and foundation or footing drains where flows are not contaminated with process materials such as solvents. Discharges from fire fighting activities are authorized by this permit, but do not have to be identified in the plan.

## PART II

### Section A. Definitions

This list of definitions may include terms not applicable to this permit.

**Acute toxic unit** ( $TU_a$ ) means  $100/LC_{50}$  where the  $LC_{50}$  is determined from a whole effluent toxicity (WET) test which produces a result that is statistically or graphically estimated to be lethal to 50% of the test organisms.

**Bioaccumulative chemical of concern (BCC)** means a chemical which, upon entering the surface waters, by itself or as its toxic transformation product, accumulates in aquatic organisms by a human health bioaccumulation factor of more than 1000 after considering metabolism and other physiochemical properties that might enhance or inhibit bioaccumulation. The human health bioaccumulation factor shall be derived according to R 323.1057(5). Chemicals with half-lives of less than 8 weeks in the water column, sediment, and biota are not BCCs. The minimum bioaccumulation concentration factor (BAF) information needed to define an organic chemical as a BCC is either a field-measured BAF or a BAF derived using the biota-sediment accumulation factor (BSAF) methodology. The minimum BAF information needed to define an inorganic chemical as a BCC, including an organometal, is either a field-measured BAF or a laboratory-measured bioconcentration factor (BCF). The BCCs to which these rules apply are identified in Table 5 of R 323.1057 of the Water Quality Standards.

**Biosolids** are the solid, semisolid, or liquid residues generated during the treatment of sanitary sewage or domestic sewage in a treatment works. This includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes and a derivative of the removed scum or solids.

**Bulk biosolids** means biosolids that are not sold or given away in a bag or other container for application to a lawn or home garden.

**Chronic toxic unit** ( $TU_c$ ) means  $100/MATC$  or  $100/IC_{25}$ , where the maximum acceptable toxicant concentration (MATC) and  $IC_{25}$  are expressed as a percent effluent in the test medium.

**Class B Biosolids** refers to material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with the Part 24 Rules. Processes include aerobic digestion, composting, anaerobic digestion, lime stabilization and air drying.

**Daily concentration** is the sum of the concentrations of the individual samples of a parameter divided by the number of samples taken during any calendar day. If the parameter concentration in any sample is less than the quantification limit, regard that value as zero when calculating the daily concentration. The daily concentration will be used to determine compliance with any maximum and minimum daily concentration limitations (except for pH and dissolved oxygen). When required by the permit, report the maximum calculated daily concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the Discharge Monitoring Reports (DMRs).

For pH, report the maximum value of any individual sample taken during the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs and the minimum value of any individual sample taken during the month in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs. For dissolved oxygen, report the minimum concentration of any individual sample in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Daily loading** is the total discharge by weight of a parameter discharged during any calendar day. This value is calculated by multiplying the daily concentration by the total daily flow and by the appropriate conversion factor. The daily loading will be used to determine compliance with any maximum daily loading limitations. When required by the permit, report the maximum calculated daily loading for the month in the "MAXIMUM" column under "QUANTITY OR LOADING" on the DMRs.

**Department** means the Michigan Department of Environmental Quality.

**Detection Level** means the lowest concentration or amount of the target analyte that can be determined to be different from zero by a single measurement at a stated level of probability.

**EC<sub>50</sub>** means a statistically or graphically estimated concentration that is expected to cause 1 or more specified effects in 50% of a group of organisms under specified conditions.

## PART II

### Section A. Definitions

**Fecal coliform bacteria monthly** is the geometric mean of the samples collected in a calendar month (or 30 consecutive days). The calculated monthly value will be used to determine compliance with the maximum monthly fecal coliform bacteria limitations. When required by the permit, report the calculated monthly value in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Fecal coliform bacteria 7-day** is the geometric mean of the samples collected in any 7-day period. The calculated 7-day value will be used to determine compliance with the maximum 7-day fecal coliform bacteria limitations. When required by the permit, report the maximum calculated 7-day concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**Flow Proportioned sample** is a composite sample with the sample volume proportional to the effluent flow.

**Grab sample** is a single sample taken at neither a set time nor flow.

**IC<sub>25</sub>** means the toxicant concentration that would cause a 25% reduction in a nonquantal biological measurement for the test population.

**Interference** is a discharge which, alone or in conjunction with a discharge or discharges from other sources, both: 1) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and 2) therefore, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or, of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent state or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including state regulations contained in any state sludge management plan prepared pursuant to Subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act. [This definition does not apply to sample matrix interference.]

**Land Application** means spraying or spreading biosolids or a biosolids derivative onto the land surface, injecting below the land surface, or incorporating into the soil so that the biosolids or biosolids derivative can either condition the soil or fertilize crops or vegetation grown in the soil.

**LC<sub>50</sub>** means a statistically or graphically estimated concentration that is expected to be lethal to 50% of a group of organisms under specified conditions.

**Maximum acceptable toxicant concentration (MATC)** means the concentration obtained by calculating the geometric mean of the lower and upper chronic limits from a chronic test. A lower chronic limit is the highest tested concentration that did not cause the occurrence of a specific adverse effect. An upper chronic limit is the lowest tested concentration which did cause the occurrence of a specific adverse effect and above which all tested concentrations caused such an occurrence.

**MGD** means million gallons per day.

**Monthly frequency of analysis** refers to a calendar month. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**Monthly concentration** is the sum of the daily concentrations determined during a reporting month (or 30 consecutive days) divided by the number of daily concentrations determined. The calculated monthly concentration will be used to determine compliance with any maximum monthly concentration limitations. When required by the permit, report the calculated monthly concentration in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMRs.

For minimum percent removal requirements, the monthly influent concentration and the monthly effluent concentration shall be determined. The calculated monthly percent removal, which is equal to 100 times the quantity [1 minus the quantity (monthly effluent concentration divided by the monthly influent concentration)], shall be reported in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

## PART II

### Section A. Definitions

**Monthly loading** is the sum of the daily loadings of a parameter divided by the number of daily loadings determined in the reporting month (or 30 consecutive days). The calculated monthly loading will be used to determine compliance with any maximum monthly loading limitations. When required by the permit, report the calculated monthly loading in the "AVERAGE" column under "QUANTITY OR LOADING" on the DMRs.

**National Pretreatment Standards** are the regulations promulgated by or to be promulgated by the Federal Environmental Protection Agency pursuant to Section 307(b) and (c) of the Federal Act. The standards establish nationwide limits for specific industrial categories for discharge to a POTW.

**NOAEL** means the highest tested dose or concentration of a substance that results in no observed adverse effect in exposed test organisms where higher doses or concentrations result in an adverse effect.

**Noncontact Cooling Water** is water used for cooling which does not come into direct contact with any raw material, intermediate product, by-product, waste product or finished product.

**Nondomestic user** is any discharger to a POTW that discharges wastes other than or in addition to water-carried wastes from toilet, kitchen, laundry, bathing or other facilities used for household purposes.

**Partially treated sewage** is any sewage, sewage and storm water, or sewage and wastewater, from domestic or industrial sources that is treated to a level less than that required by the permittee's National Pollutant Discharge Elimination System permit, or that is not treated to national secondary treatment standards for wastewater, including discharges to surface waters from retention treatment facilities.

**Pretreatment** is reducing the amount of pollutants, eliminating pollutants, or altering the nature of pollutant properties to a less harmful state prior to discharge into a public sewer. The reduction or alteration can be by physical, chemical, or biological processes, process changes, or by other means. Dilution is not considered pretreatment unless expressly authorized by an applicable National Pretreatment Standard for a particular industrial category.

**POTW** is a publicly owned treatment works.

**Quantification level** means the measurement of the concentration of a contaminant obtained by using a specified laboratory procedure calculated at a specified concentration above the detection level. It is considered the lowest concentration at which a particular contaminant can be quantitatively measured using a specified laboratory procedure for monitoring of the contaminant.

**Quarterly frequency of analysis** refers to a three month period, defined as January through March, April through June, July through September, and October through December. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**Regional Administrator** is the Region 5 Administrator, U.S. EPA, located at R-19J, 77 W. Jackson Blvd., Chicago, Illinois 60604.

**Significant industrial user** is a nondomestic user that: 1) is subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N; or 2) discharges an average of 25,000 gallons per day or more of process wastewater to a POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the permittee as defined in 40 CFR 403.12(a) on the basis that the industrial user has a reasonable potential for adversely affecting the POTW's treatment plant operation or violating any pretreatment standard or requirement (in accordance with 40 CFR 403.8(f)(6)).

## PART II

### Section A. Definitions

**Significant Materials** Significant Materials means any material which could degrade or impair water quality, including but not limited to: raw materials; fuels; solvents, detergents, and plastic pellets; finished materials such as metallic products; hazardous substances designated under Section 101(14) of Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) (see 40 CFR 372.65); any chemical the facility is required to report pursuant to Section 313 of Emergency Planning and Community Right-to-Know Act (EPCRA); polluting materials as identified under the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code); Hazardous Wastes as defined in Part 111 of the Michigan Act; fertilizers; pesticides; and waste products such as ashes, slag, and sludge that have the potential to be released with storm water discharges.

**Tier I value** means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier I toxicity database.

**Tier II value** means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier II toxicity database.

**Toxicity Reduction Evaluation (TRE)** means a site-specific study conducted in a stepwise process designed to identify the causative agents of effluent toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in effluent toxicity.

**Water Quality Standards** means the Part 4 Water Quality Standards promulgated pursuant to Part 31 of Act No. 451 of the Public Acts of 1994, as amended, being Rules 323.1041 through 323.1117 of the Michigan Administrative Code.

**Weekly frequency of analysis** refers to a calendar week which begins on Sunday and ends on Saturday. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**Yearly frequency of analysis** refers to a calendar year beginning on January 1 and ending on December 31. When required by this permit, an analytical result, reading, value or observation must be reported for that period if a discharge occurs during that period.

**24-Hour Composite sample** is a flow proportioned composite sample consisting of hourly or more frequent portions that are taken over a 24-hour period.

**3-Portion Composite sample** is a sample consisting of three equal volume grab samples collected at equal intervals over an 8-hour period.

**7-day concentration** is the sum of the daily concentrations determined during any 7 consecutive days in a reporting month divided by the number of daily concentrations determined. The calculated 7-day concentration will be used to determine compliance with any maximum 7-day concentration limitations. When required by the permit, report the maximum calculated 7-day concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

**7-day loading** is the sum of the daily loadings of a parameter divided by the number of daily loadings determined during any 7 consecutive days in a reporting month. The calculated 7-day loading will be used to determine compliance with any maximum 7-day loading limitations. When required by the permit, report the maximum calculated 7-day loading for the month in the "MAXIMUM" column under "QUANTITY OR LOADING" on the DMRs.

## PART II

### Section B. Monitoring Procedures

#### 1. Representative Samples

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge.

#### 2. Test Procedures

Test procedures for the analysis of pollutants shall conform to regulations promulgated pursuant to Section 304(h) of the Federal Act (40 CFR Part 136 - Guidelines Establishing Test Procedures for the Analysis of Pollutants), unless specified otherwise in this permit. Requests to use test procedures not promulgated under see 40 CFR Part 136 for pollutant monitoring required by this permit shall be made in accordance with the Alternate Test Procedures regulations specified in 40 CFR 136.4. These requests shall be submitted to the Chief of the Permits Section, Water Bureau, Michigan Department of Environmental Quality, P.O. Box 30273, Lansing, Michigan, 48909-7773. The permittee may use such procedures upon approval.

The permittee shall periodically calibrate and perform maintenance procedures on all analytical instrumentation at intervals to ensure accuracy of measurements. The calibration and maintenance shall be performed as part of the permittee's laboratory Quality Control/Quality Assurance program.

#### 3. Instrumentation

The permittee shall periodically calibrate and perform maintenance procedures on all monitoring instrumentation at intervals to ensure accuracy of measurements.

#### 4. Recording Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information: 1) the exact place, date, and time of measurement or sampling; 2) the person(s) who performed the measurement or sample collection; 3) the dates the analyses were performed; 4) the person(s) who performed the analyses; 5) the analytical techniques or methods used; 6) the date of and person responsible for equipment calibration; and 7) the results of all required analyses.

#### 5. Records Retention

All records and information resulting from the monitoring activities required by this permit including all records of analyses performed and calibration and maintenance of instrumentation and recordings from continuous monitoring instrumentation shall be retained for a minimum of three (3) years, or longer if requested by the Regional Administrator or the Department.

## PART II

### Section C. Reporting Requirements

#### 1. Start-up Notification

If the permittee will not discharge during the first 60 days following the effective date of this permit, the permittee shall notify the Department within 14 days following the effective date of this permit, and then 60 days prior to the commencement of the discharge.

#### 2. Submittal Requirements for Self-Monitoring Data

Unless instructed on the effluent limits page to conduct "retained self-monitoring," the permittee shall submit self-monitoring data on the Environmental Protection Agency's Discharge Monitoring Report (DMR) forms (monthly summary information) and the Department's Daily Discharge Monitoring Report forms (daily information) to PCS-Data Entry, Water Bureau, Michigan Department of Environmental Quality, P.O. Box 30273, Lansing, Michigan, 48909-7773, for each calendar month of the authorized discharge period(s). The forms shall be postmarked no later than the **10<sup>th</sup> day of the month** following each month of the authorized discharge period(s). Electronic Environmental Discharge Monitoring Reporting (**e2-DMR**) System participants shall submit self-monitoring data for each month of the authorized discharge period(s). The electronic forms shall be submitted to the department no later than the **20th day of the month** following each month of the authorized discharge period(s).

Alternative Daily Discharge Monitoring Report formats may be used if they provide equivalent reporting details and are approved by the Department. For information on the electronic submittal of this information, contact the Department or visit the **e<sup>2</sup>-Reporting** website @ <https://secure1.state.mi.us/e2rs/> - click on "about e-DMR" to download the **Facility Participation Package**.

#### 3. Retained Self-Monitoring Requirements

If instructed on the effluent limits page to conduct retained self-monitoring, the permittee shall maintain a year-to-date log of retained self-monitoring results and, upon request, provide such log for inspection to the staff of the Water Bureau, Michigan Department of Environmental Quality (in the case of hospitals, nursing homes and extended care facilities, to the staff of the Division of Health Facilities and Services, Michigan Department of Consumer and Industry Services). Retained self-monitoring results are public information and shall be promptly provided to the public upon request.

The permittee shall certify, in writing, to the Department, on or before January 10th of each year, that: 1) all retained self-monitoring requirements have been complied with and a year-to-date log has been maintained; and 2) the application on which this permit is based still accurately describes the discharge.

#### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

Monitoring required pursuant to Part 41 of the Michigan Act or Rule 35 of the Mobile Home Park Commission Act (Act 96 of the Public Acts of 1987) for assurance of proper facility operation shall be submitted as required by the Department.

#### 5. Compliance Dates Notification

Within 14 days of every compliance date specified in this permit, the permittee shall submit a written notification to the Department indicating whether or not the particular requirement was accomplished. If the requirement was not accomplished, the notification shall include an explanation of the failure to accomplish the requirement, actions taken or planned by the permittee to correct the situation, and an estimate of when the requirement will be accomplished. If a written report is required to be submitted by a specified date and the permittee accomplishes this, a separate written notification is not required.

## PART II

### Section C. Reporting Requirements

#### 6. Noncompliance Notification

Compliance with all applicable requirements set forth in the Federal Act, Parts 31 and 41 of the Michigan Act, and related regulations and rules is required. All instances of noncompliance shall be reported as follows:

- a. 24-hour reporting - Any noncompliance which may endanger health or the environment (including maximum daily concentration discharge limitation exceedances) shall be reported, verbally, within 24 hours from the time the permittee becomes aware of the noncompliance. A written submission shall also be provided within five (5) days.
- b. other reporting - The permittee shall report, in writing, all other instances of noncompliance not described in a. above at the time monitoring reports are submitted; or, in the case of retained self-monitoring, within five (5) days from the time the permittee becomes aware of the noncompliance.

Written reporting shall include: 1) a description of the discharge and cause of noncompliance; and 2) the period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and the steps taken to reduce, eliminate and prevent recurrence of the noncomplying discharge.

#### 7. Spill Notification

The permittee shall immediately report any release of any polluting material which occurs to the surface waters or groundwaters of the state, unless the permittee has determined that the release is not in excess of the threshold reporting quantities specified in the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code), by calling the Department at the number indicated on the first page of this permit, or if the notice is provided after regular working hours call the Department's 24-hour Pollution Emergency Alerting System telephone number, 1-800-292-4706 (calls from out-of-state dial 1-517-373-7660).

Within ten (10) days of the release, the permittee shall submit to the Department a full written explanation as to the cause of the release, the discovery of the release, response (clean-up and/or recovery) measures taken, and preventative measures taken or a schedule for completion of measures to be taken to prevent reoccurrence of similar releases.

#### 8. Upset Noncompliance Notification

If a process "upset" (defined as an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee) has occurred, the permittee who wishes to establish the affirmative defense of upset, shall notify the Department by telephone within 24-hours of becoming aware of such conditions; and within five (5) days, provide in writing, the following information:

- a. that an upset occurred and that the permittee can identify the specific cause(s) of the upset;
- b. that the permitted wastewater treatment facility was, at the time, being properly operated; and
- c. that the permittee has specified and taken action on all responsible steps to minimize or correct any adverse impact in the environment resulting from noncompliance with this permit.

In addition, if a process "upset" has occurred that results in noncompliance with the effluent limitations for 1,4-dioxane or bromate contained in this permit, the permittee shall notify the City of Ann Arbor Water Plant by telephone at 734-994-2840 as soon as possible, but no later than 24 hours from the time the permittee becomes aware of the circumstances.

In any enforcement proceedings, the permittee, seeking to establish the occurrence of an upset, has the burden of proof.



**PART II****Section C. Reporting Requirements****9. Bypass Prohibition and Notification**

- a. Bypass Prohibition - Bypass or diversion of treatment facilities for groundwater remediations is prohibited. For discharges other than groundwater remediation, bypass is prohibited unless:
  - 1) bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - 2) there were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass; and
  - 3) the permittee submitted notices as required under 9.b. or 9.c. below.
- b. Notice of Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least ten (10) days before the date of the bypass, and provide information about the anticipated bypass as required by the Department. The Department may approve an anticipated bypass, after considering its adverse effects, if it will meet the three (3) conditions listed in 9.a. above.
- c. Notice of Unanticipated Bypass - The permittee shall submit notice to the Department of an unanticipated bypass by calling the Department at the number indicated on the first page of this permit (if the notice is provided after regular working hours, use the following number: 1-800-292-4706) and the City of Ann Arbor Water Plant by telephone at 734-994-2840 as soon as possible, but no later than 24 hours from the time the permittee becomes aware of the circumstances.
- d. Written Report of Bypass - A written submission shall be provided within five (5) working days of commencing any bypass to the Department, and at additional times as directed by the Department. The written submission shall contain a description of the bypass and its cause; the period of bypass, including exact dates and times, and if the bypass has not been corrected, the anticipated time it is expected to continue; steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass; and other information as required by the Department.
- e. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of 9.a., 9.b., 9.c., and 9.d., above. This provision does not relieve the permittee of any notification responsibilities under Part II.C.10. of this permit.
- f. Definitions
  - 1) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
  - 2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

## PART II

### Section C. Reporting Requirements

#### 10. Notification of Changes in Discharge

The permittee shall notify the Department, in writing, within 10 days of knowing, or having reason to believe, that any activity or change has occurred or will occur which would result in the discharge of: 1) detectable levels of chemicals on the current Michigan Critical Materials Register, priority pollutants or hazardous substances set forth in 40 CFR 122.21, Appendix D, or the Pollutants of Initial Focus in the Great Lakes Water Quality Initiative specified in 40 CFR 132.6, Table 6, which were not acknowledged in the application or listed in the application at less than detectable levels; 2) detectable levels of any other chemical not listed in the application or listed at less than detection, for which the application specifically requested information; or 3) any chemical at levels greater than five times the average level reported in the complete application (see the first page of this permit for the date(s) the complete application was submitted). Any other monitoring results obtained as a requirement of this permit shall be reported in accordance with the compliance schedules.

#### 11. Changes in Facility Operations

Any anticipated action or activity, including but not limited to facility expansion, production increases, or process modification, which will result in new or increased loadings of pollutants to the receiving waters must be reported to the Department by a) submission of an increased use request (application) and all information required under Rule 323.1098 (Antidegradation) of the Water Quality Standards or b) by notice if the following conditions are met: 1) the action or activity will not result in a change in the types of wastewater discharged or result in a greater quantity of wastewater than currently authorized by this permit; 2) the action or activity will not result in violations of the effluent limitations specified in this permit; 3) the action or activity is not prohibited by the requirements of Part II.C.12.; and 4) the action or activity will not require notification pursuant to Part II.C.10. Following such notice, the permit may be modified according to applicable laws and rules to specify and limit any pollutant not previously limited.

#### 12. Bioaccumulative Chemicals of Concern (BCC)

Consistent with the requirements of Rules 323.1098 and 323.1215 of the Michigan Administrative Code, the permittee is prohibited from undertaking any action that would result in a lowering of water quality from an increased loading of a BCC unless an increased use request and antidegradation demonstration have been submitted and approved by the Department.

#### 13. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharge emanates, the permittee shall submit to the Department 30 days prior to the actual transfer of ownership or control a written agreement between the current permittee and the new permittee containing: 1) the legal name and address of the new owner; 2) a specific date for the effective transfer of permit responsibility, coverage and liability; and 3) a certification of the continuity of or any changes in operations, wastewater discharge, or wastewater treatment.

If the new permittee is proposing changes in operations, wastewater discharge, or wastewater treatment, the Department may propose modification of this permit in accordance with applicable laws and rules.

## PART II

### Section D. Management Responsibilities

#### 1. Duty to Comply

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than or at a level in excess of that authorized shall constitute a violation of the permit.

It is the duty of the permittee to comply with all the terms and conditions of this permit. Any noncompliance with the Effluent Limitations, Special Conditions, or terms of this permit constitutes a violation of the Michigan Act and/or the Federal Act and constitutes grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of an application for permit renewal.

#### 2. Operator Certification

The permittee shall have the waste treatment facilities under direct supervision of an operator certified at the appropriate level for the facility certification by the Department, as required by Sections 3110 and 4104 of the Michigan Act. Permittees authorized to discharge storm water shall have the storm water treatment and/or control measures under direct supervision of a storm water operator certified by the Department, as required by Section 3110 of the Michigan Act.

#### 3. Facilities Operation

The permittee shall, at all times, properly operate and maintain all treatment or control facilities or systems installed or used by the permittee to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures.

#### 4. Power Failures

In order to maintain compliance with the effluent limitations of this permit and prevent unauthorized discharges, the permittee shall either:

- a. provide an alternative power source sufficient to operate facilities utilized by the permittee to maintain compliance with the effluent limitations and conditions of this permit; or
- b. upon the reduction, loss, or failure of one or more of the primary sources of power to facilities utilized by the permittee to maintain compliance with the effluent limitations and conditions of this permit, the permittee shall halt, reduce or otherwise control production and/or all discharge in order to maintain compliance with the effluent limitations and conditions of this permit.

#### 5. Adverse Impact

The permittee shall take all reasonable steps to minimize any adverse impact to the surface waters or groundwaters of the state resulting from noncompliance with any effluent limitation specified in this permit including, but not limited to, such accelerated or additional monitoring as necessary to determine the nature and impact of the discharge in noncompliance.

#### 6. Containment Facilities

The permittee shall provide facilities for containment of any accidental losses of polluting materials in accordance with the requirements of the Part 5 Rules (Rules 324.2001 through 324.2009 of the Michigan Administrative Code). For a Publicly Owned Treatment Work (POTW), these facilities shall be approved under Part 41 of the Michigan Act.

## PART II

### Section D. Management Responsibilities

#### 7. Waste Treatment Residues

Residuals (i.e. solids, sludges, biosolids, filter backwash, scrubber water, ash, grit or other pollutants) removed from or resulting from treatment or control of wastewaters, shall be disposed of in an environmentally compatible manner and according to applicable laws and rules. These laws may include, but are not limited to, the Michigan Act, Part 31 for protection of water resources, Part 55 for air pollution control, Part 111 for hazardous waste management, Part 115 for solid waste management, Part 121 for liquid industrial wastes, Part 301 for protection of inland lakes and streams, and Part 303 for wetlands protection. Such disposal shall not result in any unlawful pollution of the air, surface waters or groundwaters of the state.

#### 8. Treatment System Closure

In the event that discharges from a treatment system are planned to be eliminated, the permittee shall submit a closure plan to the Department for approval. The closure plan shall include characterization of any wastewater and residuals which will remain on-site after the discharges are eliminated, along with disposal methods, proposed schedule, and any other relevant information as required by the Department. Closure activities involving waste treatment residuals shall be consistent with Part II.D.7. of this permit.

The permittee shall implement the closure activities in accordance with the approved plan. Any wastewater or residual disposal inconsistent with the approved plan shall be considered a violation of this permit. After proper closure of the treatment system, this permit may be terminated.

#### 9. Right of Entry

The permittee shall allow the Department, any agent appointed by the Department or the Regional Administrator, upon the presentation of credentials:

- a. to enter upon the permittee's premises where an effluent source is located or in which any records are required to be kept under the terms and conditions of this permit; and
- b. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit; to inspect process facilities, treatment works, monitoring methods and equipment regulated or required under this permit; and to sample any discharge of pollutants.

#### 10. Availability of Reports

Except for data determined to be confidential under Section 308 of the Federal Act and Rule 2128 (Rule 323.2128 of the Michigan Administrative Code), all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department and the Regional Administrator. As required by the Federal Act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the Federal Act and Sections 3112, 3115, 4106 and 4110 of the Michigan Act.

## PART II

### Section E. Activities Not Authorized by This Permit

#### 1. Discharge to the Groundwaters

This permit does not authorize any discharge to the groundwaters. Such discharge may be authorized by a groundwater discharge permit issued pursuant to the Michigan Act.

#### 2. Facility Construction

This permit does not authorize or approve the construction or modification of any physical structures or facilities. Approval for such construction for a POTW must be by permit issued under Part 41 of the Michigan Act. Approval for such construction for a mobile home park, campground or marina shall be from the Water Bureau, Michigan Department of Environmental Quality. Approval for such construction for a hospital, nursing home or extended care facility shall be from the Division of Health Facilities and Services, Michigan Department of Consumer and Industry Services upon request.

#### 3. Civil and Criminal Liability

Except as provided in permit conditions on "Bypass" (Part II.C.9. pursuant to 40 CFR 122.41(m)), nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance, whether or not such noncompliance is due to factors beyond the permittee's control, such as accidents, equipment breakdowns, or labor disputes.

#### 4. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee may be subject under Section 311 of the Federal Act except as are exempted by federal regulations.

#### 5. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Federal Act.

#### 6. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize violation of any federal, state or local laws or regulations, nor does it obviate the necessity of obtaining such permits or approvals as may be required by law.