

STATE OF MICHIGAN
DEPARTMENT OF ENERGY, LABOR & ECONOMIC GROWTH
BUREAU OF CONSTRUCTION CODES
OKEMOS OFFICE BUILDING
P. O. BOX 30254
LANSING, MICHIGAN 48909

In the Matter of:

Mr. Rick Brockway, 450 W Marr Rd., Howell, Michigan 48855 for Crisp Point Lighthouse Society public restroom, 1944 CO Road 412, Paradise, Michigan 49768.

Petitioner,

vs

Appeal Document: CCC-PLBG-09-007

Bureau of Construction Codes,

Respondent.

MEMORANDUM OF TRANSMITTAL

The attached FINAL AGENCY ORDER of the MICHIGAN STATE PLUMBING BOARD is issued pursuant to 1969 PA 306, the Administrative Procedures Act, MCL 24.281, et seq.

A party may file an appeal in accordance with Chapter 6 of 1969 PA 306.

DECISION AND ORDER

The Michigan State Plumbing Board adopted the Findings of Fact, Conclusion and Recommendation of Staff in the matter of Mr. Rick Brockway, 450 W Marr Rd., Howell, Michigan 48855 for Crisp Point Lighthouse Society public restroom, 1944 CO Road 412, Paradise, Michigan 49768: APPEAL CCC-PLBG-09-007 at their meeting on June 9, 2009. The appeal request was to allow the use of restroom with chemical hand sanitation stations, and no drinking fountain for the area of Crisp Point Lighthouse, Public Restroom. It was explained that electricity is not available and that a well powered by a 12 volt photovoltaic system will be used. Further the water from this system will not be considered potable and may be used to flush the water closets.

FINDINGS AND CONCLUSIONS

Following a review and discussion, a **MOTION** was made by Board Member Howard and supported by Board Member Buday to approve the appeal request for Crisp Point Lighthouse, public restroom with the following conditions: Hand sanitation stations shall be supplied and signs shall be posted indicating that potable water is not available. A service sink and drinking fountain will not be required due to the water not being potable. The minimal piping in the structure shall be identified as non potable by the code. Further, a letter following a year of operation shall be provided providing an operational update. **MOTION CARRIED.**

Mr. Brockway has provided the requested documentation in accordance with the board's directive in his documentation dated June 10, 2010.

THEREFORE, the Board grants the appeal request.



Robert G. Konyndyk, Chief
Plumbing Division



Date