STATE OF MICHIGAN



DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY

LANSING



GRETCHEN WHITMER GOVERNOR

July 24, 2020

Mr. John M. Mooney, Acting Director, Air and Radiation Division United States Environmental Protection Agency Region 5 77 West Jackson Boulevard, Mail Code: A-18J Chicago, Illinois 60604-3507

Dear Mr. Mooney:

The Michigan Department of Environment, Great Lakes, and Energy (EGLE) is requesting that the United States Environmental Protection Agency (USEPA) make a Clean Data Determination (CDD) for the sulfur dioxide (SO₂) nonattainment area in a portion of Michigan's St. Clair County. EGLE has modeled the most recent three years of actual emissions from two power plant emission sources in the area with the results meeting the SO₂ National Ambient Air Quality Standard (NAAQS). In addition, DTE Energy (DTE) air monitoring for SO₂ over the most recent three years has recorded no violations of the NAAQS. The USEPA's Clean Data Policy allows a state with a nonattainment area meeting these criteria to request a CDD.

The enclosed document provides the technical data described above, including a report from DTE highlighting the impacts of their Belle River and St. Clair power plants, as well as large SO₂ sources located several miles away in Ontario, Canada.

If you have any questions regarding this CDD request, please contact Mr. Robert Irvine, Supervisor, SIP Development Unit, Air Quality Division, at 517-648-7367 or IrvineR@Michigan.gov; or you may contact me.

Sincerely,

Maryahn Dollhanty

Mary Ann Dolehanty, Director Air Quality Division 517-284-6773

Enclosure

cc: Dr. Eduardo Olaguer, EGLE Mr. Tom Shanley, EGLE Mr. Robert Irvine, EGLE Mr. Jim Haywood, EGLE

EGLE Clean Data Determination for St. Clair County, Michigan SO₂ Nonattainment Area



MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY

Air Quality Division Air Quality Evaluation Section P.O. Box 30260 Lansing, Michigan 48909-7760

www.Michigan.gov/Air

July 2020

TABLE OF CONTENTS

<u>Page</u>

ntroduction1
Clean Data Determination1
Modeling Methodology Using 2017-2019 Emissions
Modeling Results5
DTE SO ₂ Monitors6
Monitoring Data for 2017-20197
Monitoring Results7
Additional Monitoring Analysis8
Emission Sources at the Power Plants9
Emission Trends10

Attachment: 1-Hour SO₂ State Implementation Plan for St. Clair County Air Quality Monitoring Data Analysis

EGLE Clean Data Determination for St. Clair County, Michigan SO₂ Nonattainment Area

Introduction

On July 1, 2016, the United States Environmental Protection Agency (USEPA) confirmed that the air in southeastern St. Clair County, Michigan, exceeded the National Ambient Air Quality Standards (NAAQS) for sulfur dioxide (SO₂). The finding, based on the Michigan Department of Environment, Great Lakes, and Energy's (EGLE) computer modeling and recommendation, designated the southeastern portion of the county in nonattainment with the Clean Air Act's NAAQS for SO₂. EGLE's modeling of allowable (permitted) SO₂ emissions showed the emissions from two coal-fired power plants, DTE Energy (DTE) Belle River and DTE St. Clair, had the potential to cause SO₂ levels that exceed the 1-hour standard in the area.

The Clean Air Act required EGLE to develop a State Implementation Plan (SIP) by early 2018 to lower SO₂ allowable air pollution in the county. The plan must require SO₂ reductions in the area sufficient to attain the NAAQS within five years, which is mid-2021. EGLE has been working with DTE to develop the SIP but in doing so has exceeded the required submittal date. The USEPA has responded by issuing a Finding of Failure to Submit the SIP in autumn 2019. The first sanction for offsets takes effect 18 months later, in early 2021, if the SIP has not been submitted.

DTE recently announced that the St. Clair power plant will cease operating in mid-2022, which will significantly reduce SO₂ emission impacts in the area. However, the reduction is several months beyond the required compliance date for the area. To address this issue, as well as the pending sanction, EGLE is submitting for approval this Clean Data Determination. When approved, the requirement for a SIP submittal is suspended, stopping the sanction clock, and allowing time for the St. Clair power plant to shut down without additional consequences. This is further described below.

Clean Data Determination

The USEPA has issued policy memoranda and implementation rules outlining their interpretations of the provisions of the Clean Air Act that apply to nonattainment areas that have subsequently attained the NAAQS. This interpretation of the Clean Air Act is known as the Clean Data Policy and is explained by the USEPA, as follows:

In designated nonattainment areas where monitored data demonstrate that the National Ambient Air Quality Standards (NAAQS) have been achieved, EPA interprets certain requirements of the Clean Air Act as no longer applicable for so long as air quality continues to meet the standard. This interpretation of the Clean Air Act is known as the Clean Data Policy (CDP).

- Under the Clean Data Policy, EPA may issue a determination of attainment (known informally as a Clean Data Determination) after notice and comment rulemaking determining that a specific area is attaining the relevant standard.
- For such areas the requirement to submit to EPA those SIP elements related to attaining the NAAQS is suspended for so long as the area continues to attain the standard.
- These planning elements that are suspended include:
 - reasonable further progress (RFP) requirements;
 - attainment demonstrations;
 - Reasonably Available Control Measures (RACM);
 - contingency measures; and
 - other state planning requirements related to attainment of the NAAQS.

For a clean data finding for a nonattainment area, the USEPA requires three years of monitoring data showing attainment and such "additional information" as necessary for the USEPA to determine the area is in attainment. One path the USEPA allows as additional information is modeling of the most recent three years of actual emissions for the area that shows attainment of the NAAQS.


Modeling Methodology Using 2017-2019 Emissions

EGLE modeled SO₂ emissions for the years 2017-2019 to determine if the 1-hour NAAQS was met. Hourly continuous emissions monitoring system (CEMS) data for all Belle River and St. Clair stacks were provided to EGLE in AMS/EPA Regulatory Model (AERMOD) format by DTE. No other sources were explicitly modeled. Only two off-site sources were originally identified as having a significant contribution to the nonattainment area: Cargill Salt and E.B. Eddy. However, after further review, EGLE determined these facilities have decommissioned their coal-fired boilers and are no longer significant SO₂ emitters in the nonattainment area.

For meteorology, three years of meteorological data (2017-2019) from the Oakland County International Airport (i.e., Pontiac) was selected as the most representative for this analysis. The Pontiac meteorological data is collected by the National Weather Service and is in the prevailing upwind direction of the modeled SO₂ emission sources. One-minute data is also available from this first order collection station.

The modeling domain was the same as used in the original EGLE nonattainment designation recommendation to the USEPA. Receptor spacing was dense closest to the emission sources (50 m), then expands to 100 m and eventually 250 m on the outer region of the receptor grid for a total of 17,260 receptors, with non-ambient air receptors being excluded.

The topography in this area is generally flat with receptor terrain heights still included for modeling enhancement using AERMAP and 30 m NED GEOTIFF. The nonattainment receptor grid, with non-ambient receptors removed, is shown below.



Modeled Nonattainment Receptor Grid

Determination of a representative background concentration is important in calculating the overall modeled impact. The Port Huron monitor is located approximately 20 km north of the DTE power plants. This monitor serves as the downwind monitor for the sources in this modeling analysis and is useful in determining a representative background concentration.

To derive a regional background devoid of the sources explicitly modeled in the analysis or from international sources, EGLE developed an SO₂ concentration spreadsheet to exclude hourly SO₂ concentrations when the wind is blowing from sources explicitly included in the modeling as well as international sources. Using this methodology, the spreadsheet ignores all hours (and associated preceding hour) when the wind direction

is between 0 degrees and 205 degrees. This excludes all modeled sources to the south (DTE Belle River/St. Clair) and international sources to the east. Then, using the remaining hours, a variable background matrix was developed based on season-of-year and hour-of-day (a method established in USEPA guidance titled, "User's Guide for the AMS/EPA Regulatory Model – AERMOD"). The variable backgrounds by season-of-year and hour-of-day range from 1.3 ppb to 6.5 ppb.

The variable background table, as supplied to AERMOD, is provided below. There are 24 hourly values for each season in the table. Starting at the top left in the table, the value is the second highest recorded SO_2 value for all of the first hours of each 24-hour day throughout the season, so approximately 90 hours each season. The second value from the top left is the second highest recorded SO_2 value for all of the second hours of each 24-hour day throughout the season. Thus, the first row is hours 1-6, the second row is hours 7-12, etc. The 24 entries in the table for each season, therefore, are the second highest recorded SO_2 value for all of the days in the season.

** Winter						
BACKGRND SEASHR	2.3	2.3	2.0	2.1	2.1	2.1
BACKGRND SEASHR	2.0	2.5	2.7	2.5	2.8	2.3
BACKGRND SEASHR	2.3	2.1	3.5	2.2	2.0	1.9
BACKGRND SEASHR	2.0	2.0	2.0	2.0	2.0	2.1
** Spring						
BACKGRND SEASHR	1.9	1.9	1.6	1.5	1.4	1.4
BACKGRND SEASHR	1.8	1.9	2.5	2.5	1.9	2.0
BACKGRND SEASHR	2.0	1.7	3.2	1.5	2.4	1.8
BACKGRND SEASHR	1.5	1.4	2.0	2.1	2.1	1.5
** Summer						
BACKGRND SEASHR	1.7	1.3	2.2	1.9	1.5	1.7
BACKGRND SEASHR	1.7	2.2	3.2	3.3	2.4	1.9
BACKGRND SEASHR	1.9	5.6	5.8	6.5	2.7	2.0
BACKGRND SEASHR	2.1	2.8	2.6	2.5	1.9	1.7
** Fall						
BACKGRND SEASHR	2.2	1.6	2.6	2.4	2.3	2.2
BACKGRND SEASHR	2.3	2.4	2.4	3.6	3.1	2.7
BACKGRND SEASHR	2.8	2.8	2.7	4.1	3.6	5.0
BACKGRND SEASHR	3.2	2.9	2.2	2.2	2.3	2.3

2017-2019 Variable Background Season-of-Year and Hour-of-Day (ppb)

The spreadsheet used to determine this data has already been provided to the USEPA for review and validation along with the CEMS data provided by DTE, and therefore is not contained in this document.

Using the most recent version of AERMOD (v19191), 2017-2019 CEMS data, building downwash via BPIPPRM, corresponding one-minute meteorology data from the Oakland County International Airport, and the variable background, 99th percentile impacts were calculated for the full grid as well as monitor locations.

Modeling Results

The 99th percentile impacts, with background concentrations, at the Mills and Remer monitors, along with the overall maximum 99th percentile impact is as follows:

Emission Source	Hotspot (ppb)
DTE Mills Monitor	47.7
DTE Remer Monitor	52.7
Overall Maximum Impact	64.4

99th Percentile Modeling Impacts Using Actual Emissions (CEMS)

Graphical depiction of the monitor impacts and associated overall hotspot impact is as follows.

Casco 0</td

2017-2019 CEMS Data – Pontiac 1-Minute Meteorology (99th Pctl Impact w/Background)

As shown, the modeled overall impact is extremely close to the Remer monitor. This helps to validate that DTE did locate the monitors generally at points of maximum SO2 impact by the power plants.

More importantly, the results demonstrate that the area is attaining the 1-hour SO_2 NAAQS with the meteorology and emissions that actually occurred during the most recent 3-year timeframe, 2017-2019. Therefore, a key provision is met allowing EGLE to request the USEPA to make a Clean Data Determination for the St. Clair SO_2 nonattainment area.

DTE SO₂ Monitors

The figure below shows the location of the two DTE SO₂ monitor/meteorological stations with respect to the two DTE power plants. The power plant stacks are identified with blue boxes, and the monitor/meteorological stations are identified with red boxes. The power plant nearest the river is the St. Clair plant and the other one is the Belle River plant. The monitor/meteorological station to the northwest of the power plants is known as the Mills monitor. The monitor/meteorological station between the power plants is the Remer monitor. The monitors have been operating since November 2016.

Location of Two DTE SO₂ Monitor/Meteorological Stations and Power Plants



Monitoring Data for 2017-2019

EGLE has more than three years of monitoring data that has been collected at two DTE SO₂ monitors near the Belle River and St. Clair power plants. To date there have been no violations of the NAAQS recorded at the two monitors. EGLE consulted with DTE during their process of installing and operating the monitors and associated meteorological (met) stations. The monitors and met stations have been operational since November 2016 and continue to operate. The SO₂ data is collected and quality assured by a contractor using EGLE-approved methods. It is submitted monthly to EGLE for uploading to the USEPA AIRs system.

The ambient air monitors are located in areas of modeled maximum SO₂ concentrations that are attributable to the power plants. One of the monitors called the Mills monitor is located generally in a line with the stacks from the two plants to the northwest. Modeling by DTE established the best location for the Mills monitor, placing it in the area of maximum concentration of SO₂ emitted from the two power plants together. This occurs when winds are from the southeast. The other monitor is called the Remer monitor and is located north of the St. Clair plant. It was placed to pick up impacts from the St. Clair plant alone when the winds are from a southerly direction. Being located near the St. Clair River also allows the monitor to pick up emissions that come from large SO₂ sources located along the river in Canada.

Monitoring Results

The monitors have recorded no 4th high values above the 75 ppb NAAQS for the years 2017-2019. The highest 4th high was 65 ppb recorded at the Remer monitor. It should be noted that this value at the Remer monitor occurred when winds appear to transport SO₂ from Canada sources. A summary of the 4 highest SO₂ monitoring values for each monitor for the three-year time period is in the table below, with the maximum value in red and the 4th high value in green.

Date (2017)	Mills monitor (ppb)	Date (2017)	Remer monitor (ppb)
Sept 10	89	May 9	70
May 27	73	Mar 28	56
May 10	54	Nov 27	52
June 14	46	April 23	51
Date (2018)		Date (2018)	
May 21	79	May 12	164
June 19	71	April 30	87
April 22	52	May 28	70
Aug 31	50	June 8	65
Date (2019)		Date (2019)	
June 17	69	June 19	53
June 18	57	June 7	50
June 29	47	June 29	50
June 30	40	May 28	45

Highest Four Annual Impacts at the DTE Monitors in 2017-2019

To determine whether the NAAQS has been met at both SO_2 monitors, green values in the table are averaged for the 3 years (2017-2019) for each monitor. For the Mills monitor, the average of 46, 50, and 40 equals 45, which is well below the 75 ppb NAAQS. For the Remer monitor, the average of 51, 65, and 45 equals 54, also well below the NAAQS.

These results demonstrate that the area is attaining the 1-hour SO₂ NAAQS with the SO₂ values measured at the two air monitors during the most recent 3-year timeframe, 2017-2019. Therefore, a second provision is met allowing EGLE to request the USEPA make a Clean Data Determination for the St. Clair SO₂ nonattainment area.

Additional Monitoring Analysis

Attached to this report is a document titled, "1-Hour SO₂ SIP for St. Clair County Air Quality Monitoring Data Analysis July 2, 2020." The report was compiled by DTE to analyze impacts at SO₂ monitors in the area when winds come from a variety of directions. The report clearly shows, via SO₂ monitoring and wind data collected at the monitoring sites, the likely sources of SO₂ emissions when air monitors in and near the St. Clair SO₂ nonattainment area record higher SO₂ levels. The data analysis DTE provides in the report gives a detailed picture of the operations of the two power plants, their likely impacts on SO₂ monitoring data, as well as impacts by large SO₂ sources in the area of Sarnia, Ontario.

The table below was generated from data in the DTE report. It is like the previous table, but in this case it shows the four highest annual monitored values for each monitor **when the power plants** were culpable and excludes other large SO₂ sources in Canada that are generally north of the DTE power plants.

Date (2017)	Mills monitor (ppb)	Date (2017)	Remer monitor (ppb)
Sept 10	89	May 9	70
May 10	54	Nov 27	52
June 14	46	Aug 10	23
Sept 11	42	July 21	20
Date (2018)		Date (2018)	
May 21	79	May 13	45
July 3	49	April 30	25
April 29	42	July 19	12
April 23	34	June 12	11
Date (2019)		Date (2019)	
May 22	33	Jan 11	24
Oct 5	30	April 21	20
Feb 23	23	April 6	10
Feb 10	23	July 4	10

Highest Four Annual Impacts *from Belle River/St. Clair* Recorded at the DTE Monitors in 2017- 2019

The values in the table are lower because many of the higher values recorded at the monitors appear to reflect emissions from large sources in Canada. Thus, these large SO_2 sources in Sarnia, Ontario have some culpability for SO_2 impacts in addition to the power plants. EGLE has no jurisdiction over these international sources but continues dialogue with Canadian officials regarding the sources. Canadian officials expect SO_2 reductions to be occurring at these facilities as new regulations are adopted over the next several years.

Emission Sources at the Power Plants

DTE Belle River Power Plant

The Belle River power plant operates under Renewable Operating Permit (ROP) No. MI-ROP-B2796-2015b. The Belle River power plant has two electric generating units, each with a maximum gross design generating output of 697 megawatt (MW). Pulverized coal is the primary fuel for both boilers. The Belle River Peaking Units consist of five 2.5 MW each diesel electric generators and three 82.4 MW each combustion turbine electric generators. The DTE East China Peaking Units consist of four combustion turbine electric generators each 82.4 MW.

Unit No.	3 hr. Limit	Hourly Rate, lbs/hour
1	1.2	8177
2	1.2	8177

Permitted 3-hr. SO₂ Limit for the Belle River Power Plant (2016)

DTE St. Clair Power Plant

The St. Clair power plant operates under ROP No. MI-ROP-B2796-2015b. The St. Clair power plant has six electric generating units with a total maximum gross design generating output of 1,375 MW. Pulverized coal is the primary fuel for all boilers. The boilers can also be fired with fuel oil no. 6, fuel oil no. 2, off-specification recycled used oil, and biodiesel (Boiler 7 only). The St. Clair Peaking Units consist of a 23 MW combustion turbine electric generator and two 2.75 MW (each) diesel electric generators.

Permitted Monthly SO₂ Limit for the St. Clair Power Plant (2016)

Unit No.	Monthly Limit, lbs/MMBtu	Hourly Rate, lbs/hr.
1-4	1.67	9,420
6	1.67	5,186
7	1.67	7,841

Emission Trends

The newer Belle River plant was designed to burn primarily lower sulfur western coal, resulting in lower emissions than the St. Clair plant which burns a mix of eastern coal along with some western coal. SO₂ emissions from the two power plants combined for the past several years are listed in the table below. The emission trend over this period of time is generally downward, which is a result of more lower sulfur coal use at St. Clair and operational variations at both plants. The following explains the large decrease in emissions from 2018 to 2019:

The combined SO₂ emissions from the main units at both plants were:

- 41,384 tons in 2018
- 30,753 tons in 2019

The main differences between 2018 and 2019 were:

- St. Clair Unit 1 was retired in early 2019
 - o 2018 SO₂ emissions were 2,433 tons versus 125 tons in 2019
- St. Clair Units 2 and 3 operated less in 2019 than in 2018 resulting in:
 - $_{\odot}$ 2018 Unit 2 and Unit 3 combined SO_2 emissions of 4,617 tons dropping to 3,858 tons in 2019

- St. Clair Units 6 and 7 operated less in 2019 than in 2018 resulting in:
 - 2018 Unit 6 and 7 combined SO₂ emissions of 10,309 tons decreasing to 9,275 tons in 2019
- Belle River Unit 1 was in an outage for 7 months in 2019 leading to a reduction of 6,646 tons of SO₂ emissions from 2018 to 2019
- Belle River Unit 2 had nearly identical SO₂ emissions for both 2018 and 2019

The biggest difference was the extended outage at Belle River Power Plant's Unit No. 1.

SO ₂ Emissions	Power Plant	Total lbs/year	Total tons/year
Year			
2010	Belle River/St. Clair	120,945,830	60,472
2011	Belle River/St. Clair	120,986,625	60,493
2012	Belle River/St. Clair	106,155,927	53,077
2013	Belle River/St. Clair	109,796,891	54,898
2014	Belle River/St. Clair	103,840,749	51,920
2015	Belle River/St. Clair	96,738,636	48,369
2016	Belle River/St. Clair	74,329,800	37,164
2017	Belle River/St. Clair	73,837,452	36,918
2018	Belle River/St. Clair	82,767,746	41,384
2019*	Belle River/St. Clair	61,506,000	30,753

*Emissions for 2019 are not yet validated.

SO₂ emissions will change substantially with changes planned to occur at the two plants. Allowable emissions at Belle River will be substantially reduced shortly when a federal consent order takes effect. St. Clair is scheduled to shut down permanently in mid-2022. Power generation from a new natural gas fired power plant will begin in 2021, replacing generation lost when the St. Clair plant closes. These changes will allow EGLE modeling to show attainment of the NAAQS using *allowable* emissions at Belle River after St. Clair shuts down. At that time, the Air Quality Division will prepare and submit a redesignation plan to the USEPA requesting redesignation of the nonattainment area to attainment of the 1-hour SO₂ NAAQS.

ATTACHMENT 1-Hour SO₂ State Implementation Plan for St. Clair County Air Quality Monitoring Data Analysis July 2, 2020

DTE Energy's SO₂ SIP Perspective

DTE Energy believes that the sulfur dioxide (SO₂) State Implementation Plan (SIP) for St. Clair County needs to utilize the recent SO₂ and meteorological data from its two new monitoring sites (Belle River Mills Compressor Station & Belle River PP [Remer Road]) as much as possible in developing reasonable emission limits for both of its power plants in the county. These monitors were located as close as practical to receptors where the SO₂ National Ambient Air Quality Standards (NAAQS) designation modeling predicted the highest design value impacts using 2012-2014 actual emission data from DTE Energy's two St. Clair County power plants.

DTE Energy has received a permit to install (PTI) for a large natural gas-combined cycle power plant on the eastern acreage of Belle River Power Plant to replace the electrical generation no longer available when St. Clair Power Plant's coal-fired units are scheduled to be retired in 2022. This new generation will ensure that adequate base-loaded generation will be available to meet projected electrical demands moving ahead into the future.

There are three critical concepts that need to be considered:

- Acceptance of a weight-of-evidence demonstration that incorporates data from the new, and existing, SO₂ monitoring sites to properly account for real-world air pollutant transport and dispersion, instead of total reliance on impact predictions by the AERMOD Model.
- 2. Analyzing nearby SO₂ and meteorological data to determine whether DTE Energy, or large Canadian, SO₂ sources are most culpable on days when high 1-hour SO₂ is observed at the three St. Clair County monitoring sites. Days when the DTE power plants are primarily culpable will be compared against AERMOD runs for 2017 to determine whether the magnitude and frequency of high predicted SO₂ matches observed concentrations.
- 3. Because the 2010 SO₂ NAAQS is a probabilistic standard where high SO₂ only occurs from the two power plants when:
 - a. Most of the seven coal-fired units are operating near full load.
 - b. Each operating unit is burning its highest allowed sulfur coal.
 - c. Meteorological conditions are favorable (critical wind directions plus adequate vertical turbulence) for the units' SO₂ emissions to fumigate to ground-level close into the plant over US land or water (Canada's SO₂ standard is 250 ppb rather than 75 ppb).

d. Air quality modeling analyses for SIP development assume a) and b) are occurring every hour of the meteorological data base modeled. This is extremely unrealistic and DTE Energy proposes to use the monitors to provide additional verification whether the NAAQS is maintained in St. Clair County with current plant operating conditions.

An additional complicating factor was a fire that broke out at St. Clair Power Plant in August 2016, three months before the new DTE monitoring network began collecting data. Some operation at the plant restarted within two months of the fire. Unit 6 and Unit 7 didn't restart until 2017. Unit 4 has not operated since the fire. Unit 6 and 7 are the two largest units at St. Clair Power Plant and tend to burn more bituminous coal than Units 1-3. This reduced the likelihood of all five main St. Clair Power Plant units being operated at full load, simultaneously, even more than before the fire. Belle River Power Plant's operation was not directly impacted by the nearby plant's fire. Table 1 illustrates operation of these two plants leading into the fire and moving into the recovery period.

Large Canadian Sources In Lambton County & Proximity to Port Huron Monitor

Figure 1 illustrates the large SO_2 point sources and air quality monitors in Lambton County, the large SO_2 sources in St. Clair County (in 2014), the three St. Clair County monitoring sites and the 2014 annual SO_2 emissions from these sources.

Large Canadian and United States SO₂ source 2014 emissions, their distance and direction from the Port Huron monitoring site are listed in Table 2. Most of the SO₂ emissions came from DTE Energy's two power plants. However, the Canadian sources emitted 30 percent of the combined point sources' total along the St. Clair River. These Canadian SO₂ sources have much shorter stacks than DTE's power plants, and can have higher SO₂ impacts at the St. Clair County monitoring sites, as well as at the Canadian monitors. Table 3 provides SO₂ source distance and upwind direction from all three St. Clair County SO₂ monitoring sites. I assume that a source impacts a downwind monitor if it is within 20 degrees of the direct upwind wind direction. A range of wind directions are listed for the larger of the Canadian SO₂ sources in Lambton County that may impact at least one of the St. Clair County monitors.

Air Monitoring Summary from December 2016 – December 2019

Overall, the maximum monthly 1-hour SO_2 concentrations are observed during the warmer months (Late March – September), with a few exceptions. Table 4 lists the maximum hourly SO_2 concentration during this 37-month period.

DTE Energy Monitoring Site Analysis (Belle River Mills & Remer Road)

- 1. For each monitoring site, identify which large SO₂ source(s) is likely most culpable for the observed high 1-hour SO₂ impact assuming:
 - a. High SO₂ impacts from the DTE Energy power plants will most likely occur during the warm months (April – September), and be observed near the middle of the day (9AM-5PM) when the sun is highest in the sky.
 - b. High impacts from large Canadian sources are observed throughout the year and can occur at nighttime, due to their shorter stack heights than DTE Energy's power plants.
 - c. It is not always the large SO₂ source directly upwind of a specific monitoring site, during the hour, when the maximum daily SO₂ concentration is observed that is always most culpable. During light wind periods and especially in the late spring through early summer, recirculating flows due to lake breeze effects lead to SO₂ impacts from other upwind sources dominating the total SO₂ impact.
- Modeled SO₂ impacts using AERMOD need to be compared against high monitored 1hour SO₂ concentrations when DTE Energy SO₂ sources are clearly the most culpable source(s).
- 3. Focus the SO₂ monitoring data analysis on:
 - a. Days when the maximum daily observed 1-hour SO₂ concentration is above the 75 ppb NAAQS
- 4. Review the days with the top 10 measured maximum daily 1-hour SO₂ concentrations for each calendar year (2017 through 2019), to provide additional statistical power to the analysis.

DTE Energy Monitoring Site Data (December 2016 – December 2019)

All maximum daily 1-hour SO₂ concentrations 10 parts per billion (ppb), or higher, are listed for both DTE Energy monitoring sites for the last month and a few days from 2016, and the 2017 calendar year in Table 5. Table 6 lists the same SO₂ and meteorological data for the January through December 2018 period, and Table 7 lists data for 2019. The maximum monthly value is listed for months where the highest SO₂ concentration was less than 10 ppb. The color coding in the table coincides with which source(s) are upwind of the monitor during the hour when the maximum hourly concentration was observed. The concentration and wind direction have the following background color based on which sources are upwind during the maximum SO₂ hour:

- Yellow Canadian SO₂ source(s)
- Blue DTE Power Plant(s)
- Orange Maximum for the entire period in the table
- White No specific large SO₂ source is upwind

Table 8 lists the highest (Top 10) daily maximum 1-hour average SO₂ concentrations measured during calendar years 2017, 2018 and 2019 at all three St. Clair County monitors, plus the River Bend monitor in Lambton County, Ontario (Canada). Because the River Bend monitoring site is between the DTE Energy power plants and the Port Huron monitor, it provides additional clarification regarding which source(s) are contributing to high SO₂ at each monitor. Many of the highest 1-hour SO₂ concentrations were observed with at least one DTE power plant upwind of the Belle River Mills Monitor. There were only a few cases where a DTE power plant was

upwind of the Remer Road Monitor during the maximum SO_2 concentration hour. Both sites had Canadian SO_2 sources upwind when the top 10 SO_2 levels were observed, especially for the Remer Road site. Canadian SO_2 sources were likely most culpable for nearly all of the top 10 1-hour SO_2 days at all four monitors in 2019.

MDEQ-AQD Port Huron Monitoring Site Data (December 2016 – December 2018)

High measured SO₂ day data are listed for the Port Huron monitor from November 2016 through December 2017 in Table 9. Table 10 lists identical data for the January through December 2018 period at this Michigan EGLE (formerly MDEQ) monitor. Table 11 provides these high SO₂ concentration days for 2019. The same color coding scheme is used to identify which large SO₂ source(s) was upwind during the maximum 1-hour SO₂ concentration hour.

There are quite a few days where the maximum hourly SO₂ concentration exceeded 10 ppb with the DTE Energy power plants upwind of this monitor. However, most of these are in the lower range of the listed SO₂ concentrations. Days when the highest SO₂ concentrations are measured nearly always had large Canadian sources upwind during the hour when the highest SO₂ concentration was observed. Table 8, which lists the top 10 highest 1-hour SO₂ days for 2017 through 2019 clearly identifies Canadian SO₂ sources as being most culpable for these high measured concentrations. In fact, most of the top 10 1-hour SO₂ days occur when the Cabot Canada Ltd. Carbon Black Plant is directly upwind of the Port Huron monitor (direct upwind direction = 111 degrees). The only high SO₂ concentration day where the DTE Energy power plants are upwind of the Port Huron monitor is the 9th highest impact day in 2018 (July 1, 2018) when SO₂ peaked at 66 ppb.

A more detailed source culpability analysis is not necessary with the dominance of this Canadian source on maximum 1-hour SO₂ concentrations at the Port Huron monitoring site.

DTE Energy SO₂ Source Culpability Analysis for DTE Energy's Monitoring Sites

A more detailed analysis was performed on each of the top 10 days with the highest measured 1-hour SO₂ concentrations to determine whether DTE Energy's two power plants were the primary source(s) impacting the monitor during the hour with the highest SO₂ concentration. Tables 12A (Belle River Mills Site) and 12B (Remer Road Site) display the critical criteria that were reviewed to ascertain which source(s) dominated, or shared, impacts during the critical maximum SO₂ hour for 2017 and 2018. Table 12C shows the same data for both DTE Energy monitors for 2019. The five key criteria for a DTE Energy power plant impacting a nearby monitor include:

- 1. Warm season month (April September).
- 2. Midday hour when there is more vertical turbulence (9AM-5PM).
- 3. Low (< 10 ppb) SO₂ concentrations prior to, or during, the hour the maximum SO₂ concentration is measured *at the other DTE Energy monitor.*
- *4.* Low (< 10 ppb) SO₂ concentrations prior to, or during, the hour the maximum SO₂ concentration is measured at the DTE Energy monitor *at the Canadian River Bend Monitor.*
- 5. One or both DTE Energy plants is upwind (\pm 20 degrees of the direct upwind direction) of the monitor during the hour when the maximum SO₂ concentration is measured.

Eight of the 20 days at the Belle River Mills site have most of their SO₂ impact from DTE Energy

power plants for 2017 and 2018. Of these eight, four have some SO_2 coming from the nearby Canadian SO_2 sources. Also, on May 21, 2018, the exceedance (79 ppb) of the SO_2 NAAQS was primarily from DTE Energy's power plants.

At the Belle River Power Plant (Remer Road) site, DTE Energy's power plants are the most culpable SO₂ source(s) for only two of the 20 days listed for 2017 and 2018. There is some SO₂ impact from Canadian SO₂ sources on both days when it appears St. Clair Power Plant is impacting this monitor. When comparing monitored SO₂ levels against modeled impacts on days where there is some DTE Energy power plant SO₂ impact, it is important to account for the Canadian source contribution to the high SO₂ concentration measurement. The 2019 update to this data set, in Table 12C, shows an even greater dominance of Canadian SO₂ source(s) being upwind of these monitors when high 1-hour SO₂ was observed (19 out of 20 top 10 days).

Additional SO₂ and wind direction and wind speed data are provided in Tables 13A, 13B and 13C to illustrate days when:

- 1. DTE Energy SO₂ sources are clearly culpable
- 2. Canadian sources are clearly the dominant SO₂ source(s)
- 3. DTE Energy and Canadian SO₂ sources both contribute to the high observed SO₂ level


Bel	le River	& St. Claiı	PP - Ope	rating D	ays (Janı	uary 201	5 - Dece	mber 20	17)
		Belle River	Belle River	St. Clair	St. Clai				
Month	Year	Unit 1	Unit 2	Unit 1	Unit 2	Unit 3	Unit 4	Unit 6	Unit 7
Jan	2015	28	16	31	31	0	14	25	17
Feb	2015	28	0	28	28	0	21	28	23
Mar	2015	24	0	23	29	20	31	13	31
Apr	2015	24	26	30	13	30	30	0	27
May	2015	29	31	14	29	31	31	0	0
June	2015	20	30	30	17	30	17	3	16
July	2015	31	31	31	21	31	31	23	26
Aug	2015	25	22	31	31	10	31	23	25
Sep	2015	30	30	11	30	30	30	30	30
Oct	2015	19	31	14	23	31	31	24	31
Nov	2015	30	21	30	0	23	21	18	30
Dec	2015	31	26	31	0	31	31	31	3
			_	-			-		
Jan	2016	31	26	31	0	31	31	31	21
Feb	2016	19	28	22	26	15	25	4	29
Mar	2016	0	31	31	31	24	18	31	31
Apr	2016	0	4	30	30	30	30	7	7
May	2016	4	22	31	31	31	31	28	10
June	2016	29	30	24	30	25	10	15	30
July	2016	27	31	30	22	31	31	19	26
Aug	2016	31	22	5	11	9	11	11	11
Sep	2016	30	30	4	0	0	0	0	0
Oct	2016	16	31	31	4	7	0	0	0
Nov	2016	30	25	30	30	10	0	0	0
Dec	2016	31	25	19	25	19	0	0	0
	2010			10					
Jan	2017	21	31	31	31	25	0	7	0
Feb	2017	28	28	28	28	25	0	14	0
Mar	2017	31	25	31	31	31	0	13	0
Apr	2017	30	27	30	22	30	0	29	0
May	2017	22	31	31	14	31	0	19	0
June	2017	28	20	4	30	30	0	0	0
July	2017	31	31	27	31	31	0	18	0
Aug	2017	21	31	31	31	31	0	31	1
Sept	2017	27	9	30	30	27	0	20	16
Oct	2017	31	0	31	7	29	0	24	11
Nov	2017	28	0	30	28	12	0	27	22
Dec	2017	NA	4	31	14	31	0	31	0

Table 1

Table 1	(Continued))
---------	-------------	---

		Belle River	Belle River	St. Clair	St. Clair	St. Clair	St. Clair	St. Clair	St. Clair
Month	Year	Unit 1	Unit 2	Unit 1	Unit 2	Unit 3	Unit 4	Unit 6	Unit 7
Jan	2018	31	17	31	31	31	0	26	10
Feb	2018	28	24	17	28	19	0	4	0
Mar	2018	16	31	16	19	20	0	6	12
Apr	2018	22	26	30	21	30	0	29	18
May	2018	13	22	31	19	17	0	22	25
June	2018	15	29	30	20	25	0	25	27
July	2018	31	30	31	31	31	0	25	31
Aug	2018	31	31	31	31	31	0	31	27
Sept	2018	26	12	25	30	28	0	7	29
Oct	2018	10	31	31	5	31	0	0	22
Nov	2018	30	25	30	22	30	0	0	30
Dec	2018	25	23	31	31	31	0	10	31
Jan	2019	29	20	23	31	31	0	25	16
Feb	2019	6	28	2	27	20	0	26	7
Mar	2019	0	31	0	31	20	0	1	31
Apr	2019	0	24	0	27	30	0	15	30
May	2019	0	24	0	23	17	0	17	27
June	2019	0	27	0	29	30	0	30	21
July	2019	23	31	0	31	22	0	24	29
Aug	2019	29	27	0	7	28	0	31	31
Sept	2019	30	30	0	13	30	0	30	27
Oct	2019	20	22	0	8	31	0	9	31
Nov	2019	0	30	0	27	29	0	14	30
Dec	2019	0	31	0	20	14	0	25	31
otes: 1)	Green - O	perated eve	ry day in the	month, Re	ed - Did no	t operate e	entire mon	th	
2)	Key Dates	: Fire at St.	Clair PP - Au	g 11 2016, S	02 Netwo	rk Start Da	te - Nov 23	2016	
3)	Allowable	e SO2 Emissi	on Rates (Ibs	/hr):					
	Belle Riv	er Units 1 &	2: 8,177						
	St. Clair U	Jnits 1-4: 2,3	55						
	St. Clair U	Jnit 6: 5,187							
	St. Clair I	Jnit 7: 7,841							

Figure	1
--------	---



Large SO ₂ Sources in V	-				
(2014 Actual Emis	sions & Pro	oximity to th	e Monitor)		
		2014	MDEQ Port H	luron Monitor	-
		Annual SO ₂	Source Distance	Source Upwind	
		Emissions	to Monitor	Wind Direction	
Large SO ₂ Point Source	Country	(tons/year)	(km)	(degrees)	
mperial Oil-Sarnia Refinery & Chemical Plant	Canada	10,462	3.29	75	
Cabot Canada Ltd Sarnia Plant	Canada	5,400	3.27	111	
Shell - Sarnia Manufacturing Centre	Canada	3,546	5.65	182	
NOVA Chemicals - Corunna Site	Canada	2,102	8.89	155	
Suncor - Sarnia Refinery	Canada	691	2.70	160	
Clean Harbors - Corunna Site	Canada	338	15.1	125	
Suncor - St. Clair Ethanol Plant	Canada	68	11.1	167	
Smaller Canadian SO ₂ Sources	Canada	117	NA	NA	
St. Clair Power Plant	USA	27,454	21.3	185	
Belle River Power Plant	USA	24,466	20.0	191	
EB Eddy Paper	USA	1,379	3.64	17	
Cargill Salt Company	USA	254	15.2	191	
Canadian & US SO₂ Emissions	Both	76,277			
Canadian SO ₂ Emissions	Canada	22,724			
US SO ₂ Emissions	USA	53,553			
Notes:					
 The key SO₂ source upwind of nearly all high 	hest 1-hour co	oncentrations a	at the Port Huron m	onitor is Cabot Can	nada
2. Two other large SO ₂ sources have similar di	rectly upwind	directions as I	Belle River & St. Cla	air Power Plants:	
A. Shell - Sarnia Manufacturing Centre					

3. In 2014, US SO₂ sources emitted 70 % of the total emissions from both sides of the border along the St. Clair River

B. Cargill Salt Company

Table 3

St. Clair County Source / Monitor Orientation

	Bell	e River PP	St. C	lair PP	Large Can	adian SO ₂ Sources	
	Upwind	Upwind	Upwind	Upwind	Upwind	Upwind	
Monitoring	Distance	Direction	Distance	Direction	Distance	Direction	
Site	(km)	(deg)	(km)	(deg)	(km)	(deg)	
Belle River Mills	3.01	114	5.31	122	14.2-21.6	25 - 44	
Belle River PP (Remer)	1.52	279	1.32	167	13.3-21.4	8 - 27	
MDEQ Port Huron	20.0	191	21.3	185	2.2 -15	75 - 160	Cabot Canada Ltd 3.3 km & 111°

Maxin	num Mont	hly SO2 Concentrat	ions for Monitors in	St. Clair & Lambto	n Counties
F	rom Start	up of DTE Energy's	Monitors (Nov. 23.	2016) Through Dec	. 2019
		St. Clair	County SO2 Monitor	ring Site	Canadian SO2
					Monitoring Site
		Belle River Mills	Belle River PP	Port Huron	River Bend
		Maximum Hourly	Maximum Hourly	Maximum Hourly	Maximum Hourly
		SO2 Concentration	SO2 Concentration	SO2 Concentration	SO2 Concentration
Month	Year	(ppb)	(ppb)	(ppb)	(ppb)
December	2016	3	4	46	NA
January	2017	9	9	40	60
February	2017	45	5	54	27
March	2017	73	30	51	45
April	2017	38	51	66	77
Мау	2017	54	70	43	39
June	2017	46	22	51	36
July	2017	21	23	34	44
August	2017	33	23	58	23
September	2017	89	29	49	59
October	2017	6	13	55	40
November	2017	15	52	28	22
December	2017	10	11	76	15
January	2018	28	5	16	28
February	2018	25	15	38	46
March	2018	38	87	84	43
April	2018	52	50	54	75
Мау	2018	79	164	72	230
June	2018	71	65	89	101
July	2018	49	53	66	56
August	2018	50	58	64	37
September	2018	46	42	46	106
October	2018	10	9	82	37
November	2018	13	4	70	28
December	2018	18	4	109	23
January	2019	20	24	45	39
February	2019	23	10	60	20
March	2019	31	28	53	45
April	2019	24	25	63	48
Мау	2019	34	45	55	82
June	2019	69	53	44	114
July	2019	37	34	30	90
August	2019	23	26	48	100
September	2019	23	28	64	36
October	2019	30	45	50	28
November	2019	17	6	73	23
December	2019	37	14	71	31

			ontoril	19 01103 - 1		Nov. 23 2016) T	mough	200.201	•
		Belle Rive Maximum Hourly	er Mills M	onitoring Sit Hour	e Wind	Belle River PP (Maximum Hourly	Remer Ro	ad) Monitori Hour	n <u>g Site</u> Wind
		SO2 Concentration		Beginning	Direction	SO2 Concentration		Beginning	Directio
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
November	2016	5	30-Nov	1500	204	4	30-Nov	1500	197
December	2016	<u>3</u> 9	4-Dec	2000	113	4 9	16-Dec	1100	210
January February	2017 2017	45	23-Jan 19-Feb	1800 1700	13 39	5	12-Jan 19-Feb	1100 1600	9 337
February	2017	29	23-Feb	1600	31	5	13-1 65	1000	557
March	2017	10	4-Mar	1700	89	30	29-Mar	1500	6
March	2017	13	24-Mar	1900	33	24	28-Mar	0200	1
March	2017	16	25-Mar	0300	16	21	24-Mar	2000	358
March	2017	73 (2nd high)	27-Mar	2200	33				
March	2017	22	29-Mar	1000	53	40	44 Ame	2000	40
April April	2017 2017	10 25	1-Apr 3-Apr	1700 1000	75	10 18	14-Apr 17-Apr	2000 1000	12 358
April	2017	23	5-Apr	1500	34	25	19-Apr	1700	360
April	2017	19	11-Apr	0500	42	23	22-Apr	1700	356
April	2017	12	12-Apr	1800	43	51 (4th high)	23-Apr	1900	3
April	2017	20	13-Apr	1200	128	28	24-Apr	1900	2
April	2017	22	14-Apr	1300	124	29	29-Apr	0200	10
April	2017	28	17-Apr	0000	36				
April	2017	15	18-Apr	0800	116				
April	2017	14	19-Apr	1900	23				
April April	2017 2017	<u>33</u> 26	20-Apr 22-Apr	0200	35 30				
April	2017	38	22-Apr 24-Apr	1100	103				
April	2017	13	25-Apr	0000	110				
April	2017	14	29-Apr	2200	32				
May	2017	13	7-May	1500&1800	35-37	70 (1st high)	9-May	1400	186
May	2017	13	8-May	2000	37	13	11-May	1500	350
May	2017	33	9-May	1200	198	12	12-May	1800	2
May	2017	54 (3rd high)	10-May	1100	136	56 (2nd high)	13-May	1100	116
May	2017	12	11-May	1300	27	30	15-May	1200	126
May	2017	29	12-May	1900	30	14	27-May	1500	97
May May	2017 2017	23 16	15-May 20-May	1600 1300	65 119				
May	2017	10	20-May 23-May	2200	23				
May	2017	15	27-May	1000	142				
May	2017	17	28-May	1000	137				
June	2017	10	8-Jun	1300 & 1700	214	17	4-Jun	2300	6
June	2017	46 (4th high)	14-Jun	1000	127	14	5-Jun	0000	359
June	2017	12	15-Jun	1400	143	11	6-Jun	2100	357
June	2017					22	8-Jun	1200	118
June June	2017 2017					18 19	13-Jun 15-Jun	1400 1400	345 130
June	2017					10	21-Jun	1600	103
July	2017	19	3-Jul	1900	24	23	4-Jul	1700	349
July	2017	11	4-Jul	1900	20	22	19-Jul	1500	355
July	2017	10	17-Jul	1800	41	20	21-Jul	1700	180
July	2017	21	19-Jul	1700	34	13	25-Jul	14-1600	339-35
July	2017	16	21-Jul	0900	33	17	27-Jul	1900	3
July	2017	11	25-Jul	1400	15				
July August	2017	<u>10</u> 12	29-Jul 3-Aug	0900 0900	30 99	17	7-Aug	1000&1300	351-36
August	2017 2017	12	3-Aug 7-Aug	1200	99 10	<u>17</u> 23	7-Aug 10-Aug	1000&1300	173
August	2017	33	16-Aug	1200	179	23	13-Aug	1200	113
August	2017	10	20-Aug	1000	221	10	14-Aug	1200	168
August	2017	14	26-Aug	1700	25	11	16-Aug	1400	156
August	2017	23	27-Aug	1000	102	13	26-Aug	1000	357
September	2017	21	2-Sep	1300 & 1500	128	29	10-Sep	1500	90
eptember	2017	89 (1st high)	10-Sep	1200	109	16	11-Sep	1200	106
September	2017	42	11-Sep	1300	127	13	12-Sep	1100	22
September	2017	21	12-Sep	1700	9	<u>22</u>	18-Sep	1200	5
September September	2017 2017	<u>14</u> 13	18-Sep 22-Sep	1700 1300	23 206	19 18	23-Sep 24-Sep	1500 1500	222 172
	2017	13	22-3eb	1300	200	21	24-Sep 25-Sep	1200	117
		- <u> </u>	6.0.4	1300	71	13	10-Oct	1500	6
September	2017	6	0-0/07						
	2017 2017	6 15	6-Oct 27-Nov	1300	133	10	7-Nov	1200	354
September October									

2. Canadian SO2 sources upwind - Yellow DTE Energy Power Plants upwind - Blue Overall 1st High - Orange

Table 6

	1	DTE Energy Air	Qualit	y Monitor	ing Sites	(January - Jun	e 2018)		
		Pollo Pivo	r Mille M	onitoring Sit	•	Belle River PP (Domor Do	ad) Monitori	na Sito
							Kemerko		
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
N	N	SO2 Concentration	D -4-	Beginning		SO2 Concentration	D -11	Beginning	
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
January	2018	28	15-Jan	1400	111	5	9-Jan	1500	149
January	2018	10	28-Jan	1500	42				
February	2018	25	22-Feb	1700	26	14	10-Feb	2000	8
February	2018					15	16-Feb	0000	2
February	2018					14	28-Feb	1900	8
March	2018	15	1-Mar	0700	31	14	1-Mar	0000	5
March	2018	18	4-Mar	1100	22	10	5-Mar	1400	6
March	2018	22	5-Mar	1400	38	16	17-Mar	1600	13
March	2018	18	18-Mar	1800	26	17	19-Mar	1600	360
March	2018	10	19-Mar	1400	27	12	21-Mar	1100	4
March	2018	14	20-Mar	2000	25	10	23-Mar	1800	13
March	2018	10	21-Mar	0800	22	14	24-Mar	1300	359
March	2018	12	22-Mar	1800	47	87 (2nd High)	28-Mar	1700	100
March	2018	11	25-Mar	2000	41	, 			
March	2018	38	28-Mar	1800	71				
April	2018	22	11-Apr	1800	24	50	2-Apr	1100	135
April	2018	17	13-Apr	1200	33	17	13-Apr	1200	359
April	2018	38	20-Apr	1200	33	19	20-Apr	1200	309
April	2018	18	21-Apr	1300	198	30	22-Apr	1600	4
April	2018	52 (3rd High)	22-Apr	1900	26	11	28-Apr	1500	16
April	2018	34	23-Apr	0800	113	19	29-Apr	1600	13
April	2018	18	27-Apr	1500	46	25	30-Apr	1100	297
April	2018	42	29-Apr	2000	109				
Мау	2018	36	6-May	1100	21	14	3-May	1500	12
May	2018	20	7-May	0900&1500	56 & 80	43	6-May	1200	354
Мау	2018	49 (4th High)	10-May	1900	26	31	7-May	0800	351
Мау	2018	25	11-May	1900	30	22	11-May	0200	5
May	2018	35	12-May	2300	348	164 (1st High)	12-May	1800	354
May	2018	30	13-May	1200	55	45	13-May	1500	163
May	2018	35	15-May	2300	343	53	15-May	1800	2
May	2018	25	16-May	0000	341	31	17-May	0800&2200	351&3
May	2018	19	18-May	0100&0200	17 & 16	12	18-May	0100-0400	0-9
May	2018	29	20-May	1800	20	24	20-May	1900	349
May	2018	79 (1st High)	21-May	1100	121	20	22-May	1600	353
May	2018	41	23-May	1600	33	26	22-May 23-May	1600	357
Мау	2018	26	23-May	2000	11	20	23-May 24-May	1100	116
May	2018	33	29-May	1600&1700	22 & 23	70 (3rd High)	28-May	1500	139
May	2018			1000		29	29-May	1600	349
June	2018	20	1-Jun	1300	30	41	1-Jun	1000	353
June	2018	20	2-Jun	1700	14	26	2-Jun	1600	354
June	2018	19	5-Jun	1000	31	18	5-Jun	1400&1500	357
June	2018	34	6-Jun	1700	90	11	6-Jun	0800	358
June	2018	30	7-Jun	2000	27	38	7-Jun	1500	127
June	2018	34	8-Jun	1900	37	65 (4th High)	8-Jun	1500	345
June	2018	31	11-Jun	1800	14	35	11-Jun	1900	349
June	2018	24	14-Jun	1400	28	11	12-Jun	1100	149
June	2018	23	15-Jun	0800&0900	44	21	14-Jun	1300	354
June	2018	71 (2nd High)	19-Jun	1700	23	20	15-Jun	1500	358
June	2018	17	20-Jun	0800	55	29	19-Jun	0300	355
June	2018	36	21-Jun	1900	19	28	20-Jun	0500	360
June	2018	20	23-Jun	1300	73	58	21-Jun	1400	1
June	2018	12	25-Jun	1900	16	10	24-Jun	1800	6
June	2018	25	26-Jun	0900	113	15	24-Jun 25-Jun	1400&1800	355
JULIC	2010	23	20-9UH	0000	113	13	∠J-JUII		300

2. Canadian SO2 sources upwind - Yellow DTE Energy Power Plants upwind - Blue Overall 1st High - Orange

Table 6 (Continued)

			aanty N		, 51.00 (0	lanuary - Decen		,	
		Belle Rive	r Mills M	onitoring Sit	e	Belle River PP (Remer Ro	ad) Monitori	ng Site
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
		SO2 Concentration		Beginning	Direction	SO2 Concentration		Beginning	Direction
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
July	2018	49	2-Jul	1800	23	26	2-Jul	1500	354
July	2018	49	3-Jul	1100	121	27	4-Jul	1300	116
July	2018	31	4-Jul	1300	192	11	6-Jul	1800	7
July	2018	21	7-Jul	1000	109	53	10-Jul	1900	359
July	2018	11	11-Jul	1400	20	32	11-Jul	1900	15
July	2018	12	17-Jul	1700	24	15	18-Jul	0900	344
July	2018	12	18-Jul	1700	39	12	19-Jul	1600	152
July	2018	14	25-Jul	1700	27	23	25-Jul	0900	3
July	2018	18	30-Jul	1700	17				
July	2018	16	31-Jul	1700	29				
August	2018	23	10-Aug	1800	20	22	7-Aug	1200	69
August	2018	11	11-Aug	1600&1700	226-227	18	8-Aug	1500	7
August	2018	18	12-Aug	1700	28	15	10-Aug	1600	357
August	2018	21	13-Aug	1000	18	53	11-Aug	1400	107
August	2018	21	18-Aug	1400	19	15	12-Aug	1600	352
August	2018	21	19-Aug	1300	91	11	13-Aug	1300	3
August	2018	13	20-Aug	1300	122	11	18-Aug	1300	17
August	2018	16	30-Aug	0900	23	58	31-Aug	1100	64
August	2018	50 (4th High)	31-Aug	1000	169				
September	2018	30	11-Sep	1700	30	12	11-Sep	1700	352
September	2018	14	13-Sep	1900	13	16	14-Sep	1300	5
September	2018	12	14-Sep	2200	41	42	15-Sep	1300&1500	349-352
September	2018	21	15-Sep	1400	24	21	17-Sep	1100	119
September	2018	11	16-Sep	1000	132	13	18-Sep	1500	357
September	2018	46	17-Sep	1200	87	12	19-Sep	1700	20
September	2018	14	18-Sep	1700	26	11	23-Sep	1600	358
September	2018	26	23-Sep	1700	22				
October	2018	10	7-Oct	1300	25	9	18-Oct	1000	260
November	2018	13	4-Nov	1200	112	4	14-Nov	1600	118
November	2018	10	22-Nov	1600	124				
December	2018	17	15-Dec	2000	28	4	4-Dec	1800	266
December	2018	18	27-Dec	1100	118				
Notes: 1. The	SO2 1-h	our NAAQS is 75 par	ts per bil	lion (ppb) ex	pressed a	s the 99% maximum	daily 1-hou	ır average,	
ave	raged over	er 3 years							

Maximum Monthly & SO2 Concentrations > 10 ppb for St. Clair County Monitors

		DTE Energy Air				pb for St. Clair (s (Januarv - Jun	_		
			Quant			s (Gandary - Gan	2013)		
		Belle Rive	r Mills M	onitoring Sit	e	Belle River PP (Remer Ro	ad) Monitori	ng Site
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
		SO2 Concentration		Beginning	Direction	SO2 Concentration		Beginning	Directio
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
January	2019	12	7-Jan	0900	126	24	11-Jan	1400	175
January	2019	20	11-Jan	1400	178				
January	2019	12	13-Jan	1300	19				
February	2019	23	10-Feb	1300	137	10	9-Feb	1200	115
February	2019	13	20-Feb	1500	123				
February	2019	15	22-Feb	1500	112				
February	2019	23	23-Feb	1300	112				
March	2019	18	1-Mar	1400	72	21	1-Mar	1300	64
March	2019	19	9-Mar	1300	119	11	25-Mar	1600	7
March	2019	16	24-Mar	1900	19	11	26-Mar	1400	6
March	2019	12	25-Mar	0500	32	28	29-Mar	1600	353
March	2019	31	29-Mar	1800	23				
April	2019	15	4-Apr	1700	29	10	6-Apr	1300	149
April	2019	24	6-Apr	1900	350	25	10-Apr	1900	6
April	2019	11	10-Apr	2200	21	20	21-Apr	1400	160
April	2019	13	17-Apr	1600	127	13	30-Apr	1800	3
April	2019	21	25-Apr	1100	115				
April	2019	14	27-Apr	2100	16				
May	2019	23	2-May	1800	24	13	2-Mav	0700&1200	20/124
May	2019	16	4-May	1700	41	22	5-May	1600	131
May	2019	21	11-May	1300	21	23	6-May	1900	3
May	2019	12	12-May	1300	27	16	7-May	2300	360
May	2019	19	17-May	1600&1700	31	13	8-May	0000	359
May	2019	10	20-May	1900	84	40	11-May	2000	9
May	2019	29	21-May	1900	30	16	12-May	1300	356
May	2019	33	22-May	0800	120	26	17-May	0600	358
May	2019	15	24-May	0800	31	28	21-May	1200	350
May	2019	34	26-May	1300	25	14	24-May	0900	349
May	2019	25	27-May	1500	40	14	24-May 26-May	0400	343
May	2019	10	31-May	0000	7	28	27-May	1500	345
May	2019	10	JI-INIAY	0000	'	45 (4th High)	28-May	2000	17
June	2019	36	6-Jun	1500	161	10	20-Iviay 2-Jun	1100	49
June	2019	20	7-Jun	2000	25	38	6-Jun	1800	349
June	2019	10	8-Jun	12000	114	50 (2nd High)	7-Jun	1800	356
June	2019	10	15-Jun	2300	26	40	16-Jun	1600	360
June	2019	22	16-Jun	1100	32	41	17-Jun	1600	346
June	2019	69 (1st High)	17-Jun	1900	41	37	18-Jun	1300	112
June	2019	57 (2nd High)	18-Jun	1900	80	53 (1st High)	19-Jun	2000	357
	2019	14	19-Jun	1600	131	32 33 (Tst High)	20-Jun	1100	354
June June	2019	24	20-Jun	1000	6	<u> </u>	20-Jun 21-Jun	1900&2000	
June	2019	33	20-Jun 21-Jun	1900	358	25	21-Jun 22-Jun	1900&2000	
	2019	27	21-Jun 22-Jun	1900	49	<u> </u>	22-Jun 28-Jun	1300	245
June	2019			1900	49 43			1400	245 357
June June	2019	47 (3rd High) 40 (4th High)	29-Jun 30-Jun	1700	<u>43</u> 26	50 (3rd High) 34	29-Jun 30-Jun	1400	357
		our NAAQS is 75 par							300
		er 3 vears	ra hei nii	ion (hhn) ex	presseu a	5 uie 33 /0 IIId XIIIIUIII	ually 1-HOL	n averaye,	

Ma	aximun	n Monthly & SO	2 Cond	entration	s <u>></u> 10 pp	ob for St. Clair C	County I	N onitors	
	C	TE Energy Air	Quality	Monitori	ng Sites	(July - Decemb	er 2019)		
			er Mills M	onitoring Sit		Belle River PP (Remer Ro	1	
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
		SO2 Concentration		Beginning		SO2 Concentration		Beginning	
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
July	2019	23	2-Jul	1800	87	33	3-Jul	1700	4
July	2019	37	3-Jul	1900	3	10	4-Jul	1200	180
July	2019	17	6-Jul	0900	51	34	6-Jul	1400	355
July	2019	14	7-Jul	0600	16	10	7-Jul	1100	350
July	2019	30	8-Jul	1800	16	18	8-Jul	1300	345
July	2019	35	9-Jul	1300	28	18	9-Jul	1000	24
July	2019	23	11-Jul	1700	19	18	11-Jul	1300&1400	350
July	2019	14	14-Jul	1600	27	18	14-Jul	1600	354
July	2019	10	17-Jul	1000	14	15	17-Jul	1700	9
July	2019	19	21-Jul	1500	34	13	21-Jul	1400	4
July	2019	12	31-Jul	0200	28	10	24-Jul	1100&1200	12
July	2019					17	31-Jul	1700	360
August	2019	11	1-Aug	1000	12	17	1-Aug	1600-1700	356-1
August	2019	17	2-Aug	1000	18	13	2-Aug	1300	350
August	2019	18	4-Aug	1200&1500	42 & 29	12	4-Aug	1200	34
August	2019	13	7-Aug	1700	143	26	13-Aug	1400	358
August	2019	23	13-Aug	1200	31	16	14-Aug	1700	8
August	2019	18	14-Aug	2100	24	10	16-Aug	1200	176
August	2019	15	15-Aug	1700	20	12	19-Aug	1300	103
August	2019	22	16-Aug	1200	150				
August	2019	15	24-Aug	1700	31				
August	2019	14	25-Aug	1200	107				
August	2019	10	31-Aug	1600	11				
September	2019	10	4-Sep	1700	48	28	16-Sep	1700	7
September	2019	23	9-Sep	1200	76				•
September	2019	20	16-Sep	1200	33			1	
October	2019	30	5-Oct	1200	115	23	8-Oct	1300	95
October	2019	22	8-Oct	1100	96	45	18-Oct	1400	98
October	2019	18	9-Oct	1000&1100	109 & 101		10 000	1-700	50
October	2019	15	10-Oct	1500	121				
November	2019	17	18-Nov	1200&1300	143-150	6	26-Nov	1200&1300	30-60
December	2019	37	16-Dec	1500	48	14	16-Dec	1400&1500	47-50
December	2019	19	20-Dec	1200	146		10-060		-1-50
December	2019	19	20-Dec 29-Dec	0800	139				
						s the 99% maximum	daily 1-ber		
			rs het pli	ion (hhn) ex	piesseu as	5 the 33 /0 (IIdXIIIUM)	ually 1-110L	average,	
		er 3 years 2 sources upwind -	V		Device a Diev	ta unu in d. Dhua Or			_

<u> </u>	op 10 Maximum	1-Hour Dail	y SO2 Conce	ntrations - 2017	
DTE Ene	rgy Belle River Mills	Monitor	EG	LE Port Huron Monit	or
	Maximum Hourly			Maximum Hourly	
	SO2 Concentration			SO2 Concentration	
2017 Rank	(ppb)	Date	2017 Rank	(ppb)	Date
1	89	10-Sep	1	76	17-Dec
2	73	27-Mar	2	66	3-Apr
3	54	10-May	3	58	28-Aug
4	46	14-Jun	4	55	12-Oct
5	45	19-Feb	5	54	7-Feb
6	42	11-Sep	6	51	4-Mar
7	38	24-Apr	7	51	3-Jun
8	33	20-Apr	8	50	13-Dec
9	33	9-May	9	49	2-Sep
10	33	16-Aug	10	48	13-Mar
			Maximum Blue	35	21-Sep
					•
DTE Energy	Belle River PP (Rem	er) Monitor	Lambton Cour	ty (Canada) River Be	nd Monitor
	Maximum Hourly			Maximum Hourly	
	SO2 Concentration			SO2 Concentration	
2017 Rank	(ppb)	Date	2017 Rank	(ppb)	
1				(PP/	Date
•	70	9-May	1	77	Date 22-Apr
2	70 56	9-May 13-May	1 2		
-			-	77	22-Apr
2	56	13-May	2	77 60	22-Apr 12-Jan
2 3	56 52	13-May 27-Nov	2 3	77 60 59	22-Apr 12-Jan 21-Sep
2 3 4	56 52 51	13-May 27-Nov 23-Apr	2 3 4	77 60 59 54	22-Apr 12-Jan 21-Sep 24-Apr
2 3 4 5	56 52 51 30	13-May 27-Nov 23-Apr 29-Mar	2 3 4 5	77 60 59 54 51	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep
2 3 4 5 6	56 52 51 30 30	13-May 27-Nov 23-Apr 29-Mar 15-May	2 3 4 5 6	77 60 59 54 51 45	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar
2 3 4 5 6 7	56 52 51 30 30 29	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr	2 3 4 5 6 7	77 60 59 54 51 45 44	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul
2 3 4 5 6 7 8	56 52 51 30 30 29 29	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr 10-Sep	2 3 4 5 6 7 8	77 60 59 54 51 45 44 42	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul 29-Jul
2 3 4 5 6 7 8 9	56 52 51 30 30 29 29 29 28	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr 10-Sep 24-Apr	2 3 4 5 6 7 8 9	77 60 59 54 51 45 45 44 42 41	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul 29-Jul 19-Apr
2 3 4 5 6 7 8 9 10	56 52 51 30 30 29 29 29 28	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr 10-Sep 24-Apr 19-Apr	2 3 4 5 6 7 8 9 10 Maximum Blue	77 60 59 54 51 45 44 42 41 41 41 40	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul 29-Jul 19-Apr 12-Sep 20-Oct
2 3 4 5 6 7 8 9 10 Notes: 1. The S	56 52 51 30 30 29 29 29 29 28 28 25	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr 10-Sep 24-Apr 19-Apr 75 parts per bil	2 3 4 5 6 7 8 9 10 Maximum Blue	77 60 59 54 51 45 44 42 41 41 41 40	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul 29-Jul 19-Apr 12-Sep 20-Oct
2 3 4 5 6 7 8 9 10 Notes: 1. The S 1-hou	56 52 51 30 30 29 29 29 28 25 602 1-hour NAAQS is	13-May 27-Nov 23-Apr 29-Mar 15-May 29-Apr 10-Sep 24-Apr 19-Apr 75 parts per bil over 3 years	2 3 4 5 6 7 8 9 10 Maximum Blue lion (ppb) expres	77 60 59 54 51 45 44 42 41 41 41 41 40 sed as the 99% maxin	22-Apr 12-Jan 21-Sep 24-Apr 22-Sep 29-Mar 19-Jul 29-Jul 19-Apr 12-Sep 20-Oct num daily

<u> </u>	op 10 Maximum	1-Hour Dail	y SO2 Conce	ntrations - 2018	
DTE Ene	ergy Belle River Mills	Monitor	EG	LE Port Huron Monit	<u>or</u>
	Maximum Hourly			Maximum Hourly	
	SO2 Concentration			SO2 Concentration	
2018 Rank	(ppb)	Date	2018 Rank	(ppb)	Date
1	79	21-May	1	109	1-Dec
2	71	19-Jun	2	89	22-Jun
3	52	22-Apr	3	84	6-Mar
4	50	31-Aug	4	82	26-Oct
5	49	10-May	5	76	5-Oct
6	49	2-Jul	6	74	20-Dec
7	49	3-Jul	7	72	16-May
8	46	17-Sep	8	70	4-Nov
9	42	29-Apr	9	66	1-Jul
10	41	23-May	10	64	20-Aug
DIE Energy	y Belle River PP (Ren Maximum Hourly SO2 Concentration	ner) Monitor	Lampton Col	unty (Canada) River B Maximum Hourly SO2 Concentration	end Monitor
2018 Rank	(ppb)	Date	2018 Rank	(ppb)	Date
1	164	12-May	1	230	12-May
2	87	28-Mar	2	106	15-Sep
3	70	28-May	3	101	8-Jun
4	65	8-Jun	4	81	1-Jun
5	58	21-Jun	5	80	15-May
6	58	31-Aug	6	78	21-Jun
7	53	15-May	7	75	22-Apr
8	53	10-Jul	8	72	7-Jun
9	53	11-Aug	9	69	20-May
10	50	2-Apr	10	68	6-May
Maximum Blue	45	13-May	Maximum Blue	61	9-May
Notes: 1. The S	602 1-hour NAAQS is	75 parts per bil	lion (ppb) expres	sed as the 99% maxin	num daily
1-hou	ır average, averaged	over 3 years			
2. Canac	lian SO2 sources up	wind - Yellow D	OTE Energy Powe	r Plants upwind - Blu	le
Neithe	er DTE nor Canadian	SO2 sources d	irectly upwind - V	Vhite	

Table 8 (Continued)

T	op 10 Maximum	1-Hour Daily	y SO2 Conce	ntrations - 2019	
DTE En	ergy Belle River Mills	Monitor	EG	LE Port Huron Monit	or
	Maximum Hourly			Maximum Hourly	
	SO2 Concentration			SO2 Concentration	
2019 Rank	(ppb)	Date	2019 Rank	(ppb)	Date
1	69	17-Jun	1	73	17-Nov
2	57	18-Jun	2	71	30-Dec
3	47	29-Jun	3	64	9-Sep
4	40	30-Jun	4	63	11-Apr
5	37	3-Jul	5	60	27-Feb
6	37	16-Dec	6	57	20-Feb
7	36	6-Jun	7	57	12-Sep
8	35	9-Jul	8	55	8-May
9	34	26-May	9	55	16-Nov
10	33	22-May	10	53	9-Mar
			Maximum Blue	45	11-Jan
DTE Energy	y Belle River PP (Ren	ner) Monitor	Lambton Cou	unty (Canada) River B	end Monitor
	Maximum Hourly			Maximum Hourly	
	SO2 Concentration			SO2 Concentration	
2019 Rank	(ppb)	Date	2019 Rank	(ppb)	Date
1					Date
2	53	19-Jun	1	114	30-Jun
_	53 50	19-Jun 7-Jun	1 2	<u>114</u> 112	
3			-		30-Jun 29-Jun
	50	7-Jun 29-Jun	2	112	30-Jun
3	50 50	7-Jun 29-Jun 28-May	2 3	<u>112</u> 100	30-Jun 29-Jun 13-Aug
3 4	50 50 45	7-Jun 29-Jun	2 3 4	112 100 90	30-Jun 29-Jun 13-Aug 8-Jul
3 4 5	50 50 45 45	7-Jun 29-Jun 28-May 18-Oct 17-Jun	2 3 4 5	112 100 90 88	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun
3 4 5 6	50 50 45 45 41	7-Jun 29-Jun 28-May 18-Oct	2 3 4 5 6	112 100 90 88 82	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May
3 4 5 6 7	50 50 45 45 41 40	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May	2 3 4 5 6 7	112 100 90 88 82 73	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul
3 4 5 6 7 8	50 50 45 45 41 41 40 40 40	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun	2 3 4 5 6 7 8	112 100 90 88 82 73 72	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun
3 4 5 6 7 8 9	50 50 45 45 41 41 40 40 38	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun	2 3 4 5 6 7 8 9	112 100 90 88 82 73 72 65	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun
3 4 5 6 7 8 9 10 Maximum Blue	50 50 45 45 41 40 40 40 38 37 24	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun 18-Jun 11-Jan	2 3 4 5 6 7 8 9 10 Maximum Blue	112 100 90 88 82 73 72 65 60 48	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun 22-Apr
3 4 5 6 7 8 9 10 Maximum Blue Notes: 1. The S	50 50 45 45 41 40 40 40 38 38 37 24 SO2 1-hour NAAQS is	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun 18-Jun 11-Jan 75 parts per bil	2 3 4 5 6 7 8 9 10 Maximum Blue	112 100 90 88 82 73 72 65 60 48	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun 22-Apr
3 4 5 6 7 8 9 10 Maximum Blue Notes: 1. The S 1-hou	50 50 45 45 41 40 40 38 38 37 24 502 1-hour NAAQS is ar average, averaged	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun 18-Jun 18-Jun 11-Jan 75 parts per bil over 3 years	2 3 4 5 6 7 8 9 10 Maximum Blue lion (ppb) expres	112 100 90 88 82 73 72 65 60 48 sed as the 99% maxim	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun 22-Apr num daily
3 4 5 6 7 8 9 10 Maximum Blue Notes: 1. The S 1-hou 2. Canad	50 50 45 45 41 40 40 38 37 24 SO2 1-hour NAAQS is ur average, averaged dian SO2 sources upv	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun 6-Jun 18-Jun 11-Jan 75 parts per bil over 3 years vind - Yellow	2 3 4 5 6 7 8 9 10 Maximum Blue lion (ppb) expres DTE Energy Powe	112 100 90 88 82 73 72 65 60 48 sed as the 99% maximer	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun 22-Apr num daily
3 4 5 6 7 8 9 10 Maximum Blue Notes: 1. The S 1-hou 2. Canad	50 50 45 45 41 40 40 38 38 37 24 502 1-hour NAAQS is ar average, averaged	7-Jun 29-Jun 28-May 18-Oct 17-Jun 11-May 16-Jun 6-Jun 6-Jun 18-Jun 11-Jan 75 parts per bil over 3 years vind - Yellow	2 3 4 5 6 7 8 9 10 Maximum Blue lion (ppb) expres DTE Energy Powe	112 100 90 88 82 73 72 65 60 48 sed as the 99% maximer	30-Jun 29-Jun 13-Aug 8-Jul 7-Jun 11-May 6-Jul 17-Jun 17-May 16-Jun 22-Apr num daily

Table 8 (Continued)

Table	9
-------	---

Sinces	Start of	DTE Energy A	ir Quali	ty Monitor	ring Site	es (Nov. 23, 2016) Through Dec. 2017							
			t Huron N	Aonitoring Si	to	MDEO Bor	t Huron M	onitoring Sit	ho				
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind				
		SO2 Concentration				SO2 Concentration		Beginning					
Month	Year		Date	Beginning			Date						
Month		(ppb)		(EST)	(deg)	(ppb)		(EST)	(deg)				
November	2016	54	23-Nov	0900	111	17	24-Nov	0100	119				
November	2016	11	27-Nov	2000	172	12	29-Nov	2000	172				
December	2016	37	4-Dec	2100	113	14	6-Dec	1000	93				
December	2016	46	25-Dec	2300	108	30	26-Dec	0000	115				
January	2017	40	2-Jan	1200	115	11	3-Jan	0400	140				
January	2017	14	10-Jan	1900	190	12	14-Jan	1000	107				
January	2017	39	17-Jan	0400	113	15	19-Jan	1900	175				
January	2017	23	20-Jan	1400	94	54	7 5 . 1.	4400	440				
February	2017	28	6-Feb	2200	85	54	7-Feb	1100	110				
February	2017	35	20-Feb	2000	115	12	28-Feb	1700	187				
March	2017	51	4-Mar	2200	107	13	5-Mar	0600	132				
March	2017	11	6-Mar	2000	189	20	12-Mar	2200	109				
March	2017	48	13-Mar	0500	106	20	17-Mar	1300	185				
March	2017	24	26-Mar	0700	100	47	30-Mar	0500	105				
March	2017	16	31-Mar	0000	95								
April	2017	66 (2nd high)	3-Apr	0700	105	18	9-Apr	1800	189				
April	2017	10	10-Apr	0400	177	11	11-Apr	1000	155				
April	2017	26	13-Apr	0400	134	15	15-Apr	1100	117				
April	2017	12	18-Apr	0800	130	10	23-Apr	1700	191				
April	2017	27	24-Apr	1000	105	36	25-Apr	0600	114				
April	2017	20	27-Apr	1000	187	14	30-Apr	1400	87				
May	2017	15	1-May	1700	194	14	4-May	1000	137				
May	2017	10	10-May	1600	102	28	11-May	0400	115				
May	2017	21	16-May	1700	186	43	20-May	2400	112				
May	2017	25	21-May	0200	122	24	24-May	1100	101				
May	2017	10	25-May	0200	87	15	27-May	1100	87				
May	2017	13	28-May	1800	186								
June	2017	51	3-Jun	1300	111	12	8-Jun	1900	152				
June	2017	13	13-Jun	0800	112	14	14-Jun	1000	109				
July	2017	20	18-Jul	1900	189	11	22-Jul	1800	33				
July	2017	34	26-Jul	1200	189								
August	2017	14	3-Aug	1100	53	11	14-Aug	1700	191				
August	2017	27	16-Aug	1200	156	12	20-Aug	1800	192				
August	2017	18	21-Aug	1600	190	26	27-Aug	0800	100				
August	2017	58 (3rd high)	28-Aug	0300&0400	105-107	13	29-Aug	1000	112				
September	2017	49	2-Sep	0900	100 107	16	10-Sep	1100	84				
September	2017	19	11-Sep	1300	170	10	13-Sep	1200	104				
September	2017	13	14-Sep	1400	184	13	16-Sep	1500-1600	188				
September	2017	15	20-Sep	1400	194	35	21-Sep	1300-1000	186				
September	2017	22	20-Sep 22-Sep	1200	194	29	21-Sep 25-Sep	1300	149				
September	2017	25	22-Sep 26-Sep	1300	166	23	72-96h	1300	143				
October	2017	12	26-Sep 6-Oct	1300	45	55 (4th high)	12-Oct	2100	102				
October	2017	24	20-Oct	1400	45 185		21-Oct	1500					
October	2017	24 20	20-Oct 22-Oct	1300	185	13 18	21-0ct 23-0ct	0300	180 174				
						10	23-001	0300	174				
October	2017	10	27-Oct	1000	176	24	15 Nov	1200	470				
November	2017	14	14-Nov	1700	168	21	15-Nov	1300	179				
November	2017	20	17-Nov	2300	176	11	18-Nov	0100	181				
November	2017	28	27-Nov	1400	174	11	28-Nov	0300	171				
December	2017	16	4-Dec	2100	181	10	11-Dec	1400	148				
December	2017	50	13-Dec	1900	96	76 (1st high)	17-Dec	1800	111				
December	2017	28	21-Dec	2000	82								

2. Canadian SO2 sources upwind - Yellow DTE Energy Power Plants upwind - Blue Overall 1st High - Orange

		MDEQ Port H		onitoring uary - Dec		ys with SO2 <u>></u> 10 2018	0 ppb		
			t Huron N	Ionitoring Si			t Huron M	onitoring Sit	
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
		SO2 Concentration		Beginning		SO2 Concentration		Beginning	
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
January	2018	13	10-Jan	1500	183	16	15-Jan	2000	107
January	2018	15	31-Jan	0600	177				
February	2018	23	7-Feb	2100	81	32	9-Feb	1300	99
February	2018	11	18-Feb	1400&1700	178-180	38	23-Feb	0300	104
February	2018	34	24-Feb	2300	108				
March	2018	84 (3rd High)	6-Mar	0500	102	28	7-Mar	0100	88
March	2018	50	25-Mar	2300	94	58	26-Mar	0000&0300	103 & 108
March	2018	17	28-Mar	1800	38				
April	2018	54	3-Apr	0500	101	11	9-Apr	1400	118
April	2018	13	12-Apr	0000	134	34	15-Apr	1900	92
April	2018	14	21-Apr	1200	192	24	23-Apr	0800	115
April	2018	11	24-Apr	0900	127				
May	2018	16	7-May	1200	32	17	8-May	1900	182
May	2018	36	9-May	1000	187	25	13-May	1300	42
May	2018	30	14-May	1500	186	72	16-May	1100	59
May	2018	60	18-May	2300	106	16	24-May	1300	97
May	2018	20	26-May	1600	190	17	27-May	0800	181
May	2018	20	28-May	1200	234	40	30-May	0500	111
May	2018	12	31-May	0300	176				
June	2018	25	10-Jun	1000	100	13	12-Jun	1700	185
June	2018	10	16-Jun	1300	144	16	17-Jun	1500	180
June	2018	89 (2nd High)	22-Jun	0900	103	15	26-Jun	0800	123
June	2018	12	29-Jun	1700	183	10	20 0011	0000	120
July	2018	66	1-Jul	1200	183	12	3-Jul	1100	101
July	2018	11	4-Jul	0900	118	12	7-Jul	0900	116
July	2018	16	4-Jul 8-Jul	1500	182	31	12-Jul	1100	190
July	2018	23	13-Jul	1800	182	15	15-Jul	1000	246
	2018								
July		30	19-Jul	1000	181	18	20-Jul	1300	194
July	2018	37	21-Jul	2300	95	<u>14</u> 12	29-Jul	1900	108
July	2018	10	30-Jul	1700	202		31-Jul	1200	90
August	2018	28	2-Aug	1700	186	15	3-Aug	1800	184
August	2018	13	4-Aug	1500	176	14	11-Aug	1900	355
August	2018	64	20-Aug	2300	104	40	21-Aug	0000	110
August	2018	11	24-Aug	1600	185				
September	2018	13	1-Sep	1600	188	21	3-Sep	1800	190
September	2018	15	16-Sep	1000	107	46	17-Sep	1300	156
September	2018	25	20-Sep	0800	123	42	24-Sep	1000	102
September	2018	20	27-Sep	1300	198				
October	2018	13	1-Oct	1800	120	15	3-Oct	1900	157
October	2018	76	5-Oct	0800	105	32	8-Oct	0100	106
October	2018	11	9-Oct	1700	185	33	10-Oct	1300	187
October	2018	20	14-Oct	1600	183	82 (4th High)	26-Oct	1100	107
October	2018	14	28-Oct	1600	82	39	30-Oct	1300	185
October	2018	24	31-Oct	0000	180				
November	2018	70	4-Nov	1000	103	42	6-Nov	0400	111
November	2018	55	15-Nov	0300	106	44	22-Nov	0400	104
December	2018	109 (1st High)	1-Dec	1100	101	47	2-Dec	0000	107
December	2018	16	7-Dec	1500	170	74	20-Dec	2200	106
December	2018	32	27-Dec	0600	109	15	28-Dec	0100	177
December	2018	12	31-Dec	1600	78				
						s the 99% maximum	daily 1-hou	ır average,	
		er 3 years							
2. Cana	adian SO	2 sources upwind -	Yellow [TE Energy	Power Plar	nts upwind - Blue Ov	verall 1st H	ligh - Orang	e

Table 10
MDEQ Port Huron Monitoring Site Days with SO2 > 10 p

				uary - Deo		ys with SO2 <u>></u> 10 2019			
			Uan						
		EGLE Port	Huron M	Ionitoring Si	te	EGLE Port	Huron Mo	nitoring Sit	e
		Maximum Hourly		Hour	Wind	Maximum Hourly		Hour	Wind
		SO2 Concentration		Beginning	Direction	SO2 Concentration		Beginning	Directio
Month	Year	(ppb)	Date	(EST)	(deg)	(ppb)	Date	(EST)	(deg)
January	2019	27	7-Jan	0100	104	45	11-Jan	1700	203
January	2019	29	12-Jan	1100	96	10	22-Jan	2000	176
January	2019	45	28-Jan	1000	109				
February	2019	13	1-Feb	1600	177	39	6-Feb	0800	109
February	2019	15	10-Feb	2200	106	41	12-Feb	1000	100
February	2019	16	14-Feb	1400	183	20	17-Feb	1100	101
February	2019	57	20-Feb	14-Apr	104	15	23-Feb	1300	101
February	2019	60	27-Feb	1000	104	17	28-Feb	1600	160
March	2019	41	1-Mar	1300	145	11	8-Mar	1600	172
March	2019	53	9-Mar	2000	105	13	13-Mar	0700	156
March	2019	14	14-Mar	1300	188	12	17-Mar	1300	179
March	2019	14	27-Mar	1700	185		17 10101	1000	
April	2019	13	2-Apr	1600&1900	184	45	5-Apr	0700	111
April	2019	63 (4th High)	11-Apr	2300	104	45	12-Apr	0000	110
April	2019	28	22-Apr	1200	183	10	23-Apr	0000	171
April	2019	39	22-Apr 29-Apr	0600	105	10	23-Api	0000	1/1
May	2019	27	1-May	0300	105	22	2-May	1300	146
	2019	49		1100	61	55	8-May	2300	140
May May	2019	49 11	5-May 9-May	0000	118	30	16-May	1100	190
May	2019	10	18-May	2000	155	13	22-Mav	0600	118
	2019	10		1800	92	12		1200	39
May	2019	33	24-May 8-Jun	2300	92	44	29-May 9-Jun	0500	39 107
June June	2019	16	12-Jun	1000&1100	179-180	10	23-Jun	1100	183
	2019	10	24-Jun	0100	153	33	23-Jun 27-Jun	1200	173
June		-							
July	2019	26	10-Jul	1000	187	30	15-Jul	1700	190
July	2019 2019	13 13	18-Jul	1600	181	14	7 4.10	4700	450
August		40	5-Aug	1500 0900	106		7-Aug	1700	156
August August	2019 2019	40 15	15-Aug	1800	91 187	<u>10</u> 16	16-Aug 20-Aug	1500 1300	187
-	2019	41	18-Aug	2200		48	<u> </u>		180
August	2019	41 10	25-Aug 27-Aug	0400	109 176	40 14	26-Aug 31-Aug	0000	106 138
August	2019	22	-	1500	81	14	-	1100	
September September		22	1-Sep			12	3-Sep		185 121
	2019	-	5-Sep	0900	165	13	6-Sep 10-Sep	1600	
September	2019	64 (3rd High)	9-Sep	0500	107			1000	189
September	2019	57	12-Sep	2300	102	13	13-Sep	0000	126
September September	2019	27	17-Sep	1200	108	13	18-Sep	1100	151
September	2019	37	20-Sep	1500	182	17	27-Sep	1400	191
September	2019	32	29-Sep	2000	105	33	30-Sep	1500	194
October	2019	34	3-Oct	1000	117	38	5-Oct	1000	97
October	2019	18	8-Oct	1200	102	50	9-Oct	0700	112
October	2019	34	10-Oct	2200	110 167	13	15-Oct	1600	182
October	2019	13	16-Oct	0000	167	46	26-Oct	1800	96
October	2019	15	28-Oct	1700	188				
November	2019	10	13-Nov	2000	197	55	16-Nov	1000&1400	106-10
November	2019	73 (1st High)	17-Nov	0300	109	14	21-Nov	1000	184
November	2019	13	23-Nov	1600	166	10	25-Nov	1500	188
November	2019	12	26-Nov	1500	155	36	30-Nov	2100	108
December	2019	42	1-Dec	0400	98	11	8-Dec	0100	175
December	2019	30	12-Dec	2100	178	17	13-Dec	0000	178
December	2019	10	16-Dec	1300	194	43	24-Dec	1000	105
December	2019	30	28-Dec	1200	186	28	29-Dec	0100	122
December	2019	71 (2nd High)	30-Dec	0500	109				

2. Canadian SO2 sources upwind - Yellow DTE Energy Power Plants upwind - Blue Overall 1st High - Orange

	-										
				Culpab	ility Anal	ysis for Top	10 SO2 Imp	act Days for	r 2017 & 201	8	
Year											
2017							DTE Ener	av Source Cul	pability Criterio	n n	
2011		Belle Rive	er Mills M	onitoring Sit	'A	1	2	3	4	5	
		Maximum Hourly	/ WIIIS W	Hour	Wind	•	-	•	Low Peak SO2	-	
Initial	Revised	SO2 Concentration		Beginning		Warm Season	Midday Hours	at Remer Road		Plant Upwind	
Rank	Rank	(ppb)	Date	(EST)	(deg)	(April-Sept.)	(0900-1700)	(< 10 ppb)	(< 10 ppb)		Culpable SO2 Source(s
1	1	89	10-Sep	1200	109	X	X	No (14 ppb)	Х	X	DTE & Canadian
2		73	27-Mar	2200	33	~ ~	~	No (12 ppb)	No (17 ppb)	~	Canadian
3	2	54	10-May	1100	136	х	х	X	X	x	DTE Power Plants
4	3	46	14-Jun	1000	127	X	x	X	X	X	DTE Power Plants
5	Ŭ	45	19-Feb	1700	39	~ ~	x	X	No (24 ppb)	~	Canadian
6	4	43	11-Sep	1300	127	х	x	No (16 ppb)	No (19 ppb)	x	DTE & Canadian
7	5	38	24-Apr	1100	103	x	x	No (28 ppb)	No (27 ppb)	X	DTE & Canadian
8	, v	33	20-Apr	0200	35	X	~	X	No (26 ppb)	X	Canadian
9		33	9-May	1200	198	x	x	No (70 ppb)	No (11 ppb)		DTE & Canadian
10		33	16-Aug	1200	179	X	x	No (11 ppb)	Х		DTE & Canadian
-	The SC	33 02 1-hour NAAQS is 7	0						^		
otes:		ed over 3 years	ro parts p	per billion (p	bb) express	sed as the 99% i		-nour average,			
2		an SO2 sources upw	ind - Voll			Plants unwind	- Bluo				
		d rank reflects when						or high SO2 con	contrations at th	o monitor	
3		a rank renects when		ergy power p	Mants were	entirely, or part	ially, culpable it	Ji nign 302 con			
Year											
2018									pability Criteric		
			er Mills M	onitoring Sit	-	1	2	3	4	5	
		Maximum Hourly		Hour	Wind				Low Peak SO2		
Initial		SO2 Concentration		Beginning			-		at River Bend	Plant Upwind	
Rank	Rank	(ppb)	Date	(EST)	(deg)	(April-Sept.)	(0900-1700)	(< 10 ppb)	(< 10 ppb)		Culpable SO2 Source
1	1	79	21-May	1100	121	X	Х	X	Х	X	DTE Power Plants
2		71	19-Jun	1700	23	Х	х	No (36 ppb)	No (59 ppb)		Canadian
3		52	22-Apr	1900	26	Х		No (30 ppb)	No (75 ppb)		Canadian
4		50	31-Aug	1000	169	Х	Х	No (58 ppb)	Х		Canadian
5		49	10-May	1900	26	Х		Х	No (44 ppb)		Canadian
6		49	2-Jul	1800	23	Х		No (26 ppb)	No (55 ppb)		Canadian
7	2	49	3-Jul	1100	121	Х	Х	Х	Х	X	DTE Power Plants
8		46	17-Sep	1200	87	Х	Х	No (21 ppb)	No (12 ppb)		Canadian
9	3	42	29-Apr	2000	109	Х		No (19 ppb)	No (55 ppb)	X	DTE & Canadian
10		41	23-May	1600	33	Х	х	No (26 ppb)	No (34 ppb)		Canadian
lotes: 1	I. The SC	2 1-hour NAAQS is 7		per billion (pr	ob) express	ed as the 99% i	naximum daily 1				
		ed over 3 years		u 1				3 17			
2		an SO2 sources upw	/ind - Yell	low DTE En	ergy Power	Plants upwind	- Blue				
		d rank reflects when						· · · · · ·	· · · · · · · · · · · · · · · · · · ·		

Table 12A

				Culpab	lity Anal	veis for Ton	10 502 1	act Dave for	r 2017 & 201	9	
				Culpab	liity Anai	ysis for Top	10 502 imp	act Days for	2017 & 201	8	
Year											
2017							DTF Ener	av Source Cul	pability Criteric	n	
		Belle River PP (Remer R	oad) Monitori	ing Site	1	2	3		5	
		Maximum Hourly		Hour	Wind	•	-		Low Peak SO2		
Initial	Revised	SO2 Concentration				Warm Season	Midday Hours	at BR Mills	at River Bend	Plant Upwind	
Rank	Rank	(ppb)	Date	(EST)	(deg)	(April-Sept.)	(0900-1700)	(< 10 ppb)	(< 10 ppb)		Culpable SO2 Source
1	1	70	9-May	1400	186	Χ	X	No (33 ppb)	X	X	DTE & Canadian
2		56	13-May	1100	116	X	X	Χ	X		Canadian
3	2	52	27-Nov	1200	170		X	No (15 ppb)	No (22 ppb)	Х	DTE & Canadian
4	_	51	23-Apr	1900	3	х		X	No (38 ppb)	~~~~~	Canadian
5		30	29-Mar	1500	6		Х	No (22ppb)	No (45 ppb)		Canadian
6		30	15-May	1200	126	X	Х	X	X		Canadian
7		29	29-Apr	0200	10	X		Х	х		Canadian
8		29	10-Sep	1500	90	Х	Х	No (89 ppb)	х		Canadian
9		28	24-Apr	1900	2	Х		No (29 ppb)	No (29 ppb)		Canadian
10		25	19-Apr	1700	360	х	х	X	No (41 ppb)		Canadian
otes: 1	. The SO	2 1-hour NAAQS is	75 parts p	per billion (pp	b) express	ed as the 99% i	naximum daily 1-	hour average.			
3	. Revised	d rank reflects wher	n DTE En	ergy power p	lants were	entirely, or part	ially, culpable fo	or high SO2 con	centrations at th	ne monitor	
<u>Year</u>	. Revised	d rank reflects wher	n DTE En	ergy power p	lants were	entirely, or part					
<u>Year</u>	. Revised					entirely, or part	DTE Ener	gy Source Cul	centrations at th pability Criteric	n	
Year	. Revised	Belle River PP (oad) Monitor	ing Site	entirely, or part		gy Source Cul 3	pability Criteric 4	on5	
<u>Year</u> 2018		<u>Belle River PP (</u> Maximum Hourly	Remer R	oad) Monitori Hour	ing Site Wind	1	DTE Ener 2	gy Source Cul 3 Low Peak SO2	pability Criteric 4 Low Peak SO2	on 5 DTE Power Plant	
<u>Year</u> 2018 Initial	Revised	Belle River PP (Maximum Hourly SO2 Concentration	Remer Ro	oad) Monitor Hour Beginning	ing Site Wind Direction	1 Warm Season	DTE Ener 2 Midday Hours	gy Source Cul 3 Low Peak SO2 at BR Mills	pability Criteric 4 Low Peak SO2 at River Bend	on 5 DTE Power Plant Plant Upwind	
<u>Year</u> 2018 Initial Rank		<u>Belle River PP (</u> Maximum Hourly SO2 Concentration (ppb)	Remer Ro Date	oad) Monitor Hour Beginning (EST)	ing Site Wind Direction (deg)	1 Warm Season (April-Sept.)	DTE Ener 2	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb)	on 5 DTE Power Plant Plant Upwind	
Year 2018 Initial Rank 1	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164	Remer Ro Date 12-May	oad) Monitori Hour Beginning (EST) 1800	ing Site Wind Direction (deg) 354	1 Warm Season	DTE Ener 2 Midday Hours (0900-1700)	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian
Year 2018 Initial Rank 1 2	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87	Remer Ro Date 12-May 28-Mar	oad) Monitori Hour Beginning (EST) 1800 1700	ing <u>Site</u> Wind Direction (deg) <u>354</u> 100	1 Warm Season (April-Sept.) X	DTE Ener 2 Midday Hours (0900-1700) X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian
Year 2018 Initial Rank 1 2 3	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70	Date Date 12-May 28-Mar 28-May	bad) Monitori Hour Beginning (EST) 1800 1700 1500	ing Site Wind Direction (deg) 354 100 139	1 Warm Season (April-Sept.) X X	DTE Ener 2 Midday Hours (0900-1700) X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65	Date 12-May 28-Mar 28-May 8-Jun	oad) Monitori Hour Beginning (EST) 1800 1700 1500 1500	ing Site Wind Direction (deg) 354 100 139 345	1 Warm Season (April-Sept.) X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58	Date 12-May 28-Mar 28-May 8-Jun 21-Jun	bad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400	ing <u>Site</u> Wind Direction (deg) <u>354</u> 100 139 345 1	1 Warm Season (April-Sept.) X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (19 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58	Remer Ro Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug	bad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400 1400	ing Site Wind Direction (deg) 354 100 139 345 1 1	1 Warm Season (April-Sept.) X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (19 ppb) No (50 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (29 ppb) X No (101 ppb) No (58 ppb) X	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 53	Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May	bad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1800	ing Site Wind Direction (deg) 354 100 139 345 1 1 1 2	1 Warm Season (April-Sept.) X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (19 ppb) No (50 ppb) No (22 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (80 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7 8	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 58 53 53	Remer Ro Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May 10-Jul	Dad) Monitor Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1800 1900	ing Site Wind Direction (deg) 354 100 139 345 1 1 1 2 359	1 Warm Season (April-Sept.) X X X X X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (19 ppb) No (50 ppb) No (22 ppb) X	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (58 ppb) No (80 ppb) No (23 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7 8 9	Revised	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 58 53 53 53 53	Remer Ro Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May 10-Jul 11-Aug	Dad) Monitor Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1800 1900 1400	ing Site Wind Direction (deg) 354 100 139 345 1 1 2 359 107	1 Warm Season (April-Sept.) X X X X X X X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (20 ppb) No (50 ppb) No (22 ppb) X No (11 ppb)	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (80 ppb) No (23 ppb) X	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7 8 9 10	Revised Rank	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 53 53 53 53 53 53	Remer Ro Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May 10-Jul 11-Aug 2-Apr	Dad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1800 1900 1400 1100	ing Site Wind Direction (deg) 354 100 139 345 1 1 2 359 107 135	1 Warm Season (April-Sept.) X X X X X X X X X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (50 ppb) No (50 ppb) No (22 ppb) X No (11 ppb) X	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (58 ppb) No (80 ppb) No (23 ppb)	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7 8 9 10	Revised Rank	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 53 53 53 53 53 53 53 50 2 1-hour NAAQS is	Remer Ro Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May 10-Jul 11-Aug 2-Apr	Dad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1800 1900 1400 1100	ing Site Wind Direction (deg) 354 100 139 345 1 1 2 359 107 135	1 Warm Season (April-Sept.) X X X X X X X X X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X X X X X X X X X	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (50 ppb) No (50 ppb) No (22 ppb) X No (11 ppb) X	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (80 ppb) No (23 ppb) X	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian
Year 2018 Initial Rank 1 2 3 4 5 6 7 8 9 10 otes: 1	Revised Rank	Belle River PP (Maximum Hourly SO2 Concentration (ppb) 164 87 70 65 58 58 58 53 53 53 53 53 53	Remer R Date 12-May 28-Mar 28-May 8-Jun 21-Jun 31-Aug 15-May 10-Jul 11-Aug 2-Apr 75 parts p	oad) Monitori Hour Beginning (EST) 1800 1700 1500 1500 1400 1400 1400 1400 1400 14	ing Site Wind Direction (deg) 354 100 139 345 1 1 2 359 107 135 b) express	1 Warm Season (April-Sept.) X X X X X X X X X X X X X X X X X X X	DTE Ener 2 Midday Hours (0900-1700) X X X X X X X X X X X X A	gy Source Cul 3 Low Peak SO2 at BR Mills (< 10 ppb) No (34 ppb) No (38 ppb) No (10 ppb) No (21 ppb) No (50 ppb) No (50 ppb) No (22 ppb) X No (11 ppb) X	pability Criteric 4 Low Peak SO2 at River Bend (< 10 ppb) No (230 ppb) No (29 ppb) X No (101 ppb) No (58 ppb) X No (80 ppb) No (23 ppb) X	on 5 DTE Power Plant Plant Upwind	Canadian Canadian Canadian Canadian Canadian Canadian Canadian Canadian

Table 12B

				Cul	pability A		Top 10 SO2	Impact Days	s for 2019		
<u>Year</u>											
2019							DTE Ener	gy Source Cul	pability Criterio	on	
		Belle Rive	er Mills M	onitoring Sit	te	1	2	3	4	5	
		Maximum Hourly		Hour	Wind			Low Peak SO2	Low Peak SO2	DTE Power Plant	
Initial	Revised	SO2 Concentration		Beginning	Direction	Warm Season	Midday Hours	at Remer Road	at River Bend	Plant Upwind	
Rank	Rank	(ppb)	Date	(EST)	(deg)	(April-Sept.)	(0900-1700)	(< 10 ppb)	(< 10 ppb)	During Max SO2 Hour	Culpable SO2 Source
1		69	17-Jun	1900	41	Х		No (41 ppb)	No (72 ppb)		Canadian
2		57	18-Jun	1000	80	Х	Х	No (37 ppb)	No (57 ppb)		Canadian
3		47	29-Jun	1900	43	Х		No (50 ppb)	No (111 ppb)		Canadian
4		40	30-Jun	1700	26	Х	Х	No (34 ppb)	No (114 ppb)		Canadian
5		37	3-Jul	1800	3	Х		No (33 ppb)	No (48 ppb)		Canadian
6		37	16-Dec	1500	48		Х	No (14 ppb)	No (12 ppb)		Canadian
7		36	6-Jun	1500	161	Х	Х	No (20 ppb)	No (16 ppb)		Canadian
8		35	9-Jul	1300	28	Х	Х	No (18 ppb)	No (51 ppb)		Canadian
9		34	26-May	1300	25	х	х	No (11 ppb)	No (46 ppb)		Canadian
10	1	33	22-May	0800	120	Х	Х	X	<u> </u>	X	DTE Power Plants
		an SO2 sources upw d rank reflects when						or high SO2 con	centrations at tl	he monitor	
<u>Year</u>											
2019							DTE Ener	gy Source Cul	pability Criterio	on	
		Belle River PP (Remer R	oad) Monitor	ing Site	1	2	3	4	5	
		Maximum Hourly		Hour	Wind			Low Peak SO2	Low Peak SO2	DTE Power Plant	
Initial	Revised	SO2 Concentration		Beginning	Direction	Warm Season	Midday Hours	at BR Mills	at River Bend		
Rank	Rank	(ppb)	Date	(EST)	(deg)	(April-Sept.)	(0900-1700)	(< 10 ppb)	(< 10 ppb)	During Max SO2 Hour	Culpable SO2 Source
1		53	19-Jun	2000	357	Х		No (14 ppb)	No (49 ppb)		Canadian
2		50	7-Jun	1800	356	Х		No (20 ppb)	No (88 ppb)		Canadian
3		50	29-Jun	1400	357	Х	X	No (26 ppb)	No (104 ppb)		Canadian
4		45	28-May	2000	17	Х		Х	No (23 ppb)		Canadian
5		45	18-Oct	1400	98		Х	Х	Х		Canadian
6		41	17-Jun	1600	346	Х	Х	No (69 ppb)	No (72 ppb)		Canadian
		40	11-May	2000	9	Х		No (21 ppb)	No (82 ppb)		Canadian
7		40	16-Jun	1600	360	Х	Х	No (22 ppb)	No (52 ppb)		Canadian
8		40	10 0011			Х		No (36 ppb)	No (37 ppb)		Canadian
		38	6-Jun	1800	349						
8				1800 1300	349 112	X	х	No (57 ppb)	No (57 ppb)		Canadian
8 9	1	38	6-Jun				X X	No (57 ppb) No (20 ppb)	No (57 ppb) No (39 ppb)	X	Canadian DTE & Canadian
8 9 10	1. The SO	38 37 24 2 1-hour NAAQS is 7	6-Jun 18-Jun 11-Jan	1300 1400	112 175	Х	Х	No (20 ppb)		X	
8 9 10 otes:	1. The SO average	38 37 24	6-Jun 18-Jun 11-Jan 75 parts p	1300 1400 per billion (p	112 175 pb) express	X Sed as the 99% I	X maximum daily 1	No (20 ppb)		X	

Table 12C

Table 13A

First Case Day – DTE Energy SO2 Source Most Culpable

	DTE-Bell	e River Mills	Monitor	DTE-Re	emer Road M	lonitor	MDEQ-	Port Huron I	Monitor	Pontia	Airport	Port Hur	on Airport	t River Bend Monitor-Canada		
Date	SO2	Wind	Wind	SO2	Wind	Wind	SO2	Wind	Wind	Wind	Wind	Wind	Wind	SO2	Wind	Wind
Hour Beginning	Concentration	Direction	Speed	Concentration	Direction	Speed	Concentration	Direction	Speed	Speed	Direction	Speed	Direction	Concentration	Direction	Speed
(EST)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(knots)	(deg)	(knots)	(deg)	(ppb)	(deg)	(mph)
5/21/18 00:00	1	322	2.5	1	315	2.7	0	321	2	3	160	Calm	NA	4	330	1.3
5/21/18 01:00	1	321	2.3	1	310	2.2	0	302	1	Calm	NA	Calm	NA	2	355	2.5
5/21/18 02:00	0	19	2.7	1	351	3.0	NA	343	2	4	20	Calm	NA	2	349	1.8
5/21/18 03:00	0	350	2.7	1	17	2.5	0	331	2	Calm	NA	Calm	NA	1	360	2.5
5/21/18 04:00	0	309	2.1	1	336	1.5	0	332	1	3	20	Calm	NA	1	18	2.1
5/21/18 05:00	0	18	3.0	1	8	3.5	0	307	2	5	50	Calm	NA	2	40	1.7
5/21/18 06:00	1	33	3.7	2	30	3.1	0	350	2	Calm	NA	Calm	NA	2	338	0.6
5/21/18 07:00	3	75	4.4	2	69	3.0	0	32	3	7	70	Calm	NA	1	37	2.9
5/21/18 08:00	1	62	5.8	2	59	3.8	0	51	4	7	80	Calm	NA	2	52	4.4
5/21/18 09:00	1	76	7.0	1	80	4.6	0	31	2	9	80	5	70	1	66	5.0
5/21/18 10:00	48	122	5.5	1	123	5.0	1	39	3	8	70	6	90	2	74	5.2
5/21/18 11:00	79	120	6.6	1	114	5.5	2	18	3	8	110	4	110	3	74	6.8
5/21/18 12:00	75	121	7.8	1	117	6.2	6	31	3	9	100	5	130	2	144	3.2
5/21/18 13:00	10	139	7.4	2	125	6.7	0	20	4	9	130	8	120	1	146	3.5
5/21/18 14:00	2	152	7.3	2	136	6.2	2	25	3	9	120	Calm	NA	1	125	4.4
5/21/18 15:00	6	146	5.6	1	114	5.7	2	28	3	6	100	3	40	1	129	4.4
5/21/18 16:00	2	113	4.7	1	94	3.7	1	39	4	6	120	3	80	11	170	1.2
5/21/18 17:00	10	47	5.3	6	19	4.7	3	10	4	8	80	4	10	24	6	3.6
5/21/18 18:00	9	49	6.1	2	36	3.4	1	32	3	5	130	7	60	10	12	5.5
5/21/18 19:00	4	25	4.5	1	2	4.4	1	23	3	7	110	3	30	14	36	5.1
5/21/18 20:00	5	48	3.2	1	25	3.1	0	15	3	7	80	4	300	NA	55	5.4
5/21/18 21:00	3	67	3.7	1	66	2.4	0	301	1	6	90	Calm	NA	5	21	3.9
5/21/18 22:00	2	97	6.6	1	95	4.9	0	195	1	4	110	Calm	NA	5	NA	NA
5/21/18 23:00	2	93	3.4	1	111	3.8	8	126	5	4	100	4	120	2	NA	NA

Notes:

- 1. Maximum SO₂ (79 ppb) at Belle River Mills Monitor at Hour Beginning 1100
- 2. Low SO₂ (1-2 ppb) at Remer Road at 1100 and previous hours
- 3. Low SO₂ (1-2 ppb) at River Bend at 1100 and previous hours (Higher SO₂ later in the day)
- 4. Light NW to NE winds in early AM, lake effects begin at 1000, and lead to four prime impact hours (1000-1300) close to 120 degrees (Monitor downwind of Belle River & St. Clair power plants)
- 5. Maximum hourly SO₂ was during midday hours

 Table 13B

 Second Case Day – Canadian SO₂ Sources Most Culpable

	DTE-Bell	e River Mills	Monitor	DTE-Remer Road Monitor			MDEQ-	Pontia	Airport	Port Huron Airport		River Bend Monitor-Canada				
Date	SO2	Wind	Wind	SO2	Wind	Wind	SO2	Wind	Wind	Wind	Wind	Wind	Wind	SO2	Wind	Wind
Hour Beginning	Concentration	Direction	Speed	Concentration	Direction	Speed	Concentration	Direction	Speed	Speed	Direction	Speed	Direction	Concentration	Direction	Speed
(EST)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(knots)	(deg)	(knots)	(deg)	(ppb)	(deg)	(mph)
5/12/18 00:00	1	48	5.3	0	33	3.2	0	40	4	9	100	4	20	1	51	6.5
5/12/18 01:00	1	37	6.5	1	21	4.0	0	30	3	10	70	Calm	NA	1	50	6.4
5/12/18 02:00	2	34	7.6	1	26	5.9	NA	21	5	9	40	5	360	0	47	5.2
5/12/18 03:00	7	16	6.0	0	6	5.3	0	20	5	8	40	5	10	1	40	6.7
5/12/18 04:00	11	19	6.5	1	3	5.3	0	7	4	16	110	5	10	9	37	6.4
5/12/18 05:00	6	30	6.9	1	20	5.3	0	26	4	6	50	5	350	9	20	5.7
5/12/18 06:00	11	24	7.5	0	15	5.6	0	25	5	7	40	5	10	NA	36	6.4
5/12/18 07:00	8	31	6.3	0	23	4.7	0	27	5	8	60	6	30	10	33	6.2
5/12/18 08:00	3	30	6.9	1	27	4.8	0	27	4	6	50	6	10	10	35	6.8
5/12/18 09:00	6	23	6.4	1	14	4.1	0	29	5	5	10	4	20	2	44	6.7
5/12/18 10:00	10	26	6.7	1	18	5.2	1	30	4	5	50	5	20	2	42	7.1
5/12/18 11:00	27	21	5.7	2	345	4.7	1	24	5	5	20	8	360	9	34	5.9
5/12/18 12:00	9	20	5.2	32	357	5.6	1	9	5	Calm	NA	Calm	NA	8	38	7.1
5/12/18 13:00	29	28	9.4	17	14	7.2	1	2	4	8	10	5	350	79	32	7.9
5/12/18 14:00	33	40	8.1	28	357	7.2	1	22	6	4	40	9	40	32	29	5.3
5/12/18 15:00	13	39	9.3	25	8	7.1	1	19	6	5	60	7	20	46	32	9.6
5/12/18 16:00	34	47	7.1	48	354	6.7	1	24	6	5	360	6	40	35	36	9.5
5/12/18 17:00	25	39	7.1	130	347	8.0	1	40	5	7	160	6	50	92	35	11.0
5/12/18 18:00	6	38	6.7	164	354	6.7	1	31	5	5	170	8	40	230	32	9.1
5/12/18 19:00	2	36	4.5	141	18	4.3	1	16	4	3	210	3	20	215	27	7.1
5/12/18 20:00	30	48	3.8	24	26	2.6	1	9	3	Calm	NA	Calm	NA	170	36	7.3
5/12/18 21:00	5	50	6.3	3	32	3.3	1	35	3	6	90	3	30	40	34	5.6
5/12/18 22:00	11	356	3.0	2	337	2.0	1	36	4	4	180	3	30	13	50	5.4
5/12/18 23:00	35	348	3.5	17	329	2.5	0	354	3	3	100	Calm	NA	3	47	7.1

Notes:

1. Maximum SO₂ concentration (164 ppb) at Remer Road Monitor during Hour Beginning 1800

2. Moderate SO₂ concentration (34 ppb) at Belle River Mills Monitor at Hour Beginning 1600

3. Extremely high SO₂ concentrations (230 ppb) at the Canadian River Bend Monitor during Hour Beginning 1800 (River Bend is upwind of the Remer Road site with NNE winds (~30 degrees)

4. Light to moderate wind speeds the entire day from NNE to ENE

Table 13C
Third Case Day – DTE Energy & Canadian SO ₂ Sources Culpable

	DTE-Bell	e River Mills	Monitor	DTE-Re	emer Road M	onitor	MDEQ-	Port Huron I	Nonitor	Pontia	c Airport	Port Hur	on Airport	t River Bend Monitor-Canada		
Date	SO2	Wind	Wind	SO2	Wind	Wind	SO2	Wind	Wind	Wind	Wind	Wind	Wind	SO2	Wind	Wind
Hour Beginning	Concentration	Direction	Speed	Concentration	Direction	Speed	Concentration	Direction	Speed	Speed	Direction	Speed	Direction	Concentration	Direction	Speed
(EST)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(ppb)	(deg)	(mph)	(knots)	(deg)	(knots)	(deg)	(ppb)	(deg)	(mph)
9/10/2017 0:00	0	278	1.0	0	303	2.3	0	281	1	Calm	NA	Calm	NA	1	338	0.4
9/10/2017 1:00	0	314	1.2	0	339	2.2	0	77	4	Calm	NA	Calm	NA	1	NA	NA
9/10/2017 2:00	0	319	1.8	0	4	2.3	0	71	2	Calm	NA	Calm	NA	0	88	1.7
9/10/2017 3:00	0	321	1.9	0	2	2.3	0	335	2	Calm	NA	Calm	NA	0	85	1.7
9/10/2017 4:00	0	341	2.3	0	347	2.1	0	310	2	Calm	NA	Calm	NA	0	79	0.5
9/10/2017 5:00	0	337	2.6	0	345	2.6	0	291	2	3	360	Calm	NA	0	82	0.7
9/10/2017 6:00	0	356	1.3	0	320	2.6	0	318	2	3	360	Calm	NA	0	357	0.9
9/10/2017 7:00	0	348	2.4	1	5	3.3	0	316	2	Calm	NA	Calm	NA	0	22	NA
9/10/2017 8:00	0	74	3.5	1	56	2.7	0	345	1	3	30	Calm	NA	0	25	0.5
9/10/2017 9:00	0	69	3.3	1	39	2.5	1	87	3	7	70	Calm	NA	0	51	0.7
9/10/2017 10:00	3	75	4.9	1	60	3.8	1	70	4	8	60	3	60	1	89	2.8
9/10/2017 11:00	34	85	3.7	1	114	3.8	16	84	3	4	NA	4	100	1	81	3.5
9/10/2017 12:00	89	109	3.4	14	120	3.3	8	96	2	4	130	Calm	NA	2	77	1.5
9/10/2017 13:00	48	89	3.5	4	88	3.2	2	179	2	5	NA	7	100	1	203	0.6
9/10/2017 14:00	40	129	4.5	5	86	3.2	7	55	3	5	NA	6	110	1	56	0.6
9/10/2017 15:00	33	134	3.9	29	90	4.4	4	26	4	5	NA	Calm	NA	1	56	2.7
9/10/2017 16:00	27	103	4.2	1	127	3.8	2	40	4	4	NA	4	50	1	92	4.9
9/10/2017 17:00	5	139	2.6	1	60	3.2	1	38	4	4	NA	5	30	4	63	4.5
9/10/2017 18:00	2	96	3.3	1	64	2.7	1	39	4	4	NA	4	30	7	25	5.8
9/10/2017 19:00	1	109	1.7	1	60	1.3	1	37	3	4	100	Calm	NA	3	52	5.1
9/10/2017 20:00	1	72	2.3	1	44	1.6	0	65	2	Calm	NA	Calm	NA	NA	58	3.4
9/10/2017 21:00	0	62	2.1	0	26	1.4	0	154	4	Calm	NA	Calm	NA	0	160	2.4
9/10/2017 22:00	0	24	0.7	0	32	1.4	0	116	1	Calm	NA	Calm	NA	0	107	2.6
9/10/2017 23:00	0	21	1.4	0	342	1.4	0	330	1	Calm	NA	Calm	NA	0	106	1.9

Notes:

- 1. Maximum SO₂ (89 ppb) at Belle River Mills Monitor at Hour Beginning 1200
- 2. Moderately low SO₂ (14 ppb) at Remer Road Monitor at 1200 and previous hours
- 3. Low SO₂ (1-2 ppb) at the Canadian River Bend site at 1200 and previous hours (Wind direction is never in the prime Canadian SO₂ source "sweet spot" of 20-40 degrees during the midday part of the day)
- 4. Very light winds in the early AM, and remaining very light throughout the day (conducive to more vertical turbulence)
- 5. Some Canadian source impact at the Remer Road site (14-29 ppb) with neither DTE Energy power plant upwind from Hour Beginning 1200-1500