



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



C. HEIDI GREETHER
DIRECTOR

December 22, 2016

Mr. Andy Maloy, Director
EH&S Risk Management
Stericycle Environmental Solutions/PSC
18000 72nd Avenue South, Suite 217
Kent, Washington 98032

Dear Mr. Maloy:

SUBJECT: Sewer Evaluation Report; Petro-Chem Processing Group of Nortru, LLC,
Detroit, Michigan; MID 980 615 298

The Michigan Department of Environmental Quality (MDEQ), Office of Waste Management and Radiological Protection (OWMRP) has received the Sewer Evaluation report (Report) dated November 17, 2016. The OWMRP reviewed the Report for compliance with the hazardous waste management facility operating license (License) effective December 18, 2012, and Part 111, Hazardous Waste Management, of the Michigan Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

Based on this review, the OWMRP agrees with the conclusions of the Report that the sewer line along St. Jean Avenue is not intercepting groundwater. OWMRP agrees the storm sewer conduit is a relevant pathway, as there is a reasonable potential that a municipal utility worker could be exposed to hazardous substances in soil during sewer repair operations. Known groundwater concentrations along St. Jean Avenue are not above cleanup criteria for utility workers (non-residential).

Thank you for conducting the study. Should you have any questions regarding this review, please contact me at 517-284-6571; slaytond@michigan.gov; or MDEQ, OWMRP, P.O. Box 30241, Lansing, Michigan 48909-7741.

Sincerely,

David Slayton, Chief
Management & Tracking Unit
Hazardous Waste Section
Office of Waste Management and
Radiological Protection

cc: Mr. Jeffrey Davis, PSC Environmental Services
Ms. Kellie Wing, Bureau Veritas North America, Inc.
Ms. Tracy Kecskemeti, MDEQ
Mr. Jim Day, MDEQ
Ms. Virginia Himich, MDEQ
Mr. Dan Dailey, MDEQ
Mr. John McCabe, MDEQ
Dr. Kristen Kellock, MDEQ
Corrective Action File