

DEQ
RESOURCE MANAGEMENT DIVISION

MONTHLY OPERATION REPORT

OF

WATER TREATMENT PLANT

JAN 10 2012

LANSING DISTRICT

For Month of December 2011

ENTERED

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al³⁺) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MD

Dec-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Dec-11

DATE	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
		Raw	Tap	Dist				18			19			20	21
1			0.70					0.9	0.9	0.5	0.4			0.8	
2			0.75					0.8	0.7	0.4	0.5			0.7	
3			0.62					0.8	0.9	0.4	0.5			0.8	
4			0.60					0.9	0.7	0.4	0.4			0.7	
5			0.68					0.8	0.8	0.4	0.4			0.7	
6			0.72					0.8	1.0	0.5	0.5			0.8	
7			0.70					0.7	0.7	0.5	0.5			0.7	
8			0.70					0.8	0.7	0.6	0.6			0.8	
9			0.67					0.8	0.8	0.6	0.7			0.7	
10			0.69					0.7	0.8	0.6	0.6			0.7	
11			0.71					0.7	0.7	0.6	0.6			0.6	
12			0.66					0.7	0.8	0.6	0.7			0.7	
13			0.66					0.8	0.7	0.6	0.6			0.8	
14			0.73					0.8	0.8	0.7	0.7			0.8	
15			0.71					0.9	0.8	0.7	0.7			0.8	
16			0.69					0.7	0.8	0.7	0.8			0.8	
17			0.73					0.8	0.8	0.6	0.8			0.8	
18			0.67					0.9	0.8	0.7	0.7			0.7	
19			0.68					0.8	0.9	0.7	0.7			0.7	
20			0.74					0.8	0.9	0.7	0.7			0.8	
21			0.72					0.8	0.7	0.6	0.7			0.8	
22			0.66					0.7	0.7	0.5	0.6			0.7	
23			0.69					0.7	0.7	0.6	0.7			0.7	
24			0.63					0.8	0.8	0.7	0.7			0.7	
25			0.67					0.8	0.8	0.7	0.6			0.7	
26			0.60					0.8	0.9	0.7	0.7			0.6	
27			0.61					0.8	0.8	0.7	0.7			0.8	
28			0.57					0.8	0.7	0.8	0.8			0.7	
29			0.57					0.8	0.8	0.8	0.8			0.8	
30			0.57					0.7	0.7	0.7	0.7			0.7	
31			0.57					0.7	0.9	0.8	0.7			0.7	
AVG			0.67					0.8	0.8	0.6	0.6			0.7	
MAX			0.75					0.9	1.0	0.8	0.8			0.8	
MIN			0.57					0.7	0.7	0.4	0.4			0.6	



Chemical Analyses

WSSN 2310

Dec-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.40		96		71		25				29.7		5.3		
2		7.39		96		69		27				29.7		5.3		
3		7.42		96		72		24				28.9		5.8		
4		7.43		98		69		29				28.9		6.3		
5		7.60		98		67		31				29.7		5.8		
6		7.37		94		69		25				28.9		5.3		
7		7.30		104		68		36				28.9		7.8		
8		7.26		96		69		27				28.1		6.3		
9		7.20		96		68		28				28.9		5.8		
10		7.26		96		73		23				29.7		5.3		
11		7.36		96		72		24				26.5		7.3		
12		7.33		90		71		19				24.0		7.3		
13		7.22		96		68		28				28.9		5.8		
14		7.26		100		67		33				28.1		7.3		
15		7.36		100		69		31				28.9		6.8		
16		7.27		94		69		25				28.1		5.8		
17		7.22		94		69		25				28.1		5.8		
18		7.35		98		72		26				28.9		6.3		
19		7.34		98		70		28				29.7		5.8		
20		7.27		92		69		23				28.1		5.3		
21		7.29		92		66		26				27.3		5.8		
22		7.33		98		72		26				30.5		5.3		
23		7.34		98		73		25				29.7		5.8		
24		7.28		96		71		25				29.7		5.3		
25		7.34		94		71		23				24.8		7.8		
26		7.27		98		68		30				29.7		5.8		
27		7.29		96		63		33				26.5		7.3		
28		7.31		98		71		27				29.7		5.8		
29		7.28		98		68		30				29.7		5.8		
30		7.30		98		71		27				28.9		6.3		
31		7.27		98		70		28				28.9		6.3		
AVG		7.32		97		70		27				28.6		6.1		
MAX		7.60		104		73		36				30.5		7.8		
MIN		7.20		90		63		19				24.0		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Dec-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					12.8				
2	1/0		2/0	2/0	2/0	2/0					14.1				
3	1/0		2/0	2/0	2/0	2/0					13.0				
4	1/0		2/0	2/0	2/0	2/0					13.0				
5	1/0		2/0	2/0	2/0	2/0					12.4				
6	1/0		2/0	2/0	2/0	2/0					13.5				
7	1/0		2/0	2/0	2/0	2/0					13.5				
8	1/0		2/0	2/0	2/0	2/0					13.5				
9	1/0		2/0	2/0	2/0	2/0					13.9				
10	1/0		2/0	2/0	2/0	2/0					12.9				
11	1/0		2/0	2/0	2/0	2/0					13.1				
12	1/0		2/0	2/0	2/0	2/0					14.1				
13	1/0		2/0	2/0	2/0	2/0					12.9				
14	1/0		2/0	2/0	2/0	2/0					11.8				
15	1/0		2/0	2/0	2/0	2/0			< 2		14.2				
16	1/0		2/0	2/0	2/0	2/0					12.7				
17	1/0		2/0	2/0	2/0	2/0					13.7				
18	1/0		2/0	2/0	2/0	2/0					13.1				
19	1/0		2/0	2/0	2/0	2/0					12.6				
20	1/0		2/0	2/0	2/0	2/0					12.2				
21	1/0		2/0	2/0	2/0	2/0					12.0				
22	1/0		2/0	2/0	2/0	2/0					12.9				
23	1/0		2/0	2/0	2/0	2/0					12.4				
24	1/0		2/0	2/0	2/0	2/0					12.5				
25	1/0		2/0	2/0	2/0	2/0					12.5				
26	1/0		2/0	2/0	2/0	2/0					13.1				
27	1/0		2/0	2/0	2/0	2/0					12.7				
28	1/0		2/0	2/0	2/0	2/0					11.1				
29	1/0		2/0	2/0	2/0	2/0					11.5				
30	1/0		2/0	2/0	2/0	2/0					11.0				
31	1/0		2/0	2/0	2/0	2/0					11.5				
											12.8				
											14.2				
											11.0				

[illegible]

Dec-11

Distribution System Monitoring																	
DATE	Total Chlorine Residual at Bacteriological Montioning Stations mg/l																
	1	2	3	4	5	6	7	8	9	10	11	CS	WR	STA II AM	STA II PM	Number of Samples	
1														1.0	1.0	2	
2												0.8	0.6	1.1	0.9	4	
3														1.0	1.0	2	
4														0.9	0.8	2	
5												0.7	0.9	0.9	0.9	4	
6	0.5	0.5		0.6		0.6	0.4		0.9	0.3	0.6	0.5	0.9	1.1	1.0	12	
7												0.6	0.6	0.9	0.9	4	
8	0.6	0.4		0.6		0.5	0.5		0.8	0.3	0.5	0.5	0.7	0.9	0.9	12	
9												0.5	0.7	0.9	0.9	4	
10														0.9	0.9	2	
11														0.9	0.9	2	
12												n/a	n/a	1.2	1.0	2	
13														0.9	0.9	2	
14	0.5	0.4		0.7		0.6	0.5			0.1	0.6	0.6	1.0	0.9	1.0	11	
15	0.6	0.3		0.7		0.6	0.5		0.8	0.2	0.6	0.7	0.8	0.9	1.0	12	
16												0.4	0.7	1.0	1.0	4	
17														1.0	1.0	2	
18														1.0	0.9	2	
19												0.5	0.8	0.9	1.0	4	
20	0.5	0.6		0.7		0.7	0.5		0.7	0.1	0.5	0.5	0.8	1.0	0.9	12	
21	0.7	0.5		0.7		0.7	0.5			0.1	0.5	0.6	0.8	0.9	1.0	11	
22												0.5	0.7	0.9	0.9	4	
23														0.8	0.9	2	
24														0.9	1.0	2	
25														1.1	1.1	2	
26														0.9	1.0	2	
27														1.2	1.1	2	
28														0.9	0.9	2	
29												0.5	0.8	0.9	1.0	4	
30														0.9	0.9	2	
31														1.0	1.0	2	
Monthly Cl ₂ Avg.				0.752													
Quarterly Cl ₂ Avg.				0.717													
Yearly Cl ₂ Avg.				0.742													
Total Samples				136													

2310

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

DEQ
RESOURCE MANAGEMENT DIVISION

DEC 09 2011

For Month of November 2011

LANSING DISTRICT

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

ENTERED

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MD

Nov-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Nov-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.82					0.8	0.7	0.6	0.6			0.7	
2			0.84					0.8	0.9	0.8	0.7			0.8	
3			0.84					0.8	0.7	0.7	0.7			0.7	
4			0.83					0.7	0.8	0.6	0.7			0.7	
5			0.71					0.7	0.8	0.6	0.7			0.7	
6			0.70					0.7	0.7	0.6	0.6			0.7	
7			0.62					0.7	0.6	0.6	0.6			0.6	
8			0.66					0.7	0.7	0.6	0.6			0.7	
9			0.63					0.7	0.7	0.5	0.6			0.8	
10			0.68					0.8	0.8	0.6	0.6			0.8	
11			0.68					0.8	0.8	0.5	0.6			0.7	
12			0.63					0.6	0.8	0.5	0.5			0.7	
13			0.70					0.8	0.8	0.5	0.5			0.7	
14			0.68					0.7	0.8	0.4	0.5			0.8	
15			0.69					0.7	0.7	0.5	0.6			0.6	
16			0.64					0.6	0.7	0.5	0.5			0.6	
17			0.68					0.8	0.7	0.5	0.6			0.7	
18			0.71					0.8	0.7	0.5	0.6			0.7	
19			0.69					0.8	0.8	0.5	0.7			0.8	
20			0.68					0.7	0.7	0.7	0.6			0.7	
21			0.63					0.8	0.8	0.7	0.6			0.6	
22			0.68					0.8	0.7	0.6	0.6			0.8	
23			0.61					0.9	0.8	0.6	0.7			0.7	
24			0.62					0.8	0.8	0.7	0.6			0.7	
25			0.57					0.6	0.8	0.6	0.6			0.7	
26			0.63					0.7	0.8	0.6	0.5			0.6	
27			0.61					0.8	0.7	0.6	0.6			0.7	
28			0.61					0.9	0.9	0.6	0.6			0.7	
29			0.69					0.8	0.8	0.5	0.5			0.8	
30			0.70					0.9	0.9	0.5	0.4			0.8	
AVG			0.68					0.8	0.8	0.6	0.6			0.7	
MAX			0.84					0.9	0.9	0.8	0.7			0.8	
MIN			0.57					0.6	0.6	0.4	0.4			0.6	



Chemical Analyses

WSSN 2310

Nov-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.34		98		73		25				28.9		6.3		
2		7.20		98		68		30				28.9		6.3		
3		7.22		96		70		26				28.9		5.8		
4		7.20		96		69		27				28.9		5.8		
5		7.25		96		69		27				28.9		5.8		
6		7.23		98		72		26				28.9		6.3		
7		7.39		98		72		26				28.9		6.3		
8		7.21		100		70		30				28.9		6.8		
9		7.26		96		69		27				28.9		5.8		
10		7.27		98		70		28				28.1		6.8		
11		7.29		100		72		28				28.9		6.8		
12		7.14		98		73		25				28.9		6.3		
13		7.30		98		72		26				28.1		6.8		
14		7.29		96		68		28				28.1		6.3		
15		7.25		98		71		27				28.9		6.3		
16		7.28		98		74		24				30.5		5.3		
17		7.22		96		72		24				27.3		6.8		
18		7.28		98		71		27				28.9		6.3		
19		7.24		94		71		23				29.7		4.9		
20		7.17		98		71		27				29.7		5.8		
21		7.25		98		68		30				28.9		6.3		
22		7.30		96		70		26				28.1		6.3		
23		7.45		96		71		25				28.1		6.3		
24		7.30		98		71		27				28.9		6.3		
25		7.32		98		72		26				28.9		6.3		
26		7.31		96		72		24				28.9		5.8		
27		7.34		96		69		27				28.9		5.8		
28		7.42		98		72		26				29.7		5.8		
29		7.47		98		73		25				28.9		6.3		
30		7.38		98		73		25				28.1		6.8		
AVG		7.29		97		71		26				28.8		6.2		
MAX		7.47		100		74		30				30.5		6.8		
MIN		7.14		94		68		23				27.3		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Nov-11

D A T E	Total Coliform							Standard Plate Count		Wind Directio n	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
	60	61	62	63	64	65									
1	1/0		2/0	2/0	2/0	2/0					17.8				
2	1/0		2/0	2/0	2/0	2/0			2		18.5				
3	1/0		2/0	2/0	2/0	2/0					17.6				
4	1/0		2/0	2/0	2/0	2/0					18.3				
5	1/0		2/0	2/0	2/0	2/0					18.3				
6	1/0		2/0	2/0	2/0	2/0					18.0				
7	1/0		2/0	2/0	2/0	2/0					17.5				
8	1/0		2/0	2/0	2/0	2/0					18.7				
9	1/0		2/0	2/0	2/0	2/0					17.4				
10	1/0		2/0	2/0	2/0	2/0					16.8				
11	1/0		2/0	2/0	2/0	2/0					18.1				
12	1/0		2/0	2/0	2/0	2/0					16.9				
13	1/0		2/0	2/0	2/0	2/0					17.7				
14	1/0		2/0	2/0	2/0	2/0					18.1				
15	1/0		2/0	2/0	2/0	2/0					17.7				
16	1/0		2/0	2/0	2/0	2/0					15.5				
17	1/0		2/0	2/0	2/0	2/0					15.9				
18	1/0		2/0	2/0	2/0	2/0					15.8				
19	1/0		2/0	2/0	2/0	2/0					15.9				
20	1/0		2/0	2/0	2/0	2/0					15.7				
21	1/0		2/0	2/0	2/0	2/0					15.3				
22	1/0		2/0	2/0	2/0	2/0					15.6				
23	1/0		2/0	2/0	2/0	2/0					14.0				
24	1/0		2/0	2/0	2/0	2/0					14.8				
25	1/0		2/0	2/0	2/0	2/0					14.5				
26	1/0		2/0	2/0	2/0	2/0					15.7				
27	1/0		2/0	2/0	2/0	2/0					15.9				
28	1/0		2/0	2/0	2/0	2/0					14.1				
29	1/0		2/0	2/0	2/0	2/0					13.8				
30	1/0		2/0	2/0	2/0	2/0					14.1				
											16.5				
											18.7				
											13.8				

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				143			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

ENTERED
9310

DEQ
RESOURCE MANAGEMENT DIVISION

NOV 10 2011

For Month of October 2011

LANSING DISTRICT

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃⁺) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MD

Oct-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Oct-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.92					0.9	0.9	0.7	0.7			0.7	
2			0.86					0.9	0.9	0.9	0.8			0.8	
3			0.87					0.9	0.9	0.8	0.8			0.8	
4			0.85					0.8	1.0	0.8	0.7			0.7	
5			0.86					0.9	0.9	0.8	0.8			0.8	
6			0.82					0.9	1.0	0.8	0.8			0.9	
7			0.84					0.9	0.9	0.8	0.8			0.8	
8			0.87					0.8	0.8	0.8	0.8			0.8	
9			0.84					0.7	0.8	0.7	0.7			0.6	
10			0.81					0.8	0.7	0.7	0.7			0.6	
11			0.81					0.8	0.8	0.7	0.7			0.7	
12			0.84					0.7	0.7	0.7	0.8			0.6	
13			0.88					0.8	0.7	0.7	0.7			0.7	
14			0.86					0.6	0.7	0.5	0.6			0.6	
15			0.85					0.8	0.7	0.6	0.7			0.7	
16			0.82					0.6	0.6	0.5	0.6			0.6	
17			0.82					0.8	0.7	0.6	0.7			0.6	
18			0.81					0.9	0.6	0.6	0.6			0.7	
19			0.78					0.8	0.6	0.6	0.6			0.7	
20			0.79					0.9	0.8	0.6	0.6			0.7	
21			0.77					0.8	0.7	0.6	0.6			0.6	
22			0.78					0.8	0.7	0.6	0.7			0.6	
23			0.75					0.8	0.7	0.7	0.7			0.6	
24			0.77					0.8	0.8	0.7	0.7			0.6	
25			0.77					0.8	0.7	0.6	0.7			0.7	
26			0.76					0.8	0.7	0.7	0.7			0.7	
27			0.78					0.8	0.7	0.7	0.7			0.7	
28			0.76					0.8	0.8	0.6	0.7			0.7	
29			0.83					0.8	0.8	0.7	0.7			0.7	
30			0.77					0.8	0.7	0.7	0.7			0.7	
31			0.82					0.8	0.8	0.6	0.8			0.7	
AVG			0.82					0.8	0.8	0.7	0.7			0.7	
MAX			0.92					0.9	1.0	0.9	0.8			0.9	
MIN			0.75					0.6	0.6	0.5	0.6			0.6	



Chemical Analyses

WSSN 2310

Oct-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.21		98		71		27				28.9		6.3		
2		7.20		100		70		30				28.9		6.8		
3		7.32		100		71		29				29.7		6.3		
4		7.22		100		70		30				29.7		6.3		
5		7.22		100		70		30				30.5		5.8		
6		7.18		100		70		30				29.7		6.3		
7		7.16		94		68		26				27.3		6.3		
8		7.21		98		70		28				28.1		6.8		
9		7.16		100		70		30				28.9		6.8		
10		7.36		100		70		30				28.1		7.3		
11		7.25		98		71		27				28.9		6.3		
12		7.37		100		70		30				28.9		6.8		
13		7.24		100		69		31				28.9		6.8		
14		7.27		94		70		24				27.3		6.3		
15		7.22		100		72		28				29.7		6.3		
16		7.18		100		72		28				28.1		7.3		
17		7.21		102		70		32				29.7		6.8		
18		7.25		98		68		30				29.7		5.8		
19		7.25		98		69		29				29.7		5.8		
20		7.13		98		69		29				28.9		6.3		
21		7.31		98		71		27				28.9		6.3		
22		7.26		98		72		26				29.7		5.8		
23		7.19		100		73		27				28.9		6.8		
24		7.25		98		73		25				28.9		6.3		
25		7.31		98		70		28				28.9		6.3		
26		7.27		98		71		27				29.7		5.8		
27		7.23		98		70		28				28.9		6.3		
28		7.21		100		71		29				28.9		6.8		
29		7.32		98		72		26				29.7		5.8		
30		7.26		98		71		27				29.7		5.8		
31		7.31		98		69		29				28.9		6.3		
AVG		7.24		99		70		28				29.1		6.4		
MAX		7.37		102		73		32				30.5		7.3		
MIN		7.13		94		68		24				27.3		5.8		



Bacteriological & Physical Parameters


WSSN 2310

Oct-11

DATE	Total Coliform							Standard Plate Count		Wind Direction	Temp (deg.C)	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap		
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					18.9				
2	1/0		2/0	2/0	2/0	2/0					18.4				
3	1/0		2/0	2/0	2/0	2/0					18.0				
4	1/0		2/0	2/0	2/0	2/0					17.8				
5	1/0		2/0	2/0	2/0	2/0					18.3				
6	1/0		2/0	2/0	2/0	2/0					18.2				
7	1/0		2/0	2/0	2/0	2/0					18.2				
8	1/0		2/0	2/0	2/0	2/0					17.9				
9	1/0		2/0	2/0	2/0	2/0					17.6				
10	1/0		2/0	2/0	2/0	2/0					17.8				
11	1/0		2/0	2/0	2/0	2/0					17.6				
12	1/0		2/0	2/0	2/0	2/0					17.9				
13	1/0		2/0	2/0	2/0	2/0					18.3				
14	1/0		2/0	2/0	2/0	2/0					18.3				
15	1/0		2/0	2/0	2/0	2/0					18.0				
16	1/0		2/0	2/0	2/0	2/0					17.5				
17	1/0		2/0	2/0	2/0	2/0					17.6				
18	1/0		2/0	2/0	2/0	2/0			< 2		17.7				
19	1/0		2/0	2/0	2/0	2/0					17.5				
20	1/0		2/0	2/0	2/0	2/0					17.1				
21	1/0		2/0	2/0	2/0	2/0					17.0				
22	1/0		2/0	2/0	2/0	2/0					16.5				
23	1/0		2/0	2/0	2/0	2/0					17.0				
24	1/0		2/0	2/0	2/0	2/0					16.4				
25	1/0		2/0	2/0	2/0	2/0					17.9				
26	1/0		2/0	2/0	2/0	2/0					19.0				
27	1/0		2/0	2/0	2/0	2/0					18.7				
28	1/0		2/0	2/0	2/0	2/0					18.1				
29	1/0		2/0	2/0	2/0	2/0					18.4				
30	1/0		2/0	2/0	2/0	2/0					18.1				
31	1/0		2/0	2/0	2/0	2/0					17.3				
											17.8				
											19.0				
											16.4				

Oct-11

[illegible]

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				143			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

OCT 11 2011

2310

LANSING DISTRICT

For Month of September 2011


Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

- Low distribution system chlorine residuals from the previous months prompted the continued addition of chlorine gas at the plant. Chlorine addition continued through September 20th at a dosage range of 0.7 mg/L to 0.8 mg/L.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

Sep-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Sep-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			1.22			35	0.7	0.7	0.7	0.6	1.4			0.7	
2			1.22			40	0.8	0.8	0.7	0.6	1.4			0.7	
3			1.04			40	0.8	0.9	0.8	0.5	1.4			0.7	
4			0.98			35	0.7	0.8	0.8	0.6	1.3			0.7	
5			0.93			35	0.7	0.8	0.7	0.6	1.2			0.5	
6			1.02			35	0.7	0.8	0.7	0.5	1.3			0.5	
7			1.03			35	0.7	0.9	0.8	0.5	1.5			0.7	
8			1.05			35	0.3	0.9	0.7	0.6	1.2			0.7	
9			0.98			35	0.7	0.8	0.8	0.5	1.4			0.7	
10			1.02			35	0.7	0.8	0.8	0.5	1.5			0.8	
11			0.95			35	0.7	0.9	0.8	0.6	1.3			0.6	
12			1.00			35	0.7	0.8	0.8	0.6	1.4			1.0	
13			0.98			35	0.7	0.8	0.8	0.6	1.2			0.7	
14			1.03			35	0.7	0.8	0.7	0.6	1.3			0.9	
15			1.01			35	0.7	0.8	0.7	0.7	1.4			0.8	
16			0.97			35	0.7	0.8	0.8	0.7	1.6			0.8	
17			1.09			38	0.8	0.8	0.7	0.6	1.2			0.7	
18			1.00			40	0.8	0.8	0.8	0.6	1.4			1.0	
19			0.97			40	0.8	1.0	0.8	0.6	1.2			0.8	
20			1.01			20	0.4	0.9	0.9	0.7	1.3			0.9	
21			0.93					0.8	0.8	0.7	0.9			0.8	
22			0.91					0.9	0.7	0.7	0.6			0.8	
23			0.93					0.8	0.8	0.6	0.7			0.8	
24			0.89					0.8	0.8	0.6	0.7			0.8	
25			0.89					0.9	0.8	0.6	0.7			0.7	
26			0.88					1.0	0.8	0.7	0.7			0.7	
27			0.88					0.9	0.8	0.6	0.8			0.8	
28			0.87					0.9	0.8	0.7	0.7			0.8	
29			0.93					1.0	0.8	0.7	0.7			0.9	
30			0.94					0.8	0.9	0.7	0.8			0.8	
AVG			0.98			35	0.7	0.8	0.8	0.6	1.1			0.8	
MAX			1.22			40	0.8	1.0	0.9	0.7	1.6			1.0	
MIN			0.87			20	0.3	0.7	0.7	0.5	0.6			0.5	



Chemical Analyses

WSSN 2310

Sep-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.16		96		69		27				28.1		6.3		
2		7.23		102		70		32				28.1		7.8		
3		7.11		98		73		25				28.1		6.8		
4		7.20		100		71		29				28.9		6.8		
5		7.21		98		73		25				28.1		7.3		
6		7.31		98		70		28				28.1		7.3		
7		7.23		100		68		32				28.1		7.3		
8		7.24		98		70		28				28.1		6.8		
9		7.14		98		70		28				28.1		6.8		
10		7.41		100		72		28				29.7		6.3		
11		7.08		98		72		26				28.9		6.3		
12		7.21		100		72		28				28.9		6.8		
13		7.25		98		72		26				29.7		5.8		
14		7.27		100		70		30				28.9		6.8		
15		7.29		102		70		32				29.7		6.8		
16		7.27		98		72		26				28.9		6.3		
17		7.23		100		70		30				28.1		7.3		
18		7.26		100		70		30				28.1		7.3		
19		7.33		100		71		29				28.1		7.3		
20		7.24		100		69		31				28.9		6.8		
21		7.31		100		71		29				29.7		6.3		
22		7.18		100		70		30				28.9		6.8		
23		7.27		100		70		30				29.7		6.3		
24		7.25		100		70		30				29.7		6.3		
25		7.22		98		72		26				28.1		6.8		
26		7.28		100		71		29				28.9		6.8		
27		7.29		96		68		28				29.7		5.3		
28		7.30		98		70		28				28.9		6.3		
29		7.20		100		69		31				29.7		6.3		
30		7.27		100		69		31				29.7		6.3		
AVG		7.24		99		70		29				28.8		6.7		
MAX		7.41		102		73		32				29.7		7.8		
MIN		7.08		96		68		25				28.1		5.3		


Bacteriological & Physical Parameters
WSSN 2310
Aug-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					21.9				
2	1/0		2/0	2/0	2/0	2/0					22.4				
3	1/0		2/0	2/0	2/0	2/0					22.0				
4	1/0		2/0	2/0	2/0	2/0					22.1				
5	1/0		2/0	2/0	2/0	2/0					22.0				
6	1/0		2/0	2/0	2/0	2/0					21.7				
7	1/0		2/0	2/0	2/0	2/0					21.2				
8	1/0		2/0	2/0	2/0	2/0					21.3				
9	1/0		2/0	2/0	2/0	2/0					21.4				
10	1/0		2/0	2/0	2/0	2/0					n/a				
11	1/0		2/0	2/0	2/0	2/0					21.5				
12	1/0		2/0	2/0	2/0	2/0					21.3				
13	1/0		2/0	2/0	2/0	2/0					21.4				
14	1/0		2/0	2/0	2/0	2/0					20.9				
15	1/0		2/0	2/0	2/0	2/0		< 2			20.1				
16	1/0		2/0	2/0	2/0	2/0					20.8				
17	1/0		2/0	2/0	2/0	2/0					20.6				
18	1/0		2/0	2/0	2/0	2/0					20.6				
19	1/0		2/0	2/0	2/0	2/0					20.6				
20	1/0		2/0	2/0	2/0	2/0					20.5				
21	1/0		2/0	2/0	2/0	2/0					20.3				
22	1/0		2/0	2/0	2/0	2/0					20.4				
23	1/0		2/0	2/0	2/0	2/0					20.4				
24	1/0		2/0	2/0	2/0	2/0					20.2				
25	1/0		2/0	2/0	2/0	2/0					20.0				
26	1/0		2/0	2/0	2/0	2/0					20.0				
27	1/0		2/0	2/0	2/0	2/0					20.1				
28	1/0		2/0	2/0	2/0	2/0					19.9				
29	1/0		2/0	2/0	2/0	2/0					19.7				
30	1/0		2/0	2/0	2/0	2/0					19.5				
											20.9				
											22.4				
											19.5				


Aug-11[illegible]

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				149			
Total number of routine distribution samples required:				100			

DEQ
RESOURCE MANAGEMENT DIVISIONMONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANTSEP 19 2011
LANSING DISTRICTFor Month of August 2011Flint Water Plant
NAME OF WATER SYSTEM2310
WSSNGenesee
COUNTYMichael Glasgow
CERTIFIED OPERATORF-1R S-3
CLASSIFICATION
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

- Low distribution system chlorine residuals from the previous month prompted the addition of chlorine gas at the plant. Chlorine addition started on August 3rd at a dosage range of 0.8 to 1.2 mg/L and continued through the month. This resulted in a 1.5 mg/L free chlorine residual leaving the plant.
- After two weeks of chlorine addition at the plant the Cedar Street Reservoir residuals were still low (0.3 mg/L free) as was the surrounding distribution system. Chlorine (calcium hypochlorite) was added at the Cedar Street Reservoir from August 22nd through the 25th while the reservoir was filling. The following week a series of hydrants were flushed in the area, which has shown a dramatic improvement with residuals in the area.
- Since additional chlorine was introduced to the water supply, our 3rd quarter Disinfection By-Product monitoring will be conducted in early September.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Aug-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Aug-11

Fluoride / Chlorine & Residuals																
D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l								
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap			
		Raw	Tap	Dist				Free	Free	Free	Free			Free		
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	
1			1.09					0.8	0.6	0.5	0.5			0.5		
2			1.19					0.8	0.7	0.6	0.5			0.8		
3			1.04			50	1.0	0.8	0.7	0.6	0.9			0.5		
4			1.16			50	1.0	0.8	0.7	0.6	1.2			0.7		
5			1.09			50	1.0	0.8	0.8	0.5	0.8			0.7		
6			1.11			50	1.0	0.8	0.6	0.5	1.4			0.7		
7			1.05			50	1.0	0.8	0.6	0.5	1.1			0.7		
8			1.12			50	1.0	0.8	0.5	0.5	1.0			0.5		
9			1.10			50	1.0	0.8	0.6	0.4	1.2			0.7		
10			1.05			50	1.0	0.7	0.6	0.4	1.2			0.6		
11			1.14			50	1.0	0.7	0.6	0.4	1.2			0.7		
12			1.14			60	1.2	0.7	0.6	0.5	1.5			0.6		
13			0.99			55	1.1	0.8	0.7	0.3	1.3			0.6		
14			1.00			55	1.1	0.7	0.6	0.5	1.3			0.5		
15			0.99			55	1.1	0.7	0.6	0.4	1.3			0.5		
16			1.04			55	1.1	0.6	0.6	0.4	1.0			0.5		
17			1.08			40	0.8	0.7	0.6	0.4	1.5			0.5		
18			1.07			40	0.8	0.7	0.7	0.4	1.4			0.6		
19			1.02			45	0.9	0.7	0.7	0.5	1.3			0.6		
20			1.08			45	0.9	0.7	0.8	0.4	1.3			0.5		
21			1.05			45	0.9	0.7	0.7	0.4	1.2			0.5		
22			1.04			45	0.9	0.8	0.6	0.5	1.3			0.6		
23			1.09			45	0.9	0.8	0.6	0.5	1.2			0.6		
24			1.03			45	0.9	0.9	0.7	0.5	1.3			0.6		
25			1.14			40	0.8	0.8	0.7	0.5	1.2			0.8		
26			1.18			40	0.8	0.7	0.7	0.5	1.4			0.6		
27			1.20			40	0.8	0.9	0.7	0.6	1.5			0.7		
28			1.14			40	0.8	0.9	0.7	0.4	1.5			0.8		
29			1.17			35	0.7	0.8	0.7	0.6	1.4			0.7		
30			1.27			35	0.7	0.8	0.6	0.5	1.4			0.7		
31			1.18			40	0.8	0.8	0.7	0.5	1.3			0.6		
AVG			1.10			47	0.9	0.8	0.7	0.5	1.2			0.6		
MAX			1.27			60	1.2	0.9	0.8	0.6	1.5			0.8		
MIN			0.99			35	0.7	0.6	0.5	0.3	0.5			0.5		



Chemical Analyses

WSSN 2310

Aug-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.46		98		71		27				28.1		6.8		
2		7.31		100		69		31				28.9		6.8		
3		7.28		98		73		25				29.7		5.8		
4		7.23		100		72		28				29.7		6.3		
5		7.27		98		71		27				28.1		6.8		
6		7.27		98		71		27				28.9		6.3		
7		7.21		98		76		22				28.9		5.3		
8		7.30		98		73		25				28.1		6.8		
9		7.19		100		70		30				28.9		6.8		
10		7.28		98		71		27				29.7		5.8		
11		7.30		100		69		31				29.7		6.3		
12		7.23		96		69		27				30.5		4.9		
13		7.21		98		73		25				29.7		5.8		
14		7.20		98		73		25				28.1		6.8		
15		7.19		98		75		23				28.1		6.8		
16		7.23		100		75		25				28.9		6.8		
17		7.25		100		72		28				28.9		6.8		
18		7.25		100		71		29				28.9		6.8		
19		7.26		100		70		30				28.9		7.3		
20		7.32		100		72		28				29.7		6.3		
21		7.18		98		71		27				28.1		6.8		
22		7.41		104		73		31				28.9		7.8		
23		7.23		100		73		27				29.7		6.3		
24		7.26		98		71		27				28.9		6.3		
25		7.27		100		72		28				28.9		6.8		
26		7.29		100		70		30				28.9		6.8		
27		7.18		100		71		29				28.9		6.8		
28		7.51		100		70		30				28.9		6.8		
29		7.29		100		71		29				29.7		6.3		
30		7.25		102		71		31				29.7		6.8		
31		7.31		98		71		27				29.7		5.8		
AVG		7.27		99		72		28				29.1		6.5		
MAX		7.51		104		76		31				30.5		7.8		
MIN		7.18		96		69		22				28.1		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Aug-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					21.7				
2	1/0		2/0	2/0	2/0	2/0					20.8				
3	1/0		2/0	2/0	2/0	2/0					20.2				
4	1/0		2/0	2/0	2/0	2/0					20.1				
5	1/0		2/0	2/0	2/0	2/0					20.2				
6	1/0		2/0	2/0	2/0	2/0					19.9				
7	1/0		2/0	2/0	2/0	2/0					21.3				
8	1/0		2/0	2/0	2/0	2/0					22.1				
9	1/0		2/0	2/0	2/0	2/0		< 2			22.3				
10	1/0		2/0	2/0	2/0	2/0					22.4				
11	1/0		2/0	2/0	2/0	2/0					21.5				
12	1/0		2/0	2/0	2/0	2/0					22.2				
13	1/0		2/0	2/0	2/0	2/0					22.8				
14	1/0		2/0	2/0	2/0	2/0					22.5				
15	1/0		2/0	2/0	2/0	2/0					22.4				
16	1/0		2/0	2/0	2/0	2/0					22.3				
17	1/0		2/0	2/0	2/0	2/0					22.0				
18	1/0		2/0	2/0	2/0	2/0					22.2				
19	1/0		2/0	2/0	2/0	2/0					22.1				
20	1/0		2/0	2/0	2/0	2/0					22.4				
21	1/0		2/0	2/0	2/0	2/0					22.4				
22	1/0		2/0	2/0	2/0	2/0					22.1				
23	1/0		2/0	2/0	2/0	2/0					21.9				
24	1/0		2/0	2/0	2/0	2/0					22.3				
25	1/0		2/0	2/0	2/0	2/0					22.2				
26	1/0		2/0	2/0	2/0	2/0					21.7				
27	1/0		2/0	2/0	2/0	2/0					22.0				
28	1/0		2/0	2/0	2/0	2/0					21.8				
29	1/0		2/0	2/0	2/0	2/0					21.4				
30	1/0		2/0	2/0	2/0	2/0					21.7				
31	1/0		2/0	2/0	2/0	2/0					22.4				
											21.8				
											22.8				
											19.9				

[illegible]

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				172			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

Waste & Hazardous
Materials Division

AUG 09 2011

For Month of July 2011

Lansing District


Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

- A turbidity spike was observed on July 10th at Baxter & Potter Rd (> 0.8 NTU). The spike lasted for 24 hours. An attempt was made to divert water to Dort well to hold and allow for any settling. After 2 days of negative coliform samples the water was released on July 12th. As a result plant tap turbidities on the 12th were elevated.
- A second turbidity spike was observed on July 21st at Baxter & Potter Rd. (> 0.8 NTU). The spike lasted about an hour. An extra coliform sample was collected and both samples from the day were negative. As a result, on July 22nd, plant tap turbidities were elevated.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

Jul-11

[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Jul-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			1.05					0.8	0.8	0.6	0.7			0.7	
2			1.00					0.8	0.9	0.8	0.8			0.7	
3			1.10					0.8	0.9	0.8	0.8			0.7	
4			1.04					0.8	0.8	0.7	0.7			0.7	
5			1.01					0.8	0.8	0.7	0.7			0.8	
6			0.95					0.8	0.8	0.7	0.8			0.8	
7			0.97					0.8	0.8	0.8	0.7			0.8	
8			0.98					0.8	0.8	0.8	0.8			0.8	
9			1.05					0.8	0.8	0.7	0.8			0.8	
10			1.06					0.9	0.7	0.7	0.7			0.6	
11			1.10					0.8	0.7	0.7	0.7			0.7	
12			0.95					0.9	0.7	0.6	0.7			0.7	
13			0.88					0.8	0.9	0.5	0.7			0.7	
14			1.13					0.8	0.7	0.6	0.6			0.8	
15			1.14					0.8	0.8	0.5	0.6			0.9	
16			0.87					0.7	0.7	0.6	0.6			0.7	
17			0.92					0.7	0.7	0.6	0.6			0.6	
18			1.04					0.7	0.7	0.5	0.6			0.7	
19			1.13					0.8	0.7	0.5	0.5			0.7	
20			1.07					0.8	0.7	0.5	0.5			0.7	
21			1.15					0.7	0.8	0.5	0.6			0.8	
22			1.07					0.8	0.7	0.6	0.6			0.8	
23			1.03					0.8	0.8	0.5	0.5			0.7	
24			1.07					0.8	0.8	0.5	0.6			0.7	
25			1.12					0.8	0.8	0.6	0.7			0.8	
26			1.10					0.9	0.7	0.6	0.6			0.8	
27			1.04					0.8	0.7	0.6	0.7			0.7	
28			1.16					0.8	0.8	0.6	0.7			0.8	
29			1.21					0.8	0.7	0.6	0.7			0.7	
30			1.24					0.7	0.7	0.5	0.7			0.7	
31			1.09					0.7	0.6	0.5	0.6			0.6	
AVG			1.06					0.8	0.8	0.6	0.7			0.7	
MAX			1.24					0.9	0.9	0.8	0.8			0.9	
MIN			0.87					0.7	0.7	0.5	0.5			0.6	



Chemical Analyses

WSSN 2310

Jul-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.24		100		71		29				31.3		5.3		
2		7.20		100		71		29				30.5		5.8		
3		7.20		100		72		28				29.7		6.3		
4		7.18		102		73		29				30.5		6.3		
5		7.25		100		72		28				29.7		6.3		
6		7.28		98		69		29				28.9		6.3		
7		7.23		102		70		32				29.7		6.8		
8		7.15		102		73		29				28.9		7.3		
9		7.20		96		70		26				28.9		5.8		
10		7.29		100		73		27				29.7		6.3		
11		7.42		100		74		26				29.7		6.3		
12		7.21		100		70		30				28.9		6.8		
13		7.27		98		70		28				29.7		5.8		
14		7.36		100		70		30				29.7		6.3		
15		7.28		98		71		27				28.1		6.8		
16		7.23		98		74		24				29.7		5.8		
17		7.13		98		70		28				29.7		5.8		
18		7.33		98		71		27				29.7		5.8		
19		7.24		100		72		28				28.1		7.3		
20		7.26		98		72		26				28.9		6.3		
21		7.19		100		72		28				28.9		6.8		
22		7.27		100		72		28				28.9		6.8		
23		7.42		100		76		24				30.5		5.8		
24		7.22		98		75		23				29.7		5.8		
25		7.24		100		70		30				28.9		6.8		
26		7.30		98		69		29				28.9		6.3		
27		7.29		98		71		27				28.9		6.3		
28		7.30		100		72		28				28.1		7.3		
29		7.13		100		71		29				28.9		6.8		
30		7.18		100		71		29				28.1		7.3		
31		7.14		98		74		24				29.7		5.8		
AVG		7.25		99		72		28				29.3		6.4		
MAX		7.42		102		76		32				31.3		7.3		
MIN		7.13		96		69		23				28.1		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Jul-11

DATE	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					17.3				
2	1/0		2/0	2/0	2/0	2/0					17.1				
3	1/0		2/0	2/0	2/0	2/0					17.8				
4	1/0		2/0	2/0	2/0	2/0					17.7				
5	1/0		2/0	2/0	2/0	2/0					19.0				
6	1/0		2/0	2/0	2/0	2/0					18.5				
7	1/0		2/0	2/0	2/0	2/0					18.2				
8	1/0		2/0	2/0	2/0	2/0					18.1				
9	1/0		2/0	2/0	2/0	2/0					18.3				
10	1/0		2/0	2/0	2/0	2/0					19.4				
11	2/0		2/0	2/0	2/0	2/0					18.2				
12	1/0		2/0	2/0	2/0	2/0			< 2		18.7				
13	1/0		2/0	2/0	2/0	2/0					18.3				
14	1/0		2/0	2/0	2/0	2/0					18.4				
15	1/0		2/0	2/0	2/0	2/0					18.4				
16	1/0		2/0	2/0	2/0	2/0					18.8				
17	1/0		2/0	2/0	2/0	2/0					19.6				
18	1/0		2/0	2/0	2/0	2/0					19.8				
19	1/0		2/0	2/0	2/0	2/0					20.5				
20	1/0		2/0	2/0	2/0	2/0					20.6				
21	2/0		2/0	2/0	2/0	2/0					21.2				
22	1/0		2/0	2/0	2/0	2/0					21.1				
23	1/0		2/0	2/0	2/0	2/0					20.6				
24	1/0		2/0	2/0	2/0	2/0					20.3				
25	1/0		2/0	2/0	2/0	2/0					20.3				
26	1/0		2/0	2/0	2/0	2/0					19.1				
27	1/0		2/0	2/0	2/0	2/0					19.8				
28	1/0		2/0	2/0	2/0	2/0					21.3				
29	1/0		2/0	2/0	2/0	2/0					22.4				
30	1/0		2/0	2/0	2/0	2/0					21.9				
31	1/0		2/0	2/0	2/0	2/0					21.6				
											19.4				
											22.4				
											17.1				

[illegible]

Jul-11[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				136			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of June 2011

2310
Waste & Hazardous
Materials Division

JUL 18 2011

Lansing District

Flint Water Plant

NAME OF WATER SYSTEM

2310

WSSN

Genesee


COUNTY

Michael Glasgow

CERTIFIED OPERATOR

F-1R S-3

CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Failure to complete this form is a violation of Act 399, P.A. 1976 and is subject to penalties as outlined in the Act.

44

Jun-11[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

Jun-11

DATE	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			1.02					0.8	0.8	0.8	0.7			0.8	
2			1.07					0.8	0.9	0.8	0.8			0.8	
3			0.97					0.9	0.9	0.7	0.9			0.9	
4			1.02					0.9	0.9	0.6	0.8			0.9	
5			1.01					0.9	0.8	0.7	0.8			0.9	
6			1.04					0.8	0.9	0.7	0.8			0.8	
7			1.09					0.9	0.8	0.7	0.8			0.9	
8			1.09					0.9	0.8	0.7	0.8			0.8	
9			0.99					0.9	0.9	0.7	0.8			0.8	
10			1.10					0.9	0.8	0.8	0.8			0.8	
11			1.04					0.9	0.8	0.8	0.8			0.8	
12			1.05					0.8	0.8	0.8	0.8			0.7	
13			1.07					0.8	0.8	0.8	0.8			0.8	
14			1.13					0.8	0.8	0.8	0.7			0.8	
15			1.07					0.9	0.8	0.7	0.8			0.8	
16			1.09					0.9	0.8	0.7	0.8			0.8	
17			1.08					0.9	0.8	0.7	0.8			0.9	
18			1.05					0.9	0.8	0.7	0.8			0.8	
19			1.12					0.8	0.8	0.8	0.8			0.7	
20			1.08					0.8	0.8	0.7	0.7			0.8	
21			1.07					0.8	0.8	0.8	0.8			0.7	
22			1.06					0.9	0.9	0.8	0.7			0.8	
23			1.04					0.9	0.8	0.8	0.7			0.9	
24			1.11					0.8	0.8	0.7	0.8			0.8	
25			1.08					0.8	0.8	0.7	0.8			0.8	
26			1.07					0.8	0.7	0.6	0.7			0.7	
27			1.05					0.8	0.8	0.7	0.8			0.7	
28			1.03					0.9	0.8	0.7	0.7			0.8	
29			1.12					0.8	0.8	0.7	0.7			0.8	
30			1.13					0.8	0.8	0.7	0.8			0.7	
AVG			1.06					0.9	0.8	0.7	0.8			0.8	
MAX			1.13					0.9	0.9	0.8	0.9			0.9	
MIN			0.97					0.8	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Jun-11

DATE	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.24		98		73		25				30.5		5.3		
2		7.27		96		71		25				31.3		4.4		
3		7.31		98		71		27				28.1		6.8		
4		7.37		100		69		31				28.9		6.8		
5		7.25		98		71		27				28.9		6.3		
6		7.19		98		69		29				29.7		5.8		
7		7.21		98		71		27				29.7		5.8		
8		7.18		98		72		26				28.9		6.3		
9		7.19		98		71		27				30.5		5.3		
10		7.28		98		70		28				28.1		6.8		
11		7.16		100		68		32				28.1		7.3		
12		7.17		96		69		27				28.1		6.3		
13		7.28		96		70		26				28.9		5.8		
14		7.24		98		72		26				31.3		4.9		
15		7.20		96		69		27				28.1		6.3		
16		7.26		98		71		27				28.9		6.3		
17		7.22		96		68		28				28.9		5.8		
18		7.26		96		70		26				28.1		6.3		
19		7.45		98		70		28				29.7		5.8		
20		7.25		100		71		29				28.9		6.8		
21		7.41		98		72		26				29.7		5.8		
22		7.21		100		70		30				28.1		7.3		
23		7.29		98		69		29				29.7		5.8		
24		7.20		98		72		26				28.9		6.3		
25		7.28		100		72		28				28.9		6.8		
26		7.20		98		74		24				29.7		5.8		
27		7.26		98		72		26				29.7		5.8		
28		7.30		100		71		29				28.1		7.3		
29		7.20		98		70		28				28.1		6.8		
30		7.35		98		73		25				32.1		4.4		
AVG		7.26		98		71		27				29.2		6.1		
MAX		7.45		100		74		32				32.1		7.3		
MIN		7.16		96		68		24				28.1		4.4		



Bacteriological & Physical Parameters

WSSN 2310

Jun-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					13.3				
2	1/0		2/0	2/0	2/0	2/0					13.3				
3	1/0		2/0	2/0	2/0	2/0					13.9				
4	1/0		2/0	2/0	2/0	2/0					14.2				
5	1/0		2/0	2/0	2/0	2/0					14.3				
6	1/0		2/0	2/0	2/0	2/0					14.0				
7	1/0		2/0	2/0	2/0	2/0			<2		17.3				
8	1/0		2/0	2/0	2/0	2/0					15.9				
9	1/0		2/0	2/0	2/0	2/0					16.5				
10	1/0		2/0	2/0	2/0	2/0					15.5				
11	1/0		2/0	2/0	2/0	2/0					15.1				
12	1/0		1/0	1/0	1/0	1/0					15.0				
13	1/0		2/0	2/0	2/0	2/0					14.9				
14	1/0		2/0	2/0	2/0	2/0					15.3				
15	1/0		2/0	2/0	2/0	2/0					15.9				
16	1/0		2/0	2/0	2/0	2/0					16.5				
17	1/0		2/0	2/0	2/0	2/0					17.3				
18	1/0		2/0	2/0	2/0	2/0					17.0				
19	1/0		2/0	2/0	2/0	2/0					15.8				
20	1/0		2/0	2/0	2/0	2/0					16.9				
21	1/0		2/0	2/0	2/0	2/0					16.4				
22	1/0		2/0	2/0	2/0	2/0					17.3				
23	1/0		2/0	2/0	2/0	2/0					18.3				
24	1/0		2/0	2/0	2/0	2/0					18.0				
25	1/0		2/0	2/0	2/0	2/0					17.6				
26	1/0		2/0	2/0	2/0	2/0					16.7				
27	1/0		2/0	2/0	2/0	2/0					15.7				
28	1/0		2/0	2/0	2/0	2/0					17.6				
29	1/0		2/0	2/0	2/0	2/0					17.0				
30	1/0		2/0	2/0	2/0	2/0					15.2				
											15.9				
											18.3				
											13.3				

Jun-11[illegible]

Jun-11[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				150			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

JUN 09 2011

Lansing District

For Month of May 2011


Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

May-11[illegible]



Flouride / Chlorination & Residuals

WSSN 2310

May-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Post Chlorine lbs/day	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			1.00					0.8	0.8	0.8	0.8			0.8	
2			1.01					0.8	0.8	0.8	0.8			0.8	
3			1.11					0.8	0.8	0.8	0.9			0.8	
4			1.02					0.9	0.9	0.8	0.9			0.9	
5			1.01					0.9	0.9	0.8	0.8			0.9	
6			1.06					0.9	0.8	0.8	0.8			0.9	
7			1.04					0.7	0.9	0.8	0.8			0.7	
8			1.04					0.7	0.9	0.8	0.8			0.7	
9			1.01					0.8	0.8	0.8	0.8			0.7	
10			1.03					0.8	0.9	0.8	0.8			0.9	
11			1.06					0.9	0.8	0.8	0.9			0.9	
12			0.95					0.8	0.8	0.8	0.8			0.7	
13			1.04					0.9	0.9	0.8	0.8			0.9	
14			1.05					0.8	0.9	0.7	0.8			0.9	
15			0.89					0.7	0.8	0.7	0.7			0.7	
16			0.90					0.7	0.7	0.7	0.7			0.7	
17			1.02					0.8	0.8	0.8	0.7			0.8	
18			0.95					0.9	0.8	0.7	0.8			0.8	
19			0.96					0.8	0.9	0.7	0.7			1.0	
20			0.99					1.0	0.9	0.8	0.9			1.0	
21			0.99					0.9	0.9	0.8	0.9			0.9	
22			1.03					0.8	0.9	0.8	0.8			0.8	
23			1.05					0.7	0.8	0.8	0.8			0.8	
24			0.95					0.8	0.8	0.8	0.8			0.8	
25			1.02					0.8	0.9	0.8	0.7			0.8	
26			0.99					0.9	0.9	0.8	0.9			0.8	
27			0.99					0.9	0.9	0.8	0.8			0.9	
28			1.02					0.9	0.7	0.8	0.8			0.7	
29			0.99					0.8	0.9	0.8	0.7			0.8	
30			1.01					0.8	0.8	0.8	0.9			0.8	
31			1.03					0.9	0.9	0.8	0.9			0.8	
AVG			1.01					0.8	0.8	0.8	0.8			0.8	
MAX			1.11					1.0	0.9	0.8	0.9			1.0	
MIN			0.89					0.7	0.7	0.7	0.7			0.7	



Chemical Analyses

WSSN 2310

May-11

D A T E	pH		Total Hardness (mg/L CaCO ₃)		Total Alkalinity (mg/L CaCO ₃)		Non-Carbonate Hardness (mg/L CaCO ₃)				Calcium (mg/l Ca 2+)		Magnesium (mg/l Mg 2+)		Chloride as (mg/l Cl -)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.13		98		69		29				28.9		6.3		
2		7.21		100		69		31				28.9		6.8		
3		7.24		96		71		25				29.7		5.3		
4		7.26		96		69		27				28.9		5.8		
5		7.18		98		69		29				31.3		4.9		
6		7.19		96		67		29				32.9		3.4		
7		7.24		96		69		27				29.7		5.3		
8		7.13		96		72		24				29.7		5.8		
9		7.30		96		65		31				29.7		5.3		
10		7.12		96		69		27				29.7		5.3		
11		7.22		98		69		29				29.7		5.8		
12		7.23		96		70		26				28.9		5.8		
13		7.19		100		68		32				29.7		6.3		
14		7.35		100		70		30				31.3		5.3		
15		7.15		96		76		20				29.7		5.3		
16		7.45		96		71		25				30.5		4.9		
17		7.21		98		71		27				32.1		4.4		
18		7.44		100		73		27				28.9		6.8		
19		7.05		100		70		30				29.7		6.3		
20		7.15		98		71		27				31.3		4.9		
21		7.08		100		71		29				30.5		5.8		
22		7.18		100		74		26				31.3		5.3		
23		7.19		100		74		26				29.7		6.3		
24		7.24		100		75		25				30.5		5.8		
25		7.14		100		69		31				29.7		6.3		
26		7.27		100		74		26				31.3		5.3		
27		7.38		100		71		29				29.7		6.3		
28		7.19		98		74		24				30.5		5.3		
29		7.21		98		75		23				30.5		5.3		
30		7.13		98		72		26				28.9		6.3		
31		7.18		98		72		26				28.9		6.3		
AVG		7.21		98		71		27				30.1		5.6		
MAX		7.45		100		76		32				32.9		6.8		
MIN		7.05		96		65		20				28.9		3.4		



Bacteriological & Physical Parameters

WSSN 2310

May-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					11.7				
2	1/0		2/0	2/0	2/0	2/0					11.3				
3	1/0		2/0	2/0	2/0	2/0					11.8				
4	1/0		2/0	2/0	2/0	2/0					13.2				
5	1/0		2/0	2/0	2/0	2/0					12.5				
6	1/0		2/0	2/0	2/0	2/0					10.9				
7	1/0		2/0	2/0	2/0	2/0					12.1				
8	1/0		2/0	2/0	2/0	2/0					11.3				
9	1/0		2/0	2/0	2/0	2/0					10.8				
10	1/0		2/0	2/0	2/0	2/0					12.5				
11	1/0		2/0	2/0	2/0	2/0					12.5				
12	1/0		2/0	2/0	2/0	2/0					12.5				
13	1/0		2/0	2/0	2/0	2/0					12.2				
14	1/0		2/0	2/0	2/0	2/0					13.3				
15	1/0		2/0	2/0	2/0	2/0					11.8				
16	1/0		2/0	2/0	2/0	2/0					12.6				
17	1/0		2/0	2/0	2/0	2/0					12.4				
18	1/0		2/0	2/0	2/0	2/0					11.9				
19	1/0		2/0	2/0	2/0	2/0					12.9				
20	1/0		2/0	2/0	2/0	2/0					12.6				
21	1/0		2/0	2/0	2/0	2/0					13.5				
22	1/0		2/0	2/0	2/0	2/0					12.2				
23	1/0		2/0	2/0	2/0	2/0					12.3				
24	1/0		2/0	2/0	2/0	2/0					12.6				
25	1/0		2/0	2/0	2/0	2/0			2		12.6				
26	1/0		2/0	2/0	2/0	2/0					12.5				
27	1/0		2/0	2/0	2/0	2/0					12.8				
28	1/0		2/0	2/0	2/0	2/0					12.0				
29	1/0		2/0	2/0	2/0	2/0					12.5				
30	1/0		2/0	2/0	2/0	2/0					13.1				
31	1/0		2/0	2/0	2/0	2/0					14.3				
											12.4				
											14.3				
											10.8				

May-11[illegible]

May-11

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				142			
Total number of routine distribution samples required:				100			

2310

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

Waste & Hazardous
Materials Division

MAY 10 2011

For Month of April 2011

Lansing District

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Failure to complete this form is a violation of Act 399, P.A. 1976 and is subject to penalties as outlined in the Act.

MP

Apr-11

DATE	Total Million Gallons Purchased	Million Gallons to County	Million Gallons to Flint			Ferric Chloride as Fe 3+ mg/l	Turbidity, NTU units						
							Raw				Plant Tap		
							# of Samples	Avg.	Max		# of Samples	Avg.	Max
1	1A	1B	4	5	6	7	8	9	10	11	12	13	
1	24.58	10.11	14.47								3	0.08	0.09
2	24.09	9.85	14.24								3	0.07	0.08
3	23.51	9.92	13.59								3	0.08	0.08
4	24.34	9.72	14.62								3	0.08	0.08
5	25.38	9.76	15.62								3	0.11	0.13
6	24.30	9.64	14.66								3	0.08	0.09
7	23.74	9.65	14.09								3	0.08	0.09
8	23.52	9.68	13.84								3	0.09	0.10
9	23.69	9.76	13.93								3	0.07	0.08
10	23.67	9.53	14.14								3	0.08	0.09
11	23.68	9.41	14.27								3	0.09	0.09
12	24.52	9.66	14.86								3	0.13	0.19
13	24.58	9.57	15.01								3	0.11	0.11
14	24.66	9.40	15.26								3	0.15	0.15
15	23.96	9.78	14.18								3	0.09	0.10
16	24.10	9.78	14.32								3	0.08	0.09
17	23.67	9.76	13.91								3	0.10	0.11
18	24.33	9.71	14.62								3	0.10	0.11
19	24.06	9.75	14.31								3	0.09	0.10
20	24.39	9.90	14.49								3	0.08	0.09
21	24.05	9.97	14.08								3	0.09	0.10
22	23.78	9.87	13.91								3	0.10	0.11
23	23.68	9.82	13.86								3	0.09	0.10
24	23.25	9.56	13.69								3	0.08	0.09
25	23.06	9.41	13.65								3	0.08	0.08
26	24.05	9.58	14.47								3	0.12	0.15
27	25.24	9.76	15.48								3	0.10	0.13
28	24.72	9.82	14.90								3	0.10	0.12
29	25.05	10.16	14.89								3	0.11	0.12
30	25.00	10.44	14.56								3	0.12	0.13
AVG	24.15	9.76	14.40								3	0.09	0.11
MAX	25.38	10.44	15.62								3	0.15	0.19
MIN	23.06	9.40	13.59								3	0.07	0.08
Total	724.64	292.73	431.92										



Flouridation & Chlorination

WSSN 2310

Apr-11

DATE	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.93					0.9	1.0	0.9	0.9			1.0	
2			0.93					0.9	1.0	0.9	0.9			0.9	
3			0.98					0.9	0.9	0.8	1.0			0.9	
4			0.93					0.8	0.9	0.9	0.9			0.9	
5			0.96					0.9	0.8	0.8	0.9			0.9	
6			0.95					0.9	0.8	0.8	0.8			0.8	
7			0.96					0.9	0.9	0.9	0.9			0.9	
8			0.93					0.9	0.8	0.8	0.9			0.9	
9			0.92					0.9	0.9	0.8	0.9			0.9	
10			0.98					0.9	0.9	0.9	0.8			0.9	
11			1.01					0.9	0.9	0.8	0.8			0.9	
12			0.93					0.9	0.9	0.8	0.8			0.9	
13			0.97					0.9	0.9	0.9	0.9			0.9	
14			0.91					0.9	0.9	0.9	0.8			0.9	
15			0.86					0.9	0.9	0.8	0.9			0.9	
16			0.87					0.9	0.8	0.8	0.8			0.9	
17			1.03					0.8	0.9	0.8	0.8			0.8	
18			1.18					0.8	0.9	0.8	0.8			0.9	
19			1.17					0.9	0.9	0.8	0.8			0.8	
20			1.05					0.8	0.8	0.7	0.7			0.7	
21			1.15					0.7	0.6	0.7	0.8			0.9	
22			1.14					0.8	0.8	0.8	0.8			0.8	
23			1.12					0.9	0.8	0.7	0.8			0.8	
24			1.03					0.8	0.8	0.8	0.8			0.7	
25			1.03					0.8	0.8	0.8	0.8			0.8	
26			1.03					0.8	0.8	0.8	0.8			0.9	
27			1.05					0.9	1.0	0.7	0.8			1.0	
28			1.00					0.8	0.9	0.7	0.7			0.8	
29			1.00					0.7	0.8	0.8	0.8			0.9	
30			1.07					1.0	0.9	0.8	0.8			0.9	
AVG			1.00					0.9	0.9	0.8	0.8			0.9	
MAX			1.18					1.0	1.0	0.9	1.0			1.0	
MIN			0.86					0.7	0.6	0.7	0.7			0.7	



Chemical Analyses

WSSN 2310

Apr-11

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.12		96		69		27				25.7		7.8		
2		7.41		96		70		26				29.7		5.3		
3		7.16		100		72		28				29.7		6.3		
4		7.32		98		69		29				27.3		7.3		
5		7.19		100		69		31				27.3		7.8		
6		7.26		96		72		24				28.1		6.3		
7		7.14		96		67		29				28.1		6.3		
8		7.16		96		65		31				28.1		6.3		
9		7.16		98		68		30				28.1		6.8		
10		7.11		96		71		25				28.9		5.8		
11		7.34		96		72		24				28.9		5.8		
12		7.21		98		69		29				28.9		6.3		
13		7.36		98		68		30				28.1		6.8		
14		7.29		100		68		32				28.9		6.8		
15		7.30		98		69		29				27.3		7.3		
16		7.20		98		70		28				28.9		6.3		
17		7.17		98		70		28				28.9		6.3		
18		7.17		96		68		28				28.9		5.8		
19		7.11		100		68		32				28.1		7.3		
20		7.20		98		71		27				28.9		6.3		
21		7.11		102		70		32				28.1		7.8		
22		7.24		98		70		28				28.1		6.8		
23		7.24		100		70		30				27.3		7.8		
24		7.20		96		70		26				28.9		5.8		
25		7.26		100		68		32				28.1		7.3		
26		7.26		96		71		25				29.7		5.3		
27		7.24		98		71		27				31.3		4.9		
28		7.25		100		71		29				31.3		5.3		
29		7.24		102		71		31				31.3		5.8		
30		7.24		106		70		36				31.3		6.8		
AVG		7.22		98		70		29				28.7		6.5		
MAX		7.41		106		72		36				31.3		7.8		
MIN		7.11		96		65		24				25.7		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Apr-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					9.7				
2	1/0		2/0	2/0	2/0	2/0					8.3				
3	1/0		2/0	2/0	2/0	2/0					9.7				
4	1/0		2/0	2/0	2/0	2/0					10.7				
5	1/0		2/0	2/0	2/0	2/0					9.5				
6	1/0		2/0	2/0	2/0	2/0					9.4				
7	1/0		2/0	2/0	2/0	2/0			< 2		9.5				
8	1/0		2/0	2/0	2/0	2/0					9.4				
9	1/0		2/0	2/0	2/0	2/0					10.4				
10	1/0		2/0	2/0	2/0	2/0					9.4				
11	1/0		2/0	2/0	2/0	2/0					10.1				
12	1/0		2/0	2/0	2/0	2/0					10.5				
13	1/0		2/0	2/0	2/0	2/0					10.5				
14	1/0		2/0	2/0	2/0	2/0					9.2				
15	1/0		2/0	2/0	2/0	2/0					9.7				
16	1/0		2/0	2/0	2/0	2/0					8.7				
17	1/0		2/0	2/0	2/0	2/0					9.1				
18	1/0		2/0	2/0	2/0	2/0					8.0				
19	1/0		2/0	2/0	2/0	2/0					9.4				
20	1/0		2/0	2/0	2/0	2/0					8.4				
21	1/0		2/0	2/0	2/0	2/0					9.4				
22	1/0		2/0	2/0	2/0	2/0					9.3				
23	1/0		2/0	2/0	2/0	2/0					11.6				
24	1/0		2/0	2/0	2/0	2/0					12.1				
25	1/0		2/0	2/0	2/0	2/0					11.7				
26	1/0		2/0	2/0	2/0	2/0					10.4				
27	1/0		2/0	2/0	2/0	2/0					11.4				
28	1/0		2/0	2/0	2/0	2/0					11.6				
29	1/0		2/0	2/0	2/0	2/0					10.8				
30	1/0		2/0	2/0	2/0	2/0					11.6				
											10.0				
											12.1				
											8.0				

Apr-11

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				143			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

Water & Wastewater
Division

APR 15 2011

Lansing District

For Month of March 2011

Flint Water Plant

2310

Genesee

NAME OF WATER SYSTEM

WSSN

COUNTY

Michael Glasgow

F-1R S-3

CERTIFIED OPERATOR

CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Mar-11

[illegible]



Flouridation & Chlorination

WSSN 2310

Mar-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l		Chlorine Residual mg/l								
		Raw	Tap	Dist		Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well			Tap	
								Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.74					1.0	0.9	0.9	1.0			1.1	
2			0.65					0.9	1.0	1.0	0.9			0.9	
3			0.74					0.9	1.0	1.0	1.0			1.0	
4			0.72					0.9	1.0	0.8	0.9			1.0	
5			0.73					1.0	1.0	0.9	1.0			0.9	
6			0.71					1.0	1.0	0.8	0.8			1.0	
7			0.76					0.9	1.0	1.0	1.0			1.0	
8			0.73					1.0	1.0	0.9	1.0			1.0	
9			0.73					1.0	1.0	1.0	1.0			0.9	
10			0.70					1.0	1.1	1.0	0.9			1.0	
11			0.68					0.9	0.9	0.9	0.9			1.0	
12			0.67					0.9	0.9	0.9	0.9			0.9	
13			0.67					0.9	0.9	0.8	0.9			0.8	
14			0.77					0.9	1.0	0.9	0.9			0.9	
15			0.90					1.0	0.9	0.9	0.9			1.0	
16			0.93					0.9	1.0	0.9	0.9			0.9	
17			0.96					0.9	0.9	0.9	0.8			1.0	
18			1.06					0.9	0.9	0.9	0.9			1.0	
19			1.05					0.9	0.9	0.9	0.9			0.9	
20			1.04					0.9	0.9	0.9	1.0			0.9	
21			1.05					0.9	1.0	0.8	1.0			0.8	
22			1.02					0.9	1.0	0.9	0.9			0.9	
23			1.00					0.9	1.0	0.9	1.0			1.0	
24			0.96					0.9	0.9	0.9	1.0			1.0	
25			0.99					0.8	0.9	0.9	1.0			1.0	
26			0.99					0.9	0.9	0.9	1.0			1.0	
27			0.99					0.9	0.9	0.9	0.9			0.9	
28			0.89					1.0	1.0	0.9	0.9			0.9	
29			0.96					1.0	1.0	0.9	0.9			0.9	
30			0.90					0.9	1.1	0.9	0.9			1.0	
31			0.86					1.0	1.0	1.0	1.0			0.9	
AVG			0.86					0.9	1.0	0.9	0.9			0.9	
MAX			1.06					1.0	1.1	1.0	1.0			1.1	
MIN			0.65					0.8	0.9	0.8	0.8			0.8	



Chemical Analyses

WSSN 2310

Mar-11

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.22		92		70		22				28.9		4.9		
2		7.26		98		75		23				28.9		6.3		
3		7.13		100		71		29				28.1		7.3		
4		7.39		100		76		24				29.7		6.3		
5		7.23		98		65		33				30.5		5.3		
6		7.37		98		77		21				30.5		5.3		
7		7.18		98		74		24				29.7		5.8		
8		7.20		98		71		27				28.9		6.3		
9		7.23		98		71		27				30.5		5.3		
10		7.21		96		70		26				28.9		5.8		
11		7.16		102		72		30				27.3		8.3		
12		7.15		102		70		32				28.9		7.3		
13		7.19		96		72		24				28.9		5.8		
14		7.34		96		74		22				28.9		5.8		
15		7.24		100		71		29				28.1		7.3		
16		7.31		98		70		28				28.9		6.3		
17		7.21		100		68		32				28.9		6.8		
18		7.28		96		67		29				28.9		5.8		
19		7.20		98		71		27				28.1		6.8		
20		7.17		96		67		29				28.1		6.3		
21		7.27		98		70		28				28.1		6.8		
22		7.25		96		67		29				28.1		6.3		
23		7.20		100		69		31				28.1		7.3		
24		7.33		96		67		29				27.3		6.8		
25		7.33		94		70		24				27.3		6.3		
26		7.34		96		67		29				28.1		6.3		
27		7.19		96		70		26				28.9		5.8		
28		7.27		96		70		26				28.1		6.3		
29		7.34		98		66		32				29.7		5.8		
30		7.24		96		68		28				25.7		7.8		
31		7.14		100		69		31				28.1		7.3		
AVG		7.24		98		70		27				28.6		6.4		
MAX		7.39		102		77		33				30.5		8.3		
MIN		7.13		92		65		21				25.7		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Mar-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0				11.3					
2	1/0		2/0	2/0	2/0	2/0				10.7					
3	1/0		2/0	2/0	2/0	2/0				10.1					
4	1/0		2/0	2/0	2/0	2/0				N/A					
5	1/0		2/0	2/0	2/0	2/0				11.1					
6	1/0		1/0	1/0	1/0	1/0				N/A					
7	1/0		2/0	2/0	2/0	2/0				8.9					
8	1/0		2/0	2/0	2/0	2/0				12.1					
9	1/0		2/0	2/0	2/0	2/0				9.5					
10	1/0		2/0	2/0	2/0	2/0				9.5					
11	1/0		2/0	2/0	2/0	2/0				8.6					
12	1/0		2/0	2/0	2/0	2/0				10.5					
13	1/0		2/0	2/0	2/0	2/0				9.2					
14	1/0		2/0	2/0	2/0	2/0				8.9					
15	1/0		2/0	2/0	2/0	2/0				10.2					
16	1/0		2/0	2/0	2/0	2/0				9.4					
17	1/0		2/0	2/0	2/0	2/0		< 2		10.5					
18	1/0		2/0	2/0	2/0	2/0				11.5					
19	1/0		2/0	2/0	2/0	2/0				10.9					
20	1/0		2/0	2/0	2/0	2/0				10.4					
21	1/0		2/0	2/0	2/0	2/0				11.7					
22	1/0		2/0	2/0	2/0	2/0				10.4					
23	1/0		2/0	2/0	2/0	2/0				11.3					
24	1/0		2/0	2/0	2/0	2/0				10.6					
25	1/0		2/0	2/0	2/0	2/0				11.1					
26	1/0		2/0	2/0	2/0	2/0				10.2					
27	1/0		2/0	2/0	2/0	2/0				9.7					
28	1/0		2/0	2/0	2/0	2/0				9.0					
29	1/0		2/0	2/0	2/0	2/0				8.6					
30	1/0		2/0	2/0	2/0	2/0				10.3					
31	1/0		2/0	2/0	2/0	2/0				9.4					
											10.2				
											12.1				
											8.6				

[illegible]

[illegible]

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

Waste & Hazardous
Materials Division

For Month of February 2011

MAR 09 2011

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Lansing District
Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Failure to complete this form is a violation of Act 399, P.A. 1976 and is subject to penalties as outlined in the Act.

NP

Feb-11

[illegible]



Flouridation & Chlorination

WSSN 2310

Feb-11

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCI-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.85					1.0	1.0	0.9	1.0			1.0	
2			0.85					0.9	1.0	0.9	1.0			1.0	
3			0.82					0.9	1.0	0.9	1.1			1.0	
4			0.83					0.9	1.0	0.9	1.0			1.0	
5			0.79					0.9	1.0	0.9	0.9			1.1	
6			0.78					0.9	0.9	0.9	0.8			0.9	
7			0.92					0.9	1.0	0.9	0.9			0.9	
8			1.02					0.9	0.9	0.9	1.0			0.9	
9			0.95					1.0	0.9	0.9	0.9			0.9	
10			1.00					0.9	0.9	0.9	1.0			0.9	
11			1.06					0.9	1.0	0.7	0.8			1.0	
12			1.09					0.9	0.9	0.8	0.8			0.9	
13			1.16					0.9	1.0	0.8	0.9			1.0	
14			1.17					1.0	1.1	0.9	1.0			1.0	
15			1.01					0.9	1.0	0.9	0.9			1.0	
16			0.90					0.9	1.1	0.9	1.0			1.0	
17			1.01					1.0	1.0	0.9	1.0			1.0	
18			1.05					1.0	1.1	0.9	1.0			1.1	
19			1.02					1.0	1.1	0.9	1.0			1.1	
20			1.02					1.0	1.0	1.0	0.9			1.0	
21			1.15					1.0	1.0	0.9	0.9			1.0	
22			0.90					1.0	1.0	0.9	1.0			1.0	
23			0.98					0.9	1.1	0.9	1.0			1.0	
24			0.80					1.0	1.0	0.9	0.9			1.0	
25			0.76					1.0	1.0	0.9	1.0			1.0	
26			0.76					0.9	1.0	0.9	0.9			0.9	
27			0.78					1.0	1.0	0.9	0.9			1.0	
28			0.81					0.9	0.9	0.9	0.9			0.8	
AVG			0.94					0.9	1.0	0.9	0.9			1.0	
MAX			1.17					1.0	1.1	1.0	1.1			1.1	
MIN			0.76					0.9	0.9	0.7	0.8			0.8	



Chemical Analyses

WSSN 2310

Feb-11

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.23		96		70		26				27.3		6.3		
2		7.19		100		67		33				27.3		7.8		
3		7.26		100		70		30				28.9		6.8		
4		7.26		102		71		31				28.9		7.3		
5		7.39		102		80		22				30.5		5.8		
6		7.19		98		68		30				29.7		5.8		
7		7.23		98		79		19				30.5		5.3		
8		7.40		98		74		24				29.7		5.8		
9		7.29		98		69		29				28.9		6.3		
10		7.37		98		72		26				30.5		4.9		
11		7.24		100		72		28				29.7		6.3		
12		7.23		96		71		25				29.7		5.3		
13		7.21		96		72		24				28.1		6.3		
14		7.30		98		71		27				28.9		6.3		
15		7.32		90		68		22				27.3		5.3		
16		7.28		96		69		27				29.7		5.3		
17		7.20		98		67		31				27.3		7.3		
18		7.23		98		65		33				27.3		7.3		
19		7.19		98		66		32				26.5		7.8		
20		7.15		96		68		28				27.3		6.8		
21		7.27		98		72		26				28.9		6.3		
22		7.12		92		66		26				27.3		5.8		
23		7.25		96		67		29				28.1		6.3		
24		7.12		96		67		29				27.3		6.8		
25		7.19		98		67		31				28.1		6.8		
26		7.23		96		71		25				28.1		6.3		
27		7.25		96		69		27				28.9		5.8		
28		7.35		98		69		29				28.9		6.3		
AVG		7.25		97		70		27				28.6		6.3		
MAX		7.40		102		80		33				30.5		7.8		
MIN		7.12		90		65		19				26.5		4.9		

Feb-11

[illegible]



Bacteriological & Physical Parameters

WSSN 2310

Feb-11

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
	60	61	62	63	64	65									
1	1/0		2/0	2/0	2/0						13.9				
2	1/0		2/0	2/0	2/0						14.0				
3	1/0		2/0	2/0	2/0						14.4				
4	1/0		2/0	2/0	2/0						14.8				
5	1/0		2/0	2/0	2/0						N/A				
6	1/0		2/0	2/0	2/0						13.1				
7	1/0		2/0	2/0	2/0						11.4				
8	1/0		2/0	2/0	2/0						11.9				
9	1/0		2/0	2/0	2/0						11.0				
10	1/0		2/0	2/0	2/0						9.9				
11	1/0		1/0	1/0	1/0						9.6				
12	1/0		2/0	2/0	2/0						9.9				
13	1/0		2/0	2/0	2/0						9.7				
14	1/0		2/0	2/0	2/0						9.5				
15	1/0		2/0	2/0	2/0						11.2				
16	1/0		2/0	2/0	2/0						10.1				
17	1/0		2/0	2/0	2/0				2		11.3				
18	1/0		2/0	2/0	2/0						9.3				
19	1/0		2/0	2/0	2/0						10.9				
20	1/0		2/0	2/0	2/0						10.5				
21	1/0		2/0	2/0	2/0						10.8				
22	1/0		2/0	2/0	2/0						10.3				
23	1/0		2/0	2/0	2/0						9.7				
24	1/0		2/0	2/0	2/0						11.3				
25	1/0		2/0	2/0	2/0						12.1				
26	1/0		2/0	2/0	2/0						10.8				
27	1/0		2/0	2/0	2/0						8.9				
28	1/0		2/0	2/0	2/0						11.6				
											11.2				
											14.8				
											8.9				

Feb-11

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				133			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

FEB 14 2011

Lansing District

For Month of January 2011


Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Brent F. Wright
CERTIFIED OPERATOR

F-2 S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

Dec-10

[illegible]



Flouridation & Chlorination

WSSN 2310

Dec-10

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	
1			1.12					1.0	1.1	0.9	1.1			1.2	
2			1.14					0.9	1.0	1.0	1.0			1.1	
3			1.17					1.0	1.0	0.9	1.1			1.0	
4			1.19					1.0	0.8	0.9	1.0			0.9	
5			1.05					1.1	1.0	0.9	1.0			0.9	
6			1.01					1.0	0.9	0.9	0.9			1.0	
7			1.03					1.0	1.0	0.9	1.0			1.0	
8			N/A					0.9	0.9	0.7	0.9			1.0	
9			0.99					1.0	1.0	0.8	1.0			1.1	
10			1.05					0.8	1.0	0.9	1.0			1.0	
11			1.03					1.0	1.0	0.9	1.0			1.0	
12			1.06					1.0	1.0	1.0	1.0			1.0	
13			1.05					1.0	1.0	1.0	0.9			1.0	
14			1.06					0.9	1.0	0.9	0.9			1.0	
15			1.05					1.1	1.0	0.9	1.0			1.0	
16			0.94					1.0	1.0	0.9	1.1			1.0	
17			1.02					1.0	1.0	0.9	1.0			1.0	
18			1.07					0.9	1.0	0.9	1.0			1.0	
19			1.03					0.9	1.0	0.9	1.0			1.0	
20			1.03					0.9	1.0	0.9	1.0			1.1	
21			1.04					0.9	0.9	0.8	0.9			1.0	
22			0.98					1.0	0.9	0.9	0.9			1.0	
23			0.99					0.9	1.0	0.8	0.9			1.0	
24			1.02					0.9	1.1	0.9	1.0			1.1	
25			0.97					0.9	1.0	0.9	1.0			1.0	
26			0.99					0.9	1.1	0.9	1.0			1.0	
27			0.93					0.9	1.1	0.9	1.1			1.0	
28			1.00					1.0	1.1	0.9	1.1			1.1	
29			1.00					1.0	1.0	0.9	1.1			1.0	
30			0.99					1.0	1.0	0.9	1.0			1.0	
31			0.94					0.9	1.0	0.9	1.0			1.0	
AVG			1.03					1.0	1.0	0.9	1.0			1.0	
MAX			1.19					1.1	1.1	1.0	1.1			1.2	
MIN			0.93					0.8	0.8	0.7	0.9			0.9	



Chemical Analyses

WSSN 2310

Dec-10

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.16		100		68		32				24.8		9.2		
2		7.18		94		70		24				27.3		6.3		
3		7.22		90		67		23				28.1		4.9		
4		7.24		96		64		32				28.1		6.3		
5		7.22		96		64		32				28.9		5.8		
6		7.23		96		62		34				28.9		5.8		
7		7.29		94		67		27				27.3		6.3		
8		N/A		N/A		N/A		N/A				N/A		N/A		
9		7.26		98		66		32				28.1		6.8		
10		7.22		98		67		31				28.1		6.8		
11		7.24		98		64		34				28.1		6.8		
12		7.19		98		68		30				28.9		6.3		
13		7.11		96		64		32				28.9		5.8		
14		7.16		96		66		30				28.9		5.8		
15		7.12		98		66		32				28.9		6.3		
16		7.24		94		66		28				26.5		6.8		
17		7.21		96		65		31				27.3		6.8		
18		7.20		100		65		35				28.1		7.3		
19		7.27		100		67		33				28.1		7.3		
20		7.18		96		68		28				27.3		6.8		
21		7.39		100		72		28				28.1		7.3		
22		7.20		94		68		26				28.9		5.3		
23		7.18		102		71		31				28.1		7.8		
24		7.21		100		66		34				28.1		7.3		
25		7.30		100		68		32				28.1		7.3		
26		7.09		96		72		24				28.1		6.3		
27		7.03		104		68		36				28.9		7.8		
28		7.16		102		71		31				28.9		7.3		
29		7.17		98		67		31				28.1		6.8		
30		7.24		100		69		31				28.1		7.3		
31		7.15		96		68		28				24.8		8.3		
AVG		7.20		98		67		30				28.0		6.8		
MAX		7.39		104		72		36				28.9		9.2		
MIN		7.03		90		62		23				24.8		4.9		


Bacteriological & Physical Parameters
WSSN 2310
Dec-10

DATE	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					13.8				
2	1/0		2/0	2/0	2/0	2/0					13.5				
3	1/0		2/0	2/0	2/0	2/0					13.2				
4	1/0		2/0	2/0	2/0	2/0					11.3				
5	1/0		2/0	2/0	2/0	2/0			<2		10.8				
6	1/0		2/0	2/0	2/0	2/0					11.2				
7	1/0		2/0	2/0	2/0	2/0					14.7				
8	1/0		2/0	2/0	2/0	2/0					13.0				
9	1/0		2/0	2/0	2/0	2/0					12.9				
10	1/0		2/0	2/0	2/0	2/0					15.0				
11	1/0		2/0	2/0	2/0	2/0					14.2				
12	1/0		2/0	2/0	2/0	2/0					13.6				
13	1/0		2/0	2/0	2/0	2/0					14.5				
14	1/0		2/0	2/0	2/0	2/0					12.9				
15	1/0		2/0	2/0	2/0	2/0					12.7				
16	1/0		2/0	2/0	2/0	2/0					12.3				
17	1/0		2/0	2/0	2/0	2/0					13.1				
18	1/0		2/0	2/0	2/0	2/0					12.3				
19	1/0		2/0	2/0	2/0	2/0					11.9				
20	1/0		2/0	2/0	2/0	2/0					12.1				
21	1/0		2/0	2/0	2/0	2/0					N/A				
22	1/0		2/0	2/0	2/0	2/0					11.3				
23	1/0		2/0	2/0	2/0	2/0					N/A				
24	1/0		2/0	2/0	2/0	2/0					11.9				
25	1/0		2/0	2/0	2/0	2/0					12.5				
26	1/0		2/0	2/0	2/0	2/0					13.6				
27	1/0		2/0	2/0	2/0	2/0					14.0				
28	1/0		2/0	2/0	2/0	2/0					14.9				
29	1/0		2/0	2/0	2/0	2/0					15.1				
30	1/0		2/0	2/0	2/0	2/0					14.8				
31	1/0		2/0	2/0	2/0	2/0					13.9				
											13.1				
											15.1				
											10.8				

Dec-10

[illegible]

Dec-10

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				139			
Total number of routine distribution samples required:				100			