


**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of December 2012

FILED

Flint Water Plant	2310	Genesee
NAME OF WATER SYSTEM	WSSN	COUNTY
Michael Glasgow	DEQ RESOURCE MANAGEMENT DIVISION	F-1R S-3
CERTIFIED OPERATOR	JAN 14 2013	CLASSIFICATION
	LANSING DISTRICT	
SIGNATURE OF APPROPRIATE OFFICIAL		

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water


CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

[illegible]



Flouridation & Chlorination

WSSN 2310

Dec-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
		Raw	Tap	Dist		Chlorine (prior to filtration) mg/L OCl	Post Chlorine (lbs/day)	B&P	Sta II	Dort	3MG Well			Tap	
								Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.71					0.8	0.9	n/a	0.8			0.9	
2			0.65					0.8	0.9	n/a	0.9			0.8	
3			0.74					0.8	0.9	0.8	0.8			0.7	
4			0.75					0.8	0.9	0.8	1.0			0.7	
5			0.77					0.9	0.9	0.9	0.9			0.8	
6			0.69					0.7	0.9	0.8	0.8			0.8	
7			0.74					0.7	0.9	0.8	0.8			0.9	
8			0.74					0.7	0.8	0.8	0.8			0.8	
9			0.69					0.8	0.9	0.8	0.8			0.9	
10			0.68					0.8	0.9	0.7	0.7			0.7	
11			0.72					0.6	1.0	0.8	0.7			0.8	
12			0.70					0.8	0.9	0.8	0.7			0.7	
13			0.68					0.7	0.9	0.7	0.8			0.8	
14			0.68					0.8	0.9	0.9	0.7			0.8	
15			0.71					0.8	1.0	0.9	0.9			0.9	
16			0.76					0.6	0.9	0.7	0.6			0.7	
17			0.76					0.8	0.9	0.9	0.8			0.8	
18			0.72					0.7	0.9	0.8	0.8			0.7	
19			0.72					0.7	0.8	0.8	0.8			0.8	
20			0.72					0.6	0.9	0.7	0.7			0.7	
21			0.73					0.8	0.8	0.8	0.7			0.8	
22			0.72					0.9	0.9	0.8	0.8			0.9	
23			0.75					0.6	0.9	0.7	0.7			0.8	
24			0.71					0.6	0.8	0.7	0.7			0.7	
25			0.73					0.7	0.8	0.8	0.7			0.8	
26			0.77					0.8	0.7	0.8	0.8			0.7	
27			0.70					0.5	0.8	0.8	0.7			0.7	
28			0.70					0.8	0.8	0.8	0.7			0.8	
29			0.66					0.8	0.8	0.7	0.7			0.9	
30			0.71					0.7	0.8	0.7	0.7			0.7	
31			0.67					0.7	0.8	0.7	0.7			0.8	
AVG			0.72					0.7	0.9	0.8	0.8			0.8	
MAX			0.77					0.9	1.0	0.9	1.0			0.9	
MIN			0.65					0.5	0.7	0.7	0.6			0.7	



Chemical Analyses

WSSN 2310

Dec-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
I		7.29		98		71		27				30.5		5.3		
2		7.24		98		66		32				28.9		6.3		
3		7.36		98		68		30				29.7		5.8		
4		7.54		98		72		26				28.9		6.3		
5		7.37		96		70		26				29.7		5.3		
6		7.34		96		69		27				30.5		4.9		
7		7.26		98		68		30				29.7		5.8		
8		7.33		96		68		28				30.5		4.9		
9		7.32		96		69		27				28.9		5.8		
10		7.28		98		70		28				28.9		6.3		
11		7.22		100		67		33				30.5		5.8		
12		7.35		96		68		28				29.7		5.3		
13		7.38		98		71		27				29.7		5.8		
14		7.39		98		70		28				29.7		5.8		
15		7.28		96		71		25				28.9		5.8		
16		7.23		98		70		28				28.9		6.3		
17		7.39		100		72		28				28.9		6.8		
18		7.35		98		73		25				29.7		5.8		
19		7.32		98		72		26				30.5		5.3		
20		7.38		100		70		30				28.9		6.8		
21		7.31		98		64		34				28.9		6.3		
22		7.25		96		71		25				29.7		5.3		
23		7.22		100		69		31				29.7		6.3		
24		7.24		100		73		27				28.9		6.3		
25		7.28		96		71		25				28.1		6.3		
26		7.29		100		73		27				28.9		6.8		
27		7.32		98		69		29				30.5		5.3		
28		7.32		94		69		25				28.1		5.8		
29		7.26		98		69		29				28.1		6.8		
30		7.29		100		74		26				29.7		6.3		
31		7.20		98		60		38				29.7		5.8		
AVG		7.31		98		70		28				29.4		5.9		
MAX		7.54		100		74		38				30.5		6.8		
MIN		7.20		94		60		25				28.1		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Dec-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		0/0	2/0	2/0	2/0					16.5				
2	1/0		0/0	2/0	2/0	2/0					16.8				
3	1/0		2/0	2/0	2/0	2/0					15.9				
4	1/0		2/0	2/0	2/0	2/0					15.9				
5	1/0		2/0	2/0	2/0	2/0					16.7				
6	1/0		2/0	2/0	2/0	2/0					15.0				
7	1/0		2/0	2/0	2/0	2/0					16.0				
8	1/0		2/0	2/0	2/0	2/0					16.6				
9	1/0		1/0	1/0	1/0	1/0					17.1				
10	1/0		2/0	2/0	2/0	2/0					16.5				
11	1/0		2/0	2/0	2/0	2/0					15.4				
12	1/0		2/0	2/0	2/0	2/0			<2		15.0				
13	1/0		2/0	2/0	2/0	2/0					16.5				
14	1/0		2/0	2/0	2/0	2/0					15.9				
15	1/0		2/0	2/0	2/0	2/0					14.9				
16	1/0		2/0	2/0	2/0	2/0					16.2				
17	1/0		2/0	2/0	2/0	2/0					15.1				
18	1/0		2/0	2/0	2/0	2/0					15.2				
19	1/0		2/0	2/0	2/0	2/0					15.8				
20	1/0		2/0	2/0	2/0	2/0					14.8				
21	1/0		2/0	2/0	2/0	2/0					15.6				
22	1/0		2/0	2/0	2/0	2/0					15.2				
23	1/0		2/0	2/0	2/0	2/0					16.0				
24	1/0		2/0	2/0	2/0	2/0					14.2				
25	1/0		2/0	2/0	2/0	2/0					13.8				
26	1/0		2/0	2/0	2/0	2/0					13.9				
27	1/0		2/0	2/0	2/0	2/0					14.6				
28	1/0		2/0	2/0	2/0	2/0					14.2				
29	1/0		2/0	2/0	2/0	2/0					13.7				
30	1/0		2/0	2/0	2/0	2/0					14.2				
31	1/0		2/0	2/0	2/0	2/0					13.1				
											15.4				
											17.1				
											13.1				

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of November 2012



Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

DEQ
RESOURCE MANAGEMENT DIVISION

DEC 12 2012

TREATMENT RATE AND FILTER DATA

LANSING DISTRICT

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons
11. Total Power Cost per Million Gallons

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909





D A T E	Total Million Gallons Purchased	Million Gallons to County	Million Gallons to Flint			Ferric Chloride as Fe 3+ mg/l	Turbidity, NTU units						
							Raw				Plant Tap		
							# of Samples	Avg.	Max		# of Samples	Avg.	Max
1	1A	1B	4	5	6	7	8	9	10	11	12	13	
1	23.30	10.25	13.05								3	0.14	0.17
2	21.69	9.68	12.01								3	0.17	0.27
3	21.24	10.36	10.88								3	0.09	0.09
4	20.74	10.56	10.18								3	0.10	0.14
5	20.15	9.91	10.24								3	0.15	0.30
6	20.42	9.71	10.71								3	0.08	0.10
7	20.30	9.98	10.32								3	0.07	0.08
8	20.76	9.62	11.13								3	0.07	0.08
9	20.40	9.48	10.91								3	0.07	0.08
10	20.10	10.34	9.76								3	0.07	0.08
11	20.41	10.29	10.12								3	0.07	0.07
12	20.36	10.17	10.20								3	0.07	0.07
13	21.34	9.30	12.05								3	0.09	0.09
14	23.26	9.15	14.12								3	0.09	0.11
15	25.32	9.64	15.69								3	0.14	0.15
16	21.64	11.14	10.50								3	0.11	0.12
17	20.76	10.33	10.43								3	0.09	0.11
18	21.64	11.14	10.50								3	0.07	0.08
19	23.79	9.31	14.48								3	0.12	0.18
20	22.26	9.58	12.68								3	0.09	0.12
21	21.63	9.96	11.67								3	0.07	0.08
22	21.35	10.26	11.09								3	0.06	0.07
23	20.24	10.31	9.93								3	0.06	0.07
24	20.35	10.32	10.03								3	0.07	0.08
25	21.46	10.58	10.88								3	0.06	0.06
26	22.19	10.64	11.55								3	0.07	0.08
27	21.03	10.68	10.35								3	0.09	0.14
28	23.02	10.51	12.51								3	0.09	0.10
29	21.47	10.03	11.44								3	0.08	0.08
30	22.89	10.03	12.86								3	0.07	0.08
AVG	21.52	10.11	11.41								3	0.09	0.11
MAX	25.32	11.14	15.69								3	0.17	0.30
MIN	20.10	9.15	9.76								3	0.06	0.06
Total	645.49	303.24	342.26										



Flouridation & Chlorination

WSSN 2310

Nov-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl	Post Chlorine (lbs/day)	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.72					0.9	0.8	0.7	0.7			0.7	
2			0.69					0.8	0.8	0.8	0.8			0.9	
3			0.70					0.7	0.8	0.7	0.7			0.7	
4			0.66					0.7	0.8	0.7	0.7			0.8	
5			0.74					0.7	0.8	0.7	0.7			0.8	
6			0.76					0.7	0.8	0.7	0.8			0.7	
7			0.70					0.7	0.8	0.6	0.8			0.7	
8			0.73					0.7	0.7	0.8	0.8			0.8	
9			0.71					0.8	0.8	0.8	0.8			0.8	
10			0.74					0.6	0.9	0.7	0.7			0.7	
11			0.70					0.7	0.8	0.7	0.8			0.7	
12			0.69					0.8	0.8	0.7	0.8			0.7	
13			0.70					0.7	0.7	0.8	0.8			0.8	
14			0.70					0.8	0.8	0.7	0.7			0.8	
15			0.65					0.8	0.8	0.7	0.7			0.9	
16			0.71					0.7	0.9	0.8	0.8			0.8	
17			0.63					0.7	0.9	0.7	0.7			0.7	
18			0.63					0.6	0.8	0.7	0.8			0.7	
19			0.68					0.8	0.7	0.8	0.8			0.7	
20			0.71					0.8	0.7	0.8	0.8			0.7	
21			0.66					0.8	0.8	0.8	0.8			0.8	
22			0.63					0.6	0.8	0.8	0.7			0.7	
23			0.69					0.7	0.8	0.7	0.7			0.7	
24			0.60					0.8	0.8	0.6	0.7			0.8	
25			0.75					0.7	0.9	0.7	0.7			0.7	
26			0.68					0.8	0.9	0.7	0.8			0.9	
27			0.72					0.7	0.9	0.8	0.8			0.7	
28			0.76					0.9	0.9	0.7	0.8			0.9	
29			0.69					0.7	0.9	0.7	0.8			0.7	
30			0.75					0.9	0.9	n/a	0.8			0.9	
AVG			0.70					0.7	0.8	0.7	0.8			0.8	
MAX			0.76					0.9	0.9	0.8	0.8			0.9	
MIN			0.60					0.6	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Nov-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.28		100		72		28				29.7		6.3		
2		7.31		96		72		24				29.7		5.3		
3		7.26		98		72		26				28.9		6.3		
4		7.19		100		67		33				29.7		6.3		
5		7.18		100		66		34				30.5		5.8		
6		7.26		100		69		31				30.5		5.8		
7		7.25		98		67		31				29.7		5.8		
8		7.32		98		67		31				29.7		5.8		
9		7.26		96		68		28				28.9		5.8		
10		7.22		98		70		28				30.5		5.3		
11		7.21		98		68		30				30.5		5.3		
12		7.33		96		67		29				29.7		5.3		
13		7.21		100		68		32				28.9		6.8		
14		7.22		96		69		27				29.7		5.3		
15		7.35		n/a		n/a		n/a				n/a		n/a		
16		7.34		100		72		28				28.9		6.8		
17		7.30		98		66		32				29.7		5.3		
18		7.23		98		67		31				28.9		5.8		
19		7.35		100		73		27				30.5		5.8		
20		7.33		98		73		25				29.7		5.8		
21		7.30		98		71		27				28.9		6.3		
22		7.25		98		70		28				28.9		6.3		
23		7.27		98		72		26				28.9		6.3		
24		7.23		98		73		25				28.9		6.3		
25		7.26		98		67		31				28.9		6.3		
26		7.32		100		64		36				31.3		5.3		
27		7.33		98		71		27				28.9		6.3		
28		7.30		100		71		29				31.3		5.3		
29		7.39		98		67		31				28.9		6.3		
30		7.27		96		69		27				29.7		5.3		
AVG		7.28		98		69		29				29.6		5.9		
MAX		7.39		100		73		36				31.3		6.8		
MIN		7.18		96		64		24				28.9		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Nov-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0				18.0					
2	1/0		2/0	2/0	2/0	2/0				17.8					
3	1/0		2/0	2/0	2/0	2/0				17.8					
4	1/0		2/0	2/0	2/0	2/0				17.6					
5	1/0		2/0	2/0	2/0	2/0				17.6					
6	1/0		2/0	2/0	2/0	2/0				16.9					
7	1/0		2/0	2/0	2/0	2/0				16.5					
8	1/0		2/0	2/0	2/0	2/0				17.7					
9	1/0		2/0	2/0	2/0	2/0				16.6					
10	1/0		2/0	2/0	2/0	2/0				16.1					
11	1/0		2/0	2/0	2/0	2/0				14.7					
12	1/0		2/0	2/0	2/0	2/0				14.7					
13	1/0		2/0	2/0	2/0	2/0				14.0					
14	1/0		2/0	2/0	2/0	2/0		< 2		13.1					
15	1/0		2/0	2/0	2/0	2/0				12.7					
16	1/0		2/0	2/0	2/0	2/0				15.7					
17	1/0		2/0	2/0	2/0	2/0				16.3					
18	1/0		2/0	2/0	2/0	2/0				16.0					
19	1/0		2/0	2/0	2/0	2/0				16.9					
20	1/0		2/0	2/0	2/0	2/0				15.6					
21	1/0		2/0	2/0	2/0	2/0				17.7					
22	1/0		2/0	2/0	2/0	2/0				17.8					
23	1/0		2/0	2/0	2/0	2/0				16.7					
24	1/0		2/0	2/0	2/0	2/0				17.1					
25	1/0		2/0	2/0	2/0	2/0				16.6					
26	1/0		2/0	2/0	2/0	2/0				16.9					
27	1/0		2/0	2/0	2/0	2/0				15.9					
28	1/0		2/0	2/0	2/0	2/0				17.0					
29	1/0		2/0	2/0	2/0	2/0				15.3					
30	1/0		0/0	2/0	2/0	2/0				16.6					
											16.3				
											18.0				
											12.7				

[illegible]

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of October 2012

9 ENTERED

Flint Water Plant
NAME OF WATER SYSTEM


2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

DEQ
RESOURCE MANAGEMENT DIVISION

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

NOV 13 2012

LANSING DISTRICT

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons
11. Total Power Cost per Million Gallons

Remarks:

* In September we began adding chlorine gas at our 3 MG Well to boost chlorine residuals in the distribution system, and to reduce our chlorine gas storage. On average we are increasing the residual by 0.5mg/L - 0.7mg/L at the 3 MG well, which has an average flow of 6 MGD. Chlorine addition continued until October 22nd.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

[illegible]



Flouridation & Chlorination

WSSN 2310

Oct-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) lbs/day	Post Chlorine (lbs/day)	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.70				30	0.7	0.8	0.7	1.4			1.1	
2			0.76				30	0.8	0.9	0.8	1.3			0.9	
3			0.75				30	0.8	0.9	0.8	1.3			0.9	
4			0.74				30	0.7	0.9	0.8	1.4			0.9	
5			0.74				30	0.7	0.8	0.8	1.3			1.0	
6			0.73				30	0.8	0.8	0.7	1.4			0.9	
7			0.76				30	0.7	0.8	0.6	1.2			0.8	
8			0.75				40	0.9	0.8	0.6	1.5			1.0	
9			0.80				38	0.7	0.8	0.6	1.4			0.7	
10			0.77				38	0.7	0.8	0.7	1.4			0.9	
11			0.70				40	0.7	0.7	0.7	1.4			0.9	
12			0.76				40	0.7	0.8	0.8	1.4			0.8	
13			0.75				40	0.8	0.9	0.8	1.6			1.2	
14			0.72				40	0.8	0.8	0.7	1.3			1.0	
15			0.77				40	0.8	0.9	0.8	1.4			1.1	
16			0.76				40	0.9	0.8	0.8	1.4			0.9	
17			0.73				40	0.9	0.8	0.8	1.4			0.9	
18			0.76				40	0.7	0.8	0.7	1.4			0.9	
19			0.76				40	0.8	0.8	0.8	1.5			1.0	
20			0.74				40	0.8	0.8	0.8	1.5			1.1	
21			0.78				40	0.7	0.8	0.7	1.3			1.0	
22			0.71				10	0.8	0.8	0.7	1.3			0.9	
23			0.72					0.7	0.9	0.8	0.8			0.8	
24			0.74					0.8	0.9	0.7	0.8			0.9	
25			0.68					0.8	1.0	0.8	0.7			0.8	
26			0.74					0.8	0.8	0.8	0.8			0.9	
27			0.62					0.7	0.8	0.7	0.8			0.7	
28			0.69					0.7	0.8	0.7	0.8			0.7	
29			0.75					0.8	0.8	0.7	0.7			0.8	
30			0.74					0.6	0.8	0.7	0.7			0.7	
31			0.74					0.8	0.8	0.7	0.7			0.7	
AVG			0.74				35	0.8	0.8	0.7	1.2			0.9	
MAX			0.80				40	0.9	1.0	0.8	1.6			1.2	
MIN			0.62				10	0.6	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Oct-12

DATE	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.40		100		72		28				29.7		6.3		
2		7.37		98		72		26				29.7		5.8		
3		7.42		98		73		25				30.5		5.3		
4		7.41		98		75		23				29.7		5.8		
5		7.44		98		71		27				30.5		5.3		
6		7.45		102		72		30				27.3		8.3		
7		7.40		100		73		27				28.9		6.8		
8		7.37		100		70		30				30.5		5.8		
9		7.43		102		73		29				30.5		6.3		
10		7.41		96		74		22				28.9		5.8		
11		7.39		96		71		25				29.7		5.3		
12		7.34		98		68		30				28.9		6.3		
13		7.41		96		71		25				32.1		3.9		
14		7.30		100		73		27				28.9		6.8		
15		7.34		98		69		29				29.7		5.8		
16		7.47		96		74		22				29.7		5.3		
17		7.39		98		72		26				29.7		5.8		
18		7.41		98		74		24				28.9		6.3		
19		7.36		98		72		26				28.9		6.3		
20		7.36		96		74		22				29.7		5.3		
21		7.37		100		73		27				28.9		6.8		
22		7.33		100		74		26				29.7		6.3		
23		7.37		98		74		24				28.9		6.3		
24		7.41		100		74		26				28.9		6.8		
25		7.37		98		75		23				28.9		5.8		
26		7.40		98		74		24				29.7		5.8		
27		7.37		98		71		27				28.9		6.3		
28		7.28		100		72		28				29.7		6.3		
29		7.41		98		73		25				28.9		6.3		
30		7.41		98		69		29				29.7		5.8		
31		7.41		98		74		24				29.7		5.8		
AVG		7.39		98		72		26				29.5		6.0		
MAX		7.47		102		75		30				32.1		8.3		
MIN		7.28		96		68		22				27.3		3.9		



Bacteriological & Physical Parameters

WSSN 2310

Oct-12

DATE	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					20.5				
2	1/0		2/0	2/0	2/0	2/0					19.0				
3	1/0		2/0	2/0	2/0	2/0					18.6				
4	1/0		2/0	2/0	2/0	2/0					18.8				
5	1/0		2/0	2/0	2/0	2/0					18.9				
6	1/0		2/0	2/0	2/0	2/0					18.4				
7	1/0		2/0	2/0	2/0	2/0					18.5				
8	1/0		2/0	2/0	2/0	2/0					18.6				
9	1/0		2/0	2/0	2/0	2/0					19.0				
10	1/0		2/0	2/0	2/0	2/0					19.4				
11	1/0		2/0	2/0	2/0	2/0					18.9				
12	1/0		2/0	2/0	2/0	2/0					18.8				
13	1/0		2/0	2/0	2/0	2/0					18.8				
14	1/0		2/0	2/0	2/0	2/0					19.1				
15	1/0		2/0	2/0	2/0	2/0					19.2				
16	1/0		2/0	2/0	2/0	2/0					17.8				
17	1/0		2/0	2/0	2/0	2/0					17.9				
18	1/0		2/0	2/0	2/0	2/1					17.3				
19	1/0		2/0	2/0	2/0	2/0					17.3				
20	1/0		2/0	2/0	2/0	2/0					16.9				
21	1/0		2/0	2/0	2/0	2/0					17.0				
22	1/0		2/0	2/0	2/0	2/0					17.5				
23	1/0		2/0	2/0	2/0	2/0					17.1				
24	1/0		2/0	2/1	2/0	2/0					17.0				
25	1/0		2/0	2/0	2/0	2/0			< 2		17.1				
26	1/0		2/0	2/0	2/0	2/0					17.3				
27	1/0		2/0	2/0	2/0	2/0					16.1				
28	1/1		2/0	2/0	2/0	2/0					17.6				
29	1/0		2/0	2/0	2/0	2/0					16.9				
30	1/0		2/0	2/0	2/0	2/0					17.8				
31	1/0		2/0	2/0	2/0	2/0					18.0				
											18.1				
											20.5				
											16.1				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Oct-12

Total number of positive routine samples: <u>4</u>				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
10/18/2012	Laboratory Tap	Present	Absent	10/19/2012	Laboratory Tap	Absent	Absent
				10/19/2012	Control Station # 2 (Sta 2)	Absent	Absent
				10/19/2012	Pump Station #4 (3 MG Well)	Absent	Absent
10/24/2012	Pump Station #4 (3 MG Well)	Present	Absent	10/25/2012	Pump Station #4 (3 MG Well)	Absent	Absent
				10/25/2012	Control Station # 2 (Sta 2)	Absent	Absent
				10/25/2012	Laboratory Tap	Absent	Absent
10/26/2012	West Side Reservoir & Pump Station (WS)	Present	Absent	10/27/2012	West Side Reservoir & Pump Station	Absent	Absent
				10/27/2012	Mid-way Market	Absent	Absent
				10/27/2012	Frazier's Accounting	Absent	Absent
10/28/2012	Baxter & Potter Rd. Control Station (B&P)	Present	Absent	10/29/2012	Baxter & Potter Rd. Control Station (B&P)	Absent	Absent
				10/29/2012	Up-stream	n/a	n/a
				10/29/2012	Control Station # 2 (Sta 2)	Absent	Absent
Total number of routine distribution samples analyzed:				162			
Total number of routine distribution samples required:				100			



ENTERED

Coagulation Parameters

WSSN 2310

Oct-12

DATE	Total Million Gallons Purchased	Million Gallons to County	Million Gallons to Flint	4	5	Ferric Chloride as Fe 3+ mg/l	Turbidity, NTU units						
							Raw				Plant Tap		
							# of Samples	Avg.	Max		# of Samples	Avg.	Max
	1	1A	1B			6	7	8	9	10	11	12	13
1	23.29	11.63	11.65								3	0.10	0.12
2	23.01	11.67	11.34								3	0.10	0.10
3	23.01	12.07	10.95								3	0.10	0.10
4	21.53	10.83	10.70								3	0.13	0.14
5	22.85	11.79	11.06								3	0.09	0.09
6	23.03	12.10	10.93								3	0.09	0.09
7	23.21	12.00	11.20								3	0.10	0.11
8	23.12	11.38	11.74								3	0.11	0.12
9	21.93	10.68	11.25								3	0.08	0.08
10	21.96	10.23	11.73								3	0.11	0.13
11	21.81	10.30	11.51								3	0.08	0.08
12	22.41	10.04	12.37								3	0.07	0.08
13	21.07	10.89	10.18								3	0.10	0.14
14	21.91	10.40	11.51								3	0.09	0.11
15	21.50	10.07	11.43								3	0.13	0.24
16	21.72	10.03	11.69								3	0.08	0.09
17	19.69	11.12	8.57								3	0.09	0.09
18	18.72	11.65	7.07								3	0.08	0.09
19	18.34	11.21	7.13								3	0.08	0.09
20	19.42	10.74	8.68								3	0.08	0.08
21	20.52	10.15	10.37								3	0.09	0.10
22	20.47	10.69	9.78								3	0.09	0.10
23	20.53	10.09	10.44								3	0.10	0.11
24	20.31	9.40	10.91								3	0.13	0.16
25	22.10	10.07	12.03								3	0.11	0.12
26	22.69	10.84	11.84								3	0.10	0.11
27	21.82	11.69	10.13								3	0.12	0.13
28	21.33	11.37	9.96								3	0.11	0.12
29	22.17	10.08	12.09								3	0.12	0.14
30	20.50	10.48	10.02								3	0.13	0.16
31	21.51	10.07	11.44								3	0.13	0.15
AVG	21.53	10.83	10.70								3	0.10	0.11
MAX	23.29	12.10	12.37								3	0.13	0.24
MIN	18.34	9.40	7.07								3	0.07	0.08
Total	667.46	335.77	331.69										

40



Flouridation & Chlorination

WSSN 2310

Oct-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) lbs/day	Post Chlorin e (lbs/day)	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
		14	15	16				17	18	19	20	21	22	23	24
1			0.70				30	0.7	0.8	0.7	1.4			1.1	
2			0.76				30	0.8	0.9	0.8	1.3			0.9	
3			0.75				30	0.8	0.9	0.8	1.3			0.9	
4			0.74				30	0.7	0.9	0.8	1.4			0.9	
5			0.74				30	0.7	0.8	0.8	1.3			1.0	
6			0.73				30	0.8	0.8	0.7	1.4			0.9	
7			0.76				30	0.7	0.8	0.6	1.2			0.8	
8			0.75				40	0.9	0.8	0.6	1.5			1.0	
9			0.80				38	0.7	0.8	0.6	1.4			0.7	
10			0.77				38	0.7	0.8	0.7	1.4			0.9	
11			0.70				40	0.7	0.7	0.7	1.4			0.9	
12			0.76				40	0.7	0.8	0.8	1.4			0.8	
13			0.75				40	0.8	0.9	0.8	1.6			1.2	
14			0.72				40	0.8	0.8	0.7	1.3			1.0	
15			0.77				40	0.8	0.9	0.8	1.4			1.1	
16			0.76				40	0.9	0.8	0.8	1.4			0.9	
17			0.73				40	0.9	0.8	0.8	1.4			0.9	
18			0.76				40	0.7	0.8	0.7	1.4			0.9	
19			0.76				40	0.8	0.8	0.8	1.5			1.0	
20			0.74				40	0.8	0.8	0.8	1.5			1.1	
21			0.78				40	0.7	0.8	0.7	1.3			1.0	
22			0.71				10	0.8	0.8	0.7	1.3			0.9	
23			0.72					0.7	0.9	0.8	0.8			0.8	
24			0.74					0.8	0.9	0.7	0.8			0.9	
25			0.68					0.8	1.0	0.8	0.7			0.8	
26			0.74					0.8	0.8	0.8	0.8			0.9	
27			0.62					0.7	0.8	0.7	0.8			0.7	
28			0.69					0.7	0.8	0.7	0.8			0.7	
29			0.75					0.8	0.8	0.7	0.7			0.8	
30			0.74					0.6	0.8	0.7	0.7			0.7	
31			0.74					0.8	0.8	0.7	0.7			0.7	
AVG			0.74				35	0.8	0.8	0.7	1.2			0.9	
MAX			0.80				40	0.9	1.0	0.8	1.6			1.2	
MIN			0.62				10	0.6	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Oct-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.40		100		72		28				29.7		6.3		
2		7.37		98		72		26				29.7		5.8		
3		7.42		98		73		25				30.5		5.3		
4		7.41		98		75		23				29.7		5.8		
5		7.44		98		71		27				30.5		5.3		
6		7.45		102		72		30				27.3		8.3		
7		7.40		100		73		27				28.9		6.8		
8		7.37		100		70		30				30.5		5.8		
9		7.43		102		73		29				30.5		6.3		
10		7.41		96		74		22				28.9		5.8		
11		7.39		96		71		25				29.7		5.3		
12		7.34		98		68		30				28.9		6.3		
13		7.41		96		71		25				32.1		3.9		
14		7.30		100		73		27				28.9		6.8		
15		7.34		98		69		29				29.7		5.8		
16		7.47		96		74		22				29.7		5.3		
17		7.39		98		72		26				29.7		5.8		
18		7.41		98		74		24				28.9		6.3		
19		7.36		98		72		26				28.9		6.3		
20		7.36		96		74		22				29.7		5.3		
21		7.37		100		73		27				28.9		6.8		
22		7.33		100		74		26				29.7		6.3		
23		7.37		98		74		24				28.9		6.3		
24		7.41		100		74		26				28.9		6.8		
25		7.37		98		75		23				28.9		5.8		
26		7.40		98		74		24				29.7		5.8		
27		7.37		98		71		27				28.9		6.3		
28		7.28		100		72		28				29.7		6.3		
29		7.41		98		73		25				28.9		6.3		
30		7.41		98		69		29				29.7		5.8		
31		7.41		98		74		24				29.7		5.8		
AVG		7.39		98		72		26				29.5		6.0		
MAX		7.47		102		75		30				32.1		8.3		
MIN		7.28		96		68		22				27.3		3.9		



Bacteriological & Physical Parameters

WSSN 2310

Oct-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					20.5				
2	1/0		2/0	2/0	2/0	2/0					19.0				
3	1/0		2/0	2/0	2/0	2/0					18.6				
4	1/0		2/0	2/0	2/0	2/0					18.8				
5	1/0		2/0	2/0	2/0	2/0					18.9				
6	1/0		2/0	2/0	2/0	2/0					18.4				
7	1/0		2/0	2/0	2/0	2/0					18.5				
8	1/0		2/0	2/0	2/0	2/0					18.6				
9	1/0		2/0	2/0	2/0	2/0					19.0				
10	1/0		2/0	2/0	2/0	2/0					19.4				
11	1/0		2/0	2/0	2/0	2/0					18.9				
12	1/0		2/0	2/0	2/0	2/0					18.8				
13	1/0		2/0	2/0	2/0	2/0					18.8				
14	1/0		2/0	2/0	2/0	2/0					19.1				
15	1/0		2/0	2/0	2/0	2/0					19.2				
16	1/0		2/0	2/0	2/0	2/0					17.8				
17	1/0		2/0	2/0	2/0	2/0					17.9				
18	1/0		2/0	2/0	2/0	2/1					17.3				
19	1/0		2/0	2/0	2/0	2/0					17.3				
20	1/0		2/0	2/0	2/0	2/0					16.9				
21	1/0		2/0	2/0	2/0	2/0					17.0				
22	1/0		2/0	2/0	2/0	2/0					17.5				
23	1/0		2/0	2/0	2/0	2/0					17.1				
24	1/0		2/0	2/1	2/0	2/0					17.0				
25	1/0		2/0	2/0	2/0	2/0			< 2		17.1				
26	1/0		2/0	2/0	2/0	2/0					17.3				
27	1/0		2/0	2/0	2/0	2/0					16.1				
28	1/1		2/0	2/0	2/0	2/0					17.6				
29	1/0		2/0	2/0	2/0	2/0					16.9				
30	1/0		2/0	2/0	2/0	2/0					17.8				
31	1/0		2/0	2/0	2/0	2/0					18.0				
											18.1				
											20.5				
											16.1				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Oct-12

Total number of positive routine samples: <u>4</u>				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
10/18/2012	Laboratory Tap	Present	Absent	10/19/2012	Laboratory Tap	Absent	Absent
				10/19/2012	Control Station # 2 (Sta 2)	Absent	Absent
				10/19/2012	Pump Station #4 (3 MG Well)	Absent	Absent
10/24/2012	Pump Station #4 (3 MG Well)	Present	Absent	10/25/2012	Pump Station #4 (3 MG Well)	Absent	Absent
				10/25/2012	Control Station # 2 (Sta 2)	Absent	Absent
				10/25/2012	Laboratory Tap	Absent	Absent
10/26/2012	West Side Reservoir & Pump Station (WS)	Present	Absent	10/27/2012	West Side Reservoir & Pump Station	Absent	Absent
				10/27/2012	Mid-way Market	Absent	Absent
				10/27/2012	Frazier's Accounting	Absent	Absent
10/28/2012	Baxter & Potter Rd. Control Station (B&P)	Present	Absent	10/29/2012	Baxter & Potter Rd. Control Station (B&P)	Absent	Absent
				10/29/2012	Up-stream	n/a	n/a
				10/29/2012	Control Station # 2 (Sta 2)	Absent	Absent
Total number of routine distribution samples analyzed:				162			
Total number of routine distribution samples required:				100			

2310

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

 **ENTERED**

For Month of September 2012


Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

DEQ
RESOURCE MANAGEMENT DIVISION

TREATMENT RATE AND FILTER DATA

OCT 12 2012

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

LANSING DISTRICT

CHEMICAL DATA


7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

* On September 26th we began adding chlorine gas at our 3 MG Well to boost chlorine residuals in the distribution system, and to reduce our chlorine gas storage. On average we are increasing the residual by 0.5mg/L - 0.7mg/L at the 3 MG well, which has an average flow of 6 MGD.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909







Flouridation & Chlorination

WSSN 2310

Sep-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine (3MG Well) mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.65					0.8	1.0	0.6	0.8			0.8	
2			n/a					n/a	n/a	n/a	n/a			n/a	
3			0.69					0.8	0.9	0.7	0.8			0.8	
4			0.69					0.9	1.0	0.8	0.8			0.9	
5			0.69					1.1	1.0	0.8	0.8			1.0	
6			0.66					1.0	1.0	0.7	0.8			1.0	
7			0.68					1.0	1.0	0.8	0.8			1.0	
8			0.71					0.8	0.9	0.8	0.8			0.9	
9			0.69					0.8	0.9	0.8	0.7			0.7	
10			0.67					0.8	0.8	0.8	0.8			0.7	
11			0.71					0.8	0.8	0.6	0.7			0.8	
12			0.74					0.9	0.8	0.8	0.7			0.8	
13			0.71					0.7	0.9	0.6	0.7			0.7	
14			0.76					0.9	0.9	0.7	0.8			1.0	
15			0.74					0.8	0.9	0.8	0.8			1.0	
16			0.74					0.7	0.9	0.7	0.7			0.8	
17			0.72					0.8	0.8	0.7	0.8			0.7	
18			0.73					0.9	0.9	0.7	0.8			0.8	
19			0.74					0.8	0.8	0.6	0.7			0.8	
20			0.69					0.7	0.8	0.7	0.7			0.7	
21			0.72					0.8	0.8	0.7	0.7			0.7	
22			0.64					0.8	0.8	0.7	0.8			0.7	
23			0.68					0.8	1.0	0.6	0.7			0.8	
24			0.70					0.9	0.7	0.8	0.8			0.9	
25			0.71					0.9	0.9	0.8	0.8			0.9	
26			0.69				35	1.0	0.9	0.7	1.2			0.8	
27			0.68				35	0.7	0.9	0.8	1.5			1.1	
28			0.73				35	0.9	0.9	0.8	1.5			1.0	
29			0.73				35	0.9	1.0	0.9	1.5			1.1	
30			0.64				32	0.8	1.0	0.8	1.4			1.0	
AVG			0.70				34	0.8	0.9	0.7	0.9			0.9	
MAX			0.76				35	1.1	1.0	0.9	1.5			1.1	
MIN			0.64				32	0.7	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Sep-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.30		100		72		28				29.7		6.3		
2		n/a		n/a		n/a		n/a				n/a		n/a		
3		7.27		100		70		30				29.7		6.3		
4		7.43		100		73		27				29.7		6.3		
5		7.44		98		72		26				29.7		5.8		
6		7.39		98		72		26				30.5		5.3		
7		7.40		100		73		27				28.1		7.3		
8		7.41		98		72		26				26.5		7.8		
9		7.32		98		71		27				28.9		6.3		
10		7.44		100		72		28				29.7		6.3		
11		7.42		100		74		26				28.9		6.8		
12		7.49		100		72		28				29.7		6.3		
13		7.36		98		71		27				29.7		5.3		
14		7.51		98		69		29				28.9		6.3		
15		7.44		102		72		30				27.3		8.3		
16		7.23		98		72		26				28.9		6.3		
17		7.32		98		72		26				28.9		6.3		
18		7.40		98		72		26				29.7		5.8		
19		7.34		100		74		26				30.5		5.8		
20		7.44		100		71		29				28.9		6.8		
21		7.36		98		72		26				28.9		6.3		
22		7.26		100		73		27				30.5		5.8		
23		7.28		100		69		31				29.7		6.3		
24		7.35		96		73		23				29.7		5.3		
25		7.37		98		72		26				30.5		5.3		
26		7.43		98		69		29				29.7		5.8		
27		7.62		98		72		26				28.9		6.3		
28		7.35		98		71		27				30.5		5.3		
29		7.37		96		72		24				29.7		5.3		
30		7.34		100		70		30				28.9		6.8		
AVG		7.38		99		72		27				29.3		6.2		
MAX		7.62		102		74		31				30.5		8.3		
MIN		7.23		96		69		23				26.5		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Sep-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					23.3				
2	0/0		0/0	0/0	0/0	0/0					n/a				
3	1/0		2/0	2/0	2/0	2/0					22.2				
4	1/0		2/0	2/0	2/0	2/0					22.2				
5	1/0		2/0	2/0	2/0	2/0					22.7				
6	1/0		2/0	2/0	2/0	2/0					22.3				
7	1/0		2/0	2/0	2/0	2/0					22.2				
8	1/0		2/0	2/0	2/0	2/0					21.7				
9	1/0		2/0	2/0	2/0	2/0					22.4				
10	1/0		2/0	2/0	2/0	2/0					22.2				
11	1/0		2/0	2/0	2/0	2/0					22.0				
12	1/0		2/0	2/0	2/0	2/0					22.1				
13	1/0		2/0	2/0	2/0	2/0			< 2		21.8				
14	1/0		2/0	2/0	2/0	2/0					21.8				
15	1/0		2/0	2/0	2/0	2/0					21.0				
16	1/0		2/0	2/0	2/0	2/0					21.4				
17	1/0		2/0	2/0	2/0	2/0					22.1				
18	1/0		2/0	2/0	2/0	2/0					22.0				
19	1/0		2/0	2/0	2/0	2/0					22.5				
20	1/0		2/0	2/0	2/0	2/0					20.9				
21	1/0		2/0	2/0	2/0	2/0					20.7				
22	1/0		2/0	2/0	2/0	2/0					20.7				
23	1/0		2/0	2/0	2/0	2/0					20.2				
24	1/0		2/0	2/0	2/0	2/0					19.6				
25	1/0		2/0	2/0	2/0	2/0					19.6				
26	1/0		2/0	2/0	2/0	2/0					19.8				
27	1/0		2/0	2/0	2/0	2/0					20.0				
28	1/0		2/0	2/0	2/0	2/0					19.4				
29	1/0		2/0	2/0	2/0	2/0					19.2				
30	1/0		2/0	2/0	2/0	2/0					19.4				
											21.3				
											23.3				
											19.2				

[illegible]

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Sep-12

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				160			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of August 2012

 **ENTERED**

Flint Water Plant
NAME OF WATER SYSTEM


2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

**DEQ
RESOURCE MANAGEMENT DIVISION**

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

SEP 13 2012

LANSING DISTRICT

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water


CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909



[illegible]



Flouridation & Chlorination

WSSN 2310

Aug-12

D A T E	Fluorid e Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCI-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.75					0.8	0.8	0.8	0.8			0.9	
2			0.74					0.7	0.8	0.7	0.8			0.7	
3			0.77					0.8	0.8	0.8	0.7			0.9	
4			0.74					0.8	0.9	0.7	0.8			0.8	
5			0.70					0.7	0.8	0.7	0.8			0.8	
6			0.71					0.9	0.9	0.8	0.7			0.9	
7			0.67					0.8	0.9	0.6	0.6			0.8	
8			0.66					0.9	0.9	0.6	0.6			0.9	
9			0.68					0.8	0.9	0.5	0.6			0.8	
10			0.64					1.0	1.0	0.5	0.6			1.0	
11			0.67					0.9	1.0	0.5	0.6			1.0	
12			0.68					0.8	0.9	0.7	0.7			0.7	
13			0.67					0.8	0.9	0.7	0.7			0.8	
14			0.66					0.7	0.9	0.7	0.8			0.8	
15			0.66					0.8	0.9	0.7	0.7			0.8	
16			0.67					0.8	0.9	0.7	0.7			0.8	
17			0.70					0.8	0.9	0.8	0.8			0.9	
18			0.67					1.0	0.9	0.7	0.7			1.0	
19			0.63					0.8	0.8	0.8	0.8			0.9	
20			0.64					0.9	0.9	0.8	0.7			0.8	
21			0.55					0.8	0.9	0.8	0.7			0.9	
22			0.65					0.8	0.9	0.8	0.8			0.9	
23			0.64					0.9	1.0	0.9	0.8			0.9	
24			0.68					0.9	1.0	0.9	0.8			1.0	
25			0.65					0.9	0.9	0.8	0.7			0.9	
26			0.62					0.7	0.9	0.8	0.7			0.8	
27			0.64					0.8	0.8	0.8	0.8			0.8	
28			0.69					0.9	0.8	0.8	0.8			0.7	
29			0.65					0.8	0.8	0.7	0.8			0.8	
30			0.68					0.8	0.9	0.7	0.8			0.7	
31			0.69					0.9	0.9	0.8	0.7			1.0	
AVG			0.67					0.8	0.9	0.7	0.7			0.9	
MAX			0.77					1.0	1.0	0.9	0.8			1.0	
MIN			0.55					0.7	0.8	0.5	0.6			0.7	



Chemical Analyses

WSSN 2310

Aug-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.46		94		73		21				28.1		5.8		
2		7.43		96		71		25				28.9		5.8		
3		7.46		94		69		25				28.1		5.8		
4		7.46		98		73		25				27.3		7.3		
5		7.47		98		71		27				28.9		6.3		
6		7.44		98		73		25				28.1		6.8		
7		7.42		98		72		26				28.9		6.3		
8		7.48		98		73		25				28.9		6.3		
9		7.43		98		71		27				28.9		6.3		
10		7.45		96		72		24				28.1		6.3		
11		7.51		96		71		25				28.1		6.3		
12		7.28		96		72		24				28.9		5.8		
13		7.60		96		73		23				29.7		5.3		
14		7.28		96		73		23				30.5		4.9		
15		7.50		96		72		24				29.7		5.3		
16		7.38		98		69		29				28.9		6.3		
17		7.44		98		72		26				28.9		6.3		
18		7.38		100		72		28				28.1		7.3		
19		7.26		98		72		26				29.7		5.8		
20		7.61		100		72		28				29.7		6.3		
21		7.34		98		75		23				29.7		5.3		
22		7.49		98		74		24				30.5		5.3		
23		7.43		98		72		26				29.7		5.8		
24		7.45		96		72		24				27.3		6.8		
25		7.35		96		72		24				26.5		7.3		
26		7.45		100		72		28				30.5		5.8		
27		7.45		98		71		27				29.7		5.8		
28		7.31		98		73		25				29.7		5.8		
29		7.52		98		73		25				29.7		5.8		
30		7.47		98		74		24				29.7		5.8		
31		7.39		100		69		31				29.7		6.3		
AVG		7.43		97		72		25				29.0		6.1		
MAX		7.61		100		75		31				30.5		7.3		
MIN		7.26		94		69		21				26.5		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Aug-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					22.2				
2	1/0		2/0	2/0	2/0	2/0					22.3				
3	1/0		2/0	2/0	2/0	2/0					22.1				
4	1/0		2/0	2/0	2/0	2/0					22.4				
5	1/0		2/0	2/0	2/0	2/0					22.5				
6	1/0		2/0	2/0	2/0	2/0					22.5				
7	1/0		2/0	2/0	2/0	2/0					22.6				
8	1/0		2/0	2/0	2/0	2/0					21.5				
9	1/0		2/0	2/0	2/0	2/0			< 2		22.2				
10	1/0		2/0	2/0	2/0	2/0					21.3				
11	1/0		2/0	2/0	2/0	2/0					20.7				
12	1/0		2/0	2/0	2/0	2/0					21.5				
13	1/0		2/0	2/0	2/0	2/0					21.7				
14	1/0		2/0	2/0	2/0	2/0					21.7				
15	1/0		2/0	2/0	2/0	2/0					22.0				
16	1/0		2/0	2/0	2/0	2/0					22.0				
17	1/0		2/0	2/0	2/0	2/0					23.0				
18	1/0		2/0	2/0	2/0	2/0					21.5				
19	1/0		2/0	2/0	2/0	2/0					24.0				
20	1/0		2/0	2/0	2/0	2/0					22.1				
21	1/0		2/0	2/0	2/0	2/0					21.7				
22	1/0		2/0	2/0	2/0	2/0					21.9				
23	1/0		2/0	2/0	2/0	2/0					21.7				
24	1/0		2/0	2/0	2/0	2/0					24.6				
25	1/0		2/0	2/0	2/0	2/0					24.4				
26	1/0		2/0	2/0	2/0	2/0					22.1				
27	1/0		2/0	2/0	2/0	2/0					22.2				
28	1/0		2/0	2/0	2/0	2/0					21.7				
29	1/0		2/0	2/0	2/0	2/0					22.2				
30	1/0		2/0	2/0	2/0	2/0					21.8				
31	1/0		2/0	2/0	2/0	2/0					21.9				
											22.2				
											24.6				
											20.7				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Aug-12

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				175			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of July 2012

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

* On July 3rd we experienced high turbidities from the plant tap. This was most likely a small slug from Baxter & Potter Rd. as a result of switching from our 36" to our 60" pipe on July 2nd. Chlorine residuals were good, and extra bacteria samples were collected. All bacteria samples were absent. On July 4th turbidity values were back at usual levels.

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

[illegible]

Meter Pits off 72" City of Flint Transmission Main

Daily Average

July-12

Date: Henderson Oak & Potter M-15 & Potter Irish & Potter Belsay & Potter S. Genesee

1	9.77	0.83	0.23	2.32	1.11	10.12	24.38
2	8.01	0.84	0.24	2.34	1.11	10.20	22.74
3	8.00	0.90	0.19	2.42	1.11	10.66	23.28
4	8.11	0.80	0.07	2.32	1.14	9.83	22.27
5	6.85	0.88	0.15	2.56	1.16	6.18	17.78
6	5.65	0.87	0.16	2.57	1.16	4.88	15.29
7	8.29	0.87	0.15	2.51	1.15	7.07	20.04
8	8.38	0.76	0.14	2.19	1.03	11.57	24.07
9	4.87	0.82	0.25	2.45	1.03	7.41	16.83
10	5.86	0.83	0.20	2.39	1.20	10.01	20.49
11	7.86	0.86	0.21	2.48	1.30	8.42	21.13
12	8.93	0.91	0.23	2.61	1.46	7.20	21.34
13	9.27	0.89	0.22	2.51	1.41	9.33	23.63
14	8.95	0.86	0.20	2.43	1.15	10.52	24.11
15	8.53	0.87	0.18	2.47	1.23	10.96	24.24
16	6.90	0.87	0.18	2.50	1.22	10.58	22.25
17	6.40	0.83	0.18	2.31	1.16	10.46	21.34
18	8.53	0.86	0.15	2.42	1.30	10.42	23.68
19	8.06	0.86	0.11	2.53	1.53	8.12	21.21
20	5.83	0.81	0.13	2.61	1.61	5.94	16.93
21	4.95	0.77	0.11	2.49	1.41	6.05	15.78
22	5.29	0.80	0.14	2.41	1.24	7.92	17.8
23	5.26	0.76	0.13	2.30	1.16	9.71	19.35
24	5.59	0.79	0.14	2.32	1.10	9.85	19.29
25	5.58	0.81	0.17	2.37	1.20	9.63	19.76
26	5.56	0.86	0.17	2.51	1.26	9.04	19.04
27	6.92	0.81	0.10	2.47	1.45	6.78	18.53
28	6.57	0.79	0.09	2.46	1.37	5.77	17.05
29	4.76	0.77	0.12	2.58	1.52	5.86	15.61
30	3.81	0.64	0.12	2.50	1.51	6.52	15.10
31	3.80	0.59	0.12	2.24	1.24	7.84	15.83

Totals: 211.14 25.41 4.98 75.59 39.03 264.85



Flouridation & Chlorination

WSSN 2310

Jul-12

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Free	Free	Free				Free			Free				
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			n/a					0.8	0.8	0.5	0.4			0.7	
2			0.69					0.7	0.9	0.4	0.5			0.9	
3			0.67					0.8	9.0	0.5	0.6			0.8	
4			0.70					0.7	0.8	0.4	0.5			0.7	
5			0.39					0.7	0.9	0.5	0.6			0.7	
6			0.60					0.8	0.8	0.4	0.4			0.7	
7			0.66					0.7	0.9	0.4	0.4			0.8	
8			0.64					0.8	0.9	0.5	0.3			0.8	
9			0.68					0.8	0.9	0.4	0.4			0.8	
10			0.65					0.7	0.8	0.4	0.4			0.7	
11			0.65					0.9	0.8	0.4	0.5			0.8	
12			0.60					0.8	0.9	0.5	0.6			0.7	
13			0.65					0.8	0.9	0.5	0.7			0.8	
14			0.62					0.9	0.9	0.5	0.8			0.9	
15			0.65					0.7	0.9	0.6	0.7			0.7	
16			0.80					0.9	0.9	0.7	0.7			0.8	
17			0.87					0.8	0.9	0.6	0.7			0.8	
18			0.84					1.0	1.0	0.8	0.8			0.9	
19			0.72					0.8	1.0	0.8	0.9			0.9	
20			0.69					0.9	1.0	0.9	0.9			1.1	
21			0.59					1.0	1.0	0.9	0.9			1.0	
22			0.71					0.8	1.1	0.7	0.9			0.8	
23			0.69					0.9	0.9	0.8	0.8			0.9	
24			0.67					0.7	1.0	0.7	0.8			0.8	
25			0.74					1.0	1.0	0.8	0.8			0.8	
26			0.76					1.0	0.9	0.7	0.8			0.9	
27			0.82					0.8	1.0	0.7	0.8			0.9	
28			0.73					0.7	0.8	0.6	0.7			0.8	
29			0.72					0.8	0.8	0.8	0.8			0.8	
30			0.76					0.8	0.9	0.8	0.8			0.9	
31			0.74					0.8	0.9	0.8	0.9			0.9	
AVG			0.69					0.8	1.2	0.6	0.7			0.8	
MAX			0.87					1.0	9.0	0.9	0.9			1.1	
MIN			0.39					0.7	0.8	0.4	0.3			0.7	



Chemical Analyses

WSSN 2310

Jul-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		n/a		n/a		n/a		n/a				n/a		n/a		
2		7.44		96		73		23				28.9		5.8		
3		7.45		98		73		25				29.7		5.8		
4		7.30		98		74		24				28.9		6.3		
5		7.36		98		70		28				28.1		6.3		
6		7.30		98		74		24				28.9		6.3		
7		7.31		98		73		25				29.7		5.8		
8		7.44		98		71		27				29.7		5.8		
9		7.38		96		70		26				29.7		5.3		
10		7.51		96		74		22				29.7		5.3		
11		7.51		96		71		25				29.7		5.3		
12		7.40		98		71		27				28.9		5.3		
13		7.40		94		71		23				28.1		5.8		
14		7.42		98		74		24				28.1		6.8		
15		7.24		98		73		25				29.7		5.8		
16		7.41		98		74		24				29.7		5.8		
17		7.43		96		72		24				29.7		5.3		
18		7.50		96		73		23				28.9		5.8		
19		7.38		96		71		25				28.9		5.8		
20		7.45		98		71		27				28.9		6.3		
21		7.45		100		72		28				28.9		6.8		
22		7.32		100		74		26				28.9		6.8		
23		7.44		98		72		26				29.7		5.8		
24		7.42		98		73		25				28.9		6.3		
25		7.48		98		72		26				28.9		6.3		
26		7.48		100		73		27				28.9		6.8		
27		7.43		98		72		26				28.9		6.3		
28		7.29		98		74		24				29.7		5.8		
29		7.25		98		72		26				28.9		6.3		
30		7.44		98		72		26				28.9		6.3		
31		7.47		98		68		30				27.3		7.3		
AVG		7.40		98		72		25				29.1		6.1		
MAX		7.51		100		74		30				29.7		7.3		
MIN		7.24		94		68		22				27.3		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Jul-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1	1/0		0/0	0/0	0/0	0/0					n/a				
2	1/0		2/0	2/0	2/0	2/0					20.1				
3	2/0		2/0	2/0	2/0	2/0					19.9				
4	1/0		2/0	2/0	2/0	2/0					21.4				
5	1/0		2/0	2/0	2/0	2/0					21.2				
6	1/0		2/0	2/0	2/0	2/0					21.6				
7	1/0		2/0	2/0	2/0	2/0					21.5				
8	1/0		2/0	2/0	2/0	2/0					20.5				
9	1/0		2/0	2/0	2/0	2/0					19.9				
10	1/0		2/0	2/0	2/0	2/0					20.2				
11	1/0		2/0	2/0	2/0	2/0					20.9				
12	1/0		2/0	2/0	2/0	2/0					21.7				
13	1/0		2/0	2/0	2/0	2/0					21.8				
14	1/0		2/0	2/0	2/0	2/0					23.3				
15	1/0		2/0	2/0	2/0	2/0					22.4				
16	1/0		2/0	2/0	2/0	2/0					22.5				
17	1/0		2/0	2/0	2/0	2/0					21.9				
18	1/0		2/0	2/0	2/0	2/0			< 2		21.4				
19	1/0		2/0	2/0	2/0	2/0					20.7				
20	1/0		2/0	2/0	2/0	2/0					20.3				
21	1/0		2/0	2/0	2/0	2/0					20.3				
22	1/0		2/0	2/0	2/0	2/0					20.7				
23	1/0		2/0	2/0	2/0	2/0					21.7				
24	1/0		2/0	2/0	2/0	2/0					21.9				
25	1/0		2/0	2/0	2/0	2/0					21.4				
26	1/0		2/0	2/0	2/0	2/0					21.0				
27	1/0		2/0	2/0	2/0	2/0					21.5				
28	1/0		2/0	2/0	2/0	2/0					21.8				
29	1/0		2/0	2/0	2/0	2/0					21.8				
30	1/0		2/0	2/0	2/0	2/0					22.3				
31	1/0		2/0	2/0	2/0	2/0					22.5				
											21.3				
											23.3				
											19.9				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				149			
Total number of routine distribution samples required:				100			

DEQ
RESOURCE MANAGEMENT DIVISION

MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT

JUL 12 2012

For Month of June 2012

ENTERED

LANSING DISTRICT

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water


CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MD

[illegible]



Flouridation & Chlorination

WSSN 2310

Jun-12

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well	Tap			
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.75					0.8	0.7	0.6	0.7			0.8	
2			0.74					0.6	0.8	0.7	0.6			0.7	
3			0.71					0.7	0.8	0.7	0.6			0.7	
4			0.72					0.7	0.7	0.5	0.5			0.7	
5			0.73					0.6	0.7	0.5	0.6			0.6	
6			0.72					0.8	0.8	0.5	0.5			0.8	
7			0.70					0.6	0.8	0.5	0.5			0.7	
8			0.70					0.8	0.7	0.5	0.5			0.8	
9			0.71					0.8	0.8	0.5	0.6			0.8	
10			0.67					0.5	0.8	0.5	0.5			0.8	
11			0.64					0.7	0.8	0.5	0.5			0.7	
12			0.67					0.8	0.8	0.5	0.5			0.7	
13			0.71					0.7	0.7	0.4	0.5			0.7	
14			0.66					0.7	0.7	0.4	0.5			0.7	
15			0.70					0.7	0.8	0.4	0.5			0.9	
16			0.71					0.8	0.7	0.5	0.5			0.7	
17			0.67					0.8	0.7	0.5	0.4			0.6	
18			0.69					0.7	0.8	0.5	0.5			0.7	
19			0.69					0.7	0.8	0.4	0.4			0.7	
20			0.67					0.8	0.8	0.4	0.4			0.7	
21			0.69					0.7	0.8	0.4	0.4			0.9	
22			0.67					0.8	0.8	0.4	0.4			0.9	
23			0.69					0.8	0.9	0.4	0.4			0.9	
24			0.60					0.7	0.9	0.4	0.4			0.8	
25			0.67					0.7	0.8	0.4	0.4			0.5	
26			0.60					0.8	0.9	0.5	0.4			0.8	
27			0.68					0.7	0.9	0.4	0.4			0.8	
28			0.67					0.8	0.8	0.4	0.5			0.8	
29			0.68					0.7	0.8	0.4	0.5			0.8	
30			0.68					0.9	0.8	0.4	0.5			0.9	
AVG			0.69					0.7	0.8	0.5	0.5			0.8	
MAX			0.75					0.9	0.9	0.7	0.7			0.9	
MIN			0.60					0.5	0.7	0.4	0.4			0.5	



Chemical Analyses

WSSN 2310

Jun-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.40		100		72		28				29.7		6.3		
2		7.40		98		71		27				29.7		5.8		
3		7.31		98		75		23				29.7		5.8		
4		7.45		98		74		24				28.9		6.3		
5		7.41		98		70		28				28.9		6.3		
6		7.42		98		72		26				30.5		5.3		
7		7.60		98		70		28				29.7		5.8		
8		7.43		98		72		26				28.9		6.3		
9		7.43		96		71		25				28.9		5.8		
10		7.42		98		71		27				29.7		5.8		
11		7.42		98		69		29				29.7		5.8		
12		7.38		98		72		26				29.7		5.8		
13		7.37		98		71		27				28.9		6.3		
14		7.54		98		72		26				29.7		5.8		
15		7.41		94		70		24				28.1		5.8		
16		7.46		96		71		25				28.9		5.8		
17		7.53		96		64		32				26.5		7.3		
18		7.44		98		74		24				29.7		5.8		
19		7.47		98		71		27				29.7		5.8		
20		7.46		98		72		26				29.7		5.8		
21		7.46		90		68		22				24.0		7.3		
22		7.50		94		71		23				28.1		5.8		
23		7.45		94		71		23				28.1		5.8		
24		7.34		98		68		30				29.7		5.8		
25		7.43		98		72		26				29.7		5.8		
26		7.61		98		74		24				29.7		5.8		
27		7.42		98		70		28				30.5		5.3		
28		7.42		94		71		23				28.9		5.3		
29		7.43		98		70		28				29.7		5.8		
30		7.41		92		71		21				28.1		5.3		
AVG		7.44		97		71		26				29.1		5.9		
MAX		7.61		100		75		32				30.5		7.3		
MIN		7.31		90		64		21				24.0		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Jun-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					15.1				
2	1/0		2/0	2/0	2/0	2/0					14.5				
3	1/0		2/0	2/0	2/0	2/0					14.9				
4	1/0		2/0	2/0	2/0	2/0					15.8				
5	1/0		2/0	2/0	2/0	2/0					15.7				
6	1/0		2/0	2/0	2/0	2/0					16.2				
7	1/0		2/0	2/0	2/0	2/0					15.8				
8	1/0		2/0	2/0	2/0	2/0					15.3				
9	1/0		2/0	2/0	2/0	2/0					16.5				
10	1/0		2/0	2/0	2/0	2/0					16.1				
11	1/0		2/0	2/0	2/0	2/0					16.3				
12	1/0		2/0	2/0	2/0	2/0					16.1				
13	1/0		2/0	2/0	2/0	2/0					16.7				
14	1/0		2/0	2/0	2/0	2/0					16.0				
15	1/0		2/0	2/0	2/0	2/0					17.1				
16	1/0		2/0	2/0	2/0	2/0					17.0				
17	1/0		2/0	2/0	2/0	2/0					17.2				
18	1/0		2/0	2/0	2/0	2/0					18.0				
19	1/0		2/0	2/0	2/0	2/0					18.9				
20	1/0		2/0	2/0	2/0	2/0					18.7				
21	1/0		2/0	2/0	2/0	2/0					18.4				
22	1/0		2/0	2/0	2/0	2/0					18.8				
23	1/0		2/0	2/0	2/0	2/0					17.8				
24	1/0		2/0	2/0	2/0	2/0					17.7				
25	1/0		2/0	2/0	2/0	2/0					17.0				
26	1/0		2/0	2/0	2/0	2/0					17.9				
27	1/0		2/0	2/0	2/0	2/0									
28	1/0		2/0	2/0	2/0	2/0					19.5				
29	1/0		2/0	2/0	2/0	2/0					21.6				
30	1/0		2/0	2/0	2/0	2/0					21.2				
											17.2				
											21.6				
											14.5				

Distribution System Monitoring WSSN 2310 Jun-12

[illegible]



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Jun-12

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				156			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of May 2012



Flint Water Plant
NAME OF WATER SYSTEM

2310

Genesee
COUNTY

DEQ
RESOURCE MANAGEMENT DIVISION

Michael Glasgow
CERTIFIED OPERATOR

JUN 13 2012

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

LANSING DISTRICT

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃⁺) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

[illegible]



Flouridation & Chlorination

WSSN 2310

May-12

DATE	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.64					0.8	0.8	n/a	0.9			0.8	
2			0.66					0.9	n/a	n/a	1.0			0.9	
3			0.63					0.8	n/a	n/a	1.0			0.8	
4			0.67					0.8	0.9	n/a	1.0			1.0	
5			0.67					0.9	1.1	0.9	1.1			1.1	
6			0.60					0.8	0.9	0.9	1.0			0.9	
7			0.63					0.9	1.0	1.0	1.0			0.9	
8			0.62					0.8	1.0	0.9	1.0			1.0	
9			0.68					0.8	0.9	0.9	1.0			0.8	
10			0.63					0.8	0.9	0.9	0.9			0.8	
11			0.67					0.8	0.9	0.9	1.0			0.9	
12								0.8	0.9	0.9	1.0			0.9	
13			0.67					0.7	0.8	0.9	0.9			0.8	
14			0.68					0.7	0.7	0.8	0.8			0.8	
15			0.65					0.6	0.8	0.7	0.8			0.7	
16			0.66					0.7	0.7	0.8	0.8			0.8	
17			0.64					0.6	0.7	0.7	0.8			0.7	
18			0.69					0.7	0.7	0.7	0.8			0.8	
19			0.74					0.7	0.7	0.7	0.7			0.8	
20			0.71					0.8	0.7	0.7	0.7			0.7	
21			0.71					0.8	0.7	0.7	0.7			0.6	
22			0.70					0.8	0.8	0.8	0.8			0.7	
23			0.71					0.7	0.8	0.7	0.7			0.7	
24			0.76					0.8	0.8	0.7	0.8			0.8	
25			0.71					0.7	0.8	0.7	0.7			0.8	
26			0.69					0.9	0.8	0.7	0.7			0.7	
27			0.69					0.6	0.8	0.7	0.7			0.7	
28			0.73					0.6	0.7	0.7	0.6			0.7	
29			0.72					0.7	0.7	0.7	0.7			0.7	
30			0.68					0.7	0.8	0.6	0.6			0.7	
31			0.70					0.6	0.7	0.6	0.6			0.7	
AVG			0.68					0.8	0.8	0.8	0.8			0.8	
MAX			0.76					0.9	1.1	1.0	1.1			1.1	
MIN			0.60					0.6	0.7	0.6	0.6			0.6	




Chemical Analyses

WSSN 2310

May-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.38		100		73		27				30.5		5.8		
2		7.35		98		74		24				31.3		4.9		
3		7.39		100		71		29				32.9		4.4		
4		7.38		102		75		27				31.3		5.8		
5		7.35		104		73		31				31.3		6.3		
6		7.28		98		70		28				30.5		5.3		
7		7.27		102		70		32				30.5		6.3		
8		7.24		98		73		25				30.5		5.3		
9		7.35		98		72		26				31.3		4.9		
10		7.36		100		74		26				30.5		5.8		
11		7.37		104		73		31				30.5		6.8		
12		7.43		104		73		31				30.5		6.8		
13		7.40		102		75		27				32.9		4.9		
14		7.37		104		68		36				31.3		6.3		
15		7.33		100		75		25				30.5		5.8		
16		7.39		100		75		25				31.3		5.3		
17		7.43		100		71		29				30.5		5.8		
18		7.33		100		74		26				30.5		5.8		
19		7.40		106		72		34				28.9		8.3		
20		7.34		100		75		25				30.5		5.9		
21		7.45		100		71		29				30.5		5.9		
22		7.39		98		72		26				31.3		4.9		
23		7.54		98		75		23				32.1		4.4		
24		7.40		102		73		29				28.9		7.3		
25		7.39		98		71		27				29.7		5.8		
26		7.26		98		71		27				29.7		5.8		
27		7.26		98		73		25				29.7		5.8		
28		7.34		98		72		26				28.9		6.3		
29		7.36		98		75		23				28.9		6.3		
30		7.59		98		73		25				29.7		5.8		
31		7.50		98		71		27				30.5		5.3		
AVG		7.37		100		73		27				30.6		5.8		
MAX		7.59		106		75		36				32.9		8.3		
MIN		7.24		98		68		23				28.9		4.4		



Bacteriological & Physical Parameters

WSSN 2310

May-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Sta II	Lab Tap									
	60	61	62	63	64	65									
1	1/0		0/0	2/0	2/0	2/0					9.6				
2	1/0		0/0	2/0	0/0	2/0					11.9				
3	1/0		0/0	2/0	0/0	2/0					11.8				
4	1/0		2/0	2/0	2/0	2/0					12.0				
5	1/0		2/0	2/0	2/0	2/0					11.4				
6	1/0		2/0	2/0	2/0	2/0					11.2				
7	1/0		2/0	2/0	2/0	2/0					11.4				
8	1/0		2/0	2/0	2/0	2/0					12.6				
9	1/0		2/0	2/0	2/0	2/0					11.1				
10	1/0		2/0	2/0	2/0	2/0					11.0				
11	1/0		2/0	2/0	2/0	2/0					12.1				
12	1/0		2/0	2/0	2/0	2/0					11.7				
13	1/0		2/0	2/0	2/0	2/0					11.7				
14	1/0		2/0	2/0	2/0	2/0					12.4				
15	1/0		2/0	2/0	2/0	2/0					11.5				
16	1/0		2/0	2/0	2/0	2/0					11.3				
17	1/0		2/0	2/0	2/0	2/0			< 2		11.4				
18	1/0		2/0	2/0	2/0	2/0					12.7				
19	1/0		2/0	2/0	2/0	2/0					12.4				
20	1/0		2/0	2/0	2/0	2/0					13.1				
21	1/0		2/0	2/0	2/0	2/0					13.4				
22	1/0		2/0	2/0	2/0	2/0					13.5				
23	1/0		2/0	2/0	2/0	2/0					13.6				
24	1/0		2/0	2/0	2/0	2/0					14.3				
25	1/0		2/0	2/0	2/0	2/0					15.3				
26	1/0		2/0	2/0	2/0	2/0					14.8				
27	1/0		2/0	2/0	2/0	2/0					15.3				
28	1/0		2/0	2/0	2/0	2/0					15.3				
29	1/0		2/0	2/0	2/0	2/0					14.9				
30	1/0		2/0	2/0	2/0	2/0					14.8				
31	1/0		2/0	2/0	2/0	2/0					14.8				
											12.7				
											15.3				
											9.6				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				144			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

DEQ
RESOURCE MANAGEMENT DIVISION

MAY 14 2012

For Month of April 2012

LANSING DISTRICT

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

ENTERED

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

Apr-12

[illegible]



Flouridation & Chlorination

WSSN 2310

Apr-12

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCI-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well			Tap	
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.67					0.8	0.8	0.7	0.8			0.7	
2			0.66					0.8	0.7	0.7	0.7			0.8	
3			0.64					0.8	0.8	0.6	0.7			0.8	
4			0.68					0.8	0.7	0.6	0.7			0.7	
5			0.71					0.7	0.7	0.5	0.6			0.7	
6			0.68					0.7	0.7	0.6	0.7			0.8	
7			0.67					0.8	0.7	0.7	0.6			0.7	
8			0.65					0.6	0.7	0.5	0.6			0.7	
9			0.68					0.7	0.7	0.5	0.7			0.7	
10			0.68					0.8	0.7	0.5	0.6			0.8	
11			0.69					0.7	0.7	0.5	0.6			0.7	
12			0.66					0.7	0.6	0.5	0.6			0.6	
13			0.67					0.7	0.7	0.5	0.7			0.8	
14			0.70					0.7	0.8	0.5	0.7			0.8	
15			0.66					0.7	0.7	0.5	0.6			0.8	
16			0.69					0.7	0.7	0.5	0.7			0.8	
17			0.69					0.5	0.7	0.6	0.6			0.8	
18			0.66					0.8	0.6	0.5	0.6			0.6	
19			0.74					0.8	0.8	0.5	0.7			0.8	
20			0.71					0.8	0.7	0.5	0.7			0.8	
21			0.66					0.7	0.8	0.4	0.5			0.8	
22			0.59					0.8	0.7	0.5	0.5			0.8	
23			0.68					0.7	0.8	0.5	0.6			0.9	
24			0.66					0.9	0.8	0.5	0.5			0.7	
25			0.69					0.9	0.8	0.5	0.7			0.8	
26			0.66					0.9	0.9	n/a	1.0			1.0	
27			0.64					0.8	0.8	n/a	1.0			0.8	
28			0.67					0.8	n/a	n/a	0.9			1.0	
29			0.67					0.8	0.7	n/a	0.8			0.7	
30			0.66					0.8	0.9	n/a	1.0			0.8	
AVG			0.67					0.8	0.7	0.5	0.7			0.8	
MAX			0.74					0.9	0.9	0.7	1.0			1.0	
MIN			0.59					0.5	0.6	0.4	0.5			0.6	



Chemical Analyses

WSSN 2310

Apr-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.39		98		72		26				29.7		5.8		
2		7.33		98		70		28				30.5		5.3		
3		7.33		98		70		28				31.3		4.9		
4		7.33		100		70		30				30.5		5.8		
5		7.42		98		68		30				30.5		5.3		
6		7.33		98		72		26				29.7		5.8		
7		7.35		98		70		28				30.5		5.3		
8		7.26		100		72		28				28.9		6.8		
9		7.32		98		68		30				30.5		5.3		
10		7.35		98		72		26				30.5		5.3		
11		7.32		100		73		27				30.5		5.8		
12		7.33		98		70		28				30.5		5.3		
13		7.34		100		73		27				29.7		6.3		
14		7.38		98		74		24				30.5		5.3		
15		7.34		98		73		25				30.5		5.3		
16		7.39		98		75		23				29.7		5.8		
17		7.34		100		73		27				30.5		5.8		
18		7.45		98		72		26				29.7		5.8		
19		7.37		98		72		26				30.5		5.3		
20		7.36		100		71		29				29.7		6.3		
21		7.39		98		70		28				29.7		5.8		
22		7.28		98		73		25				30.5		5.3		
23		7.48		98		72		26				28.9		6.3		
24		7.41		98		74		24				30.5		5.3		
25		7.48		98		73		25				30.5		5.3		
26		7.35		100		71		29				29.7		6.3		
27		7.42		100		71		29				30.5		5.8		
28		7.28		102		71		31				29.7		6.8		
29		7.33		100		70		30				30.5		5.8		
30		7.43		100		65		35				30.5		5.8		
AVG		7.36		99		71		27				30.2		5.7		
MAX		7.48		102		75		35				31.3		6.8		
MIN		7.26		98		65		23				28.9		4.9		


Bacteriological & Physical Parameters
WSSN 2310
Apr-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap		
	B&P		Dort	3MG Well	Sta. II	Lab Tap									
														60	61
1	1/0		2/0	2/0	2/0	2/0					9.3				
2	1/0		2/0	2/0	2/0	2/0					10.3				
3	1/0		2/0	2/0	2/0	2/0					10.8				
4	1/0		2/0	2/0	2/0	2/0					12.2				
5	1/0		2/0	2/0	2/0	2/0			< 2		9.7				
6	1/0		2/0	2/0	2/0	2/0					10.4				
7	1/0		2/0	2/0	2/0	2/0					9.9				
8	1/0		2/0	2/0	2/0	2/0					9.9				
9	1/0		2/0	2/0	2/0	2/0					10.7				
10	1/0		2/0	2/0	2/0	2/0					9.9				
11	1/0		2/0	2/0	2/0	2/0					9.3				
12	1/0		2/0	2/0	2/0	2/0					10.1				
13	1/0		2/0	2/0	2/0	2/0					10.3				
14	1/0		2/0	2/0	2/0	2/0					10.5				
15	1/0		2/0	2/0	2/0	2/0					10.6				
16	1/0		2/0	2/0	2/0	2/0					10.3				
17	1/0		2/0	2/0	2/0	2/0					10.4				
18	1/0		2/0	2/0	2/0	2/0					10.6				
19	1/0		2/0	2/0	2/0	2/0					11.1				
20	1/0		2/0	2/0	2/0	2/0					11.2				
21	1/0		2/0	2/0	2/0	2/0					9.9				
22	1/0		2/0	2/0	2/0	2/0					8.9				
23	1/0		2/0	2/0	2/0	2/0					9.5				
24	1/0		2/0	2/0	2/0	2/0					9.3				
25	1/0		1/0	2/0	2/0	2/0					9.3				
26	1/0		0/0	2/0	2/0	2/0					10.5				
27	1/0		0/0	2/0	2/0	2/0					10.3				
28	1/0		0/0	2/0	0/0	2/0					10.5				
29	1/0		0/0	2/0	2/0	2/0					9.3				
30	1/0		0/0	2/0	2/0	2/0					9.3				
											10.1				
											12.2				
											8.9				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				142			
Total number of routine distribution samples required:				100			

2310

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of March 2012

 **ENTERED**

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3

CLASSIFICATION

DEQ

RESOURCE MANAGEMENT DIVISION


SIGNATURE OF APPROPRIATE OFFICIAL

APR 09 2012

LANSING DISTRICT

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al₃⁺) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MP

Mar-12

[illegible]



Flouridation & Chlorination

WSSN 2310

Mar-12

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
		Raw	Tap	Dist		Chlorine (prior to filtration) mg/L OCI-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well	Tap			
								Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.61					0.8	0.9	0.8	0.8			0.9	
2			0.61					0.9	1.0	0.7	0.9			0.9	
3			0.63					0.9	0.8	0.8	0.8			0.8	
4			0.60					0.8	0.8	0.7	0.8			0.8	
5			0.62					0.9	0.7	0.7	0.8			0.8	
6			0.62					0.8	0.9	0.7	0.9			0.9	
7			0.60					0.8	0.9	0.8	0.7			0.8	
8			0.61					0.9	1.0	0.8	0.8			0.9	
9			0.65					0.9	0.9	0.6	0.8			0.8	
10			0.59					0.8	0.9	0.8	0.7			0.7	
11			0.64					0.8	0.9	0.8	0.8			0.9	
12			0.64					0.8	0.7	0.7	0.8			0.7	
13			0.63					0.9	0.8	0.7	0.8			0.9	
14			0.60					0.8	0.9	0.7	0.7			0.8	
15			0.63					0.8	0.8	0.7	0.9			0.8	
16			0.64					0.9	0.7	0.7	0.8			0.9	
17			0.64					0.8	0.8	0.7	0.8			0.8	
18			0.55					0.8	0.9	0.8	0.8			0.8	
19			0.59					0.8	0.9	0.8	0.8			0.8	
20			0.62					0.9	0.8	0.8	0.8			0.9	
21			0.65					0.8	0.9	0.8	0.8			0.8	
22			0.64					0.8	0.9	0.8	0.9			0.8	
23			0.70					0.8	0.9	0.8	0.9			0.9	
24			0.70					0.9	0.9	0.7	0.8			0.9	
25			n/a					0.8	0.7	0.8	0.7			0.7	
26			0.66					0.8	0.9	0.8	0.8			0.9	
27			0.71					0.7	1.0	0.7	0.8			0.9	
28			0.70					0.8	0.7	0.7	0.8			0.7	
29			0.64					0.8	0.8	0.8	0.8			0.8	
30			0.71					0.8	0.8	0.7	0.8			0.8	
31			0.65					0.9	0.7	0.7	0.7			0.7	
AVG			0.64					0.8	0.8	0.7	0.8			0.8	
MAX			0.71					0.9	1.0	0.8	0.9			0.9	
MIN			0.55					0.7	0.7	0.6	0.7			0.7	



Chemical Analyses

WSSN 2310

Mar-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.20		100		69		31				28.9		6.8		
2		7.34		96		69		27				28.1		6.3		
3		7.27		98		74		24				29.7		5.8		
4		7.26		98		71		27				29.7		5.8		
5		7.36		100		69		31				29.7		6.3		
6		7.30		96		68		28				28.1		6.3		
7		7.24		96		68		28				29.7		5.3		
8		7.29		98		66		32				28.1		6.8		
9		7.36		96		72		24				28.1		6.3		
10		7.29		98		70		28				29.7		5.8		
11		7.30		96		72		24				28.9		5.3		
12		7.34		96		72		24				28.1		6.3		
13		7.30		98		71		27				28.1		6.8		
14		7.32		98		71		27				29.7		5.8		
15		7.33		100		71		29				28.9		6.8		
16		7.30		98		72		26				29.7		5.8		
17		7.36		98		72		26				28.9		6.3		
18		7.28		98		72		26				29.7		5.8		
19		7.36		100		70		30				29.7		6.3		
20		7.34		98		71		27				28.9		6.3		
21		7.48		98		71		27				29.7		5.8		
22		7.44		100		71		29				28.1		7.3		
23		7.36		94		69		25				29.7		4.9		
24		7.39		96		74		22				28.9		5.8		
25		7.34		n/a		n/a		n/a				n/a		n/a		
26		7.39		96		71		25				28.1		6.3		
27		7.44		98		70		28				28.9		6.3		
28		7.37		96		70		26				28.9		5.8		
29		7.43		96		71		25				29.7		5.3		
30		7.32		96		71		25				29.7		5.3		
31		7.31		106		66		40				28.9		8.3		
AVG		7.34		98		70		27				29.0		6.1		
MAX		7.48		106		74		40				29.7		8.3		
MIN		7.20		94		66		22				28.1		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Mar-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					11.5				
2	1/0		2/0	2/0	2/0	2/0					11.2				
3	1/0		2/0	2/0	2/0	2/0					9.7				
4	1/0		2/0	2/0	2/0	2/0					9.2				
5	1/0		2/0	2/0	2/0	2/0					9.9				
6	1/0		2/0	2/0	2/0	2/0					10.1				
7	1/0		2/0	2/0	2/0	2/0					9.0				
8	1/0		2/0	2/0	2/0	2/0			<2		10.3				
9	1/0		2/0	2/0	2/0	2/0					9.5				
10	1/0		2/0	2/0	2/0	2/0					7.7				
11	1/0		2/0	2/0	2/0	2/0					8.0				
12	1/0		2/0	2/0	2/0	2/0					8.4				
13	1/0		2/0	2/0	2/0	2/0					8.9				
14	1/0		2/0	2/0	2/0	2/0					7.7				
15	1/0		2/0	2/0	2/0	2/0					9.1				
16	1/0		2/0	2/0	2/0	2/0					9.5				
17	1/0		2/0	2/0	2/0	2/0					8.4				
18	1/0		2/0	2/0	2/0	2/0					8.8				
19	1/0		2/0	2/0	2/0	2/0					9.0				
20	1/0		2/0	2/0	2/0	2/0					10.6				
21	1/0		2/0	2/0	2/0	2/0					9.3				
22	1/0		2/0	2/0	2/0	2/0					9.7				
23	1/0		2/0	2/0	2/0	2/0					11.6				
24	1/0		2/0	2/0	2/0	2/0					11.4				
25	1/0		1/0	1/0	1/0	1/0					n/a				
26	1/0		2/0	2/0	2/0	2/0					10.9				
27	1/0		2/0	2/0	2/0	2/0					9.8				
28	1/0		2/0	2/0	2/0	2/0					10.3				
29	1/0		2/0	2/0	2/0	2/0					9.4				
30	1/0		2/0	2/0	2/0	2/0					9.8				
31	1/0		2/0	2/0	2/0	2/0					9.9				
											9.6				
											11.6				
											7.7				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				160			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

2310
 **ENTERED**

For Month of February 2012

Flint Water Plant
NAME OF WATER SYSTEM

2310
WSSN

Genesee
COUNTY

Michael Glasgow
CERTIFIED OPERATOR

F-1R S-3
CLASSIFICATION


SIGNATURE OF APPROPRIATE OFFICIAL

DEQ
RESOURCE MANAGEMENT DIVISION

MAR 07 2012

LANSING DISTRICT

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

[illegible]



Flouridation & Chlorination

WSSN 2310

Feb-12

DATE	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well			Tap	
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.60					0.9	0.7	0.8	0.8			0.8	
2			0.64					0.9	0.7	0.7	0.8			0.9	
3			0.67					0.8	0.9	0.7	0.9			0.9	
4			0.66					0.8	0.9	0.8	0.8			0.9	
5			0.64					0.8	0.8	0.8	0.8			0.9	
6			0.62					0.8	0.8	0.8	0.8			0.8	
7			0.64					0.8	0.9	0.7	0.9			0.9	
8			0.62					0.9	1.0	0.8	0.8			0.7	
9			0.68					0.8	0.9	0.7	0.9			0.9	
10			0.61					0.9	0.9	0.8	0.9			0.8	
11			0.62					0.8	0.8	0.7	0.7			0.8	
12			0.61					0.9	0.9	0.7	0.8			0.8	
13			0.64					0.8	0.8	0.7	0.8			0.8	
14			0.58					0.8	0.8	0.8	0.8			0.9	
15			0.57					0.8	0.8	0.8	0.8			0.8	
16			0.61					0.9	0.8	0.8	0.9			0.9	
17			0.62					0.8	0.8	0.8	0.8			0.8	
18			0.61					0.8	0.7	0.8	0.8			0.7	
19			0.62					0.8	0.7	0.7	0.9			0.8	
20			0.62					0.8	0.8	0.7	0.8			0.7	
21			0.66					0.7	0.8	0.7	0.8			0.7	
22			0.66					0.9	0.8	0.7	0.8			0.9	
23			0.65					0.9	0.8	0.8	0.8			0.8	
24			0.67					0.9	0.8	0.7	0.8			0.8	
25			0.67					0.8	0.9	0.7	0.8			0.8	
26			0.63					0.9	0.8	0.8	0.8			0.7	
27			0.65					0.8	0.9	0.7	0.8			0.7	
28			0.65					0.9	0.8	0.8	0.8			0.9	
29			0.55					0.9	0.8	0.7	0.7			0.8	
AVG			0.63					0.8	0.8	0.7	0.8			0.8	
MAX			0.68					0.9	1.0	0.8	0.9			0.9	
MIN			0.55					0.7	0.7	0.7	0.7			0.7	



Chemical Analyses

WSSN 2310

Feb-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium as Ca 2+ mg/l		Magnesium as Mg 2+ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.26		96		67		29				27.3		6.8		
2		7.29		98		71		27				28.1		6.8		
3		7.34		96		69		27				28.1		6.3		
4		7.32		96		66		30				27.3		7.3		
5		7.27		96		74		22				28.9		5.8		
6		7.34		96		67		29				29.7		5.3		
7		7.28		96		71		25				28.1		6.3		
8		7.39		98		71		27				29.7		5.8		
9		7.36		96		67		29				28.1		6.3		
10		7.39		98		70		28				29.7		5.8		
11		7.28		98		70		28				28.9		6.3		
12		7.28		98		70		28				29.7		5.8		
13		7.34		98		67		31				25.7		8.3		
14		7.33		98		72		26				29.7		5.8		
15		7.43		100		72		28				29.7		6.3		
16		7.20		92		69		23				28.1		5.3		
17		7.34		98		69		29				29.7		5.8		
18		7.18		98		66		32				28.9		6.3		
19		7.18		100		72		28				29.7		6.3		
20		7.28		98		68		30				29.7		5.8		
21		7.18		100		70		30				29.7		6.3		
22		7.32		90		65		25				28.1		4.9		
23		7.22		98		70		28				27.3		7.3		
24		7.26		98		70		28				27.3		7.3		
25		7.32		96		71		25				28.1		6.3		
26		7.40		98		72		26				29.7		5.8		
27		7.47		98		68		30				28.9		6.3		
28		7.30		98		70		28				28.1		6.8		
29		7.28		98		64		34				29.7		5.8		
AVG		7.30		97		69		28				28.7		6.3		
MAX		7.47		100		74		34				29.7		8.3		
MIN		7.18		90		64		22				25.7		4.9		



Bacteriological & Physical Parameters

WSSN 2310

Feb-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
	60	61	62	63	64	65									
1	1/0		2/0	2/0	2/0	2/0					11.9				
2	1/0		2/0	2/0	2/0	2/0					11.9				
3	1/0		2/0	2/0	2/0	2/0					12.2				
4	1/0		2/0	2/0	2/0	2/0					11.7				
5	1/0		2/0	2/0	2/0	2/0					12.1				
6	1/0		2/0	2/0	2/0	2/0					11.6				
7	1/0		2/0	2/0	2/0	2/0					10.3				
8	1/0		2/0	2/0	2/0	2/0					8.4				
9	1/0		2/0	2/0	2/0	2/0					10.0				
10	1/0		2/0	2/0	2/0	2/0					9.4				
11	1/0		2/0	2/0	2/0	2/0					8.3				
12	1/0		2/0	2/0	2/0	2/0					8.5				
13	1/0		2/0	2/0	2/0	2/0					10.5				
14	1/0		2/0	2/0	2/0	2/0					9.7				
15	1/0		2/0	2/0	2/0	2/0					9.7				
16	1/0		2/0	2/0	2/0	2/0		< 2			11.3				
17	1/0		2/0	2/0	2/0	2/0					10.1				
18	1/0		2/0	2/0	2/0	2/0					8.8				
19	1/0		2/0	2/0	2/0	2/0					8.5				
20	1/0		2/0	2/0	2/0	2/0					8.6				
21	1/0		2/0	2/0	2/0	2/0					8.8				
22	1/0		2/0	2/0	2/0	2/0					11.2				
23	1/0		2/0	2/0	2/0	2/0					9.8				
24	1/0		2/0	2/0	2/0	2/0					8.8				
25	1/0		2/0	2/0	2/0	2/0					9.9				
26	1/0		2/0	2/0	2/0	2/0					9.7				
27	1/0		2/0	2/0	2/0	2/0					9.5				
28	1/0		2/0	2/0	2/0	2/0					10.2				
29	1/0		2/0	2/0	2/0	2/0					8.8				
											10.0				
											12.2				
											8.3				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				135			
Total number of routine distribution samples required:				100			

**MONTHLY OPERATION REPORT
OF
WATER TREATMENT PLANT**

For Month of January 2012



Flint Water Plant
NAME OF WATER SYSTEM

2310

Genesee

WSSN

COUNTY

DEQ

RESOURCE MANAGEMENT DIVISION

F-1R S-3

CLASSIFICATION

Michael Glasgow
CERTIFIED OPERATOR

FEB 13 2012

LANSING DISTRICT

Michael Glasgow
SIGNATURE OF APPROPRIATE OFFICIAL

TREATMENT RATE AND FILTER DATA

1. Treatment Rate, Maximum _____ Million Gallons Per Day
2. Treatment Rate, Approved Rated Plant Capacity _____ Million Gallons per Day
3. Average Filter Run _____ Hours, Average Head Loss _____ Feet
4. Average Filtration Rate _____ Gallons per Square Ft. per Minute
5. Maximum Filtration Rate _____ Gallons per Square Ft. per Minute
6. Average Wash Water Use _____ percent of Treated Water

CHEMICAL DATA

7. Chlorine on hand _____ lbs.: Estimated supply _____ days
8. Lime (CaO) on hand _____ lbs.: Estimated supply _____ days
9. Alum (Al3+) on hand _____ lbs.: Estimated supply _____ days
10. Cost of All Chemicals per Million Gallons _____
11. Total Power Cost per Million Gallons _____

Remarks:

Submit to: Mike Prysby, P.E.
MDEQ-Water Division-Lansing District
P.O. Box 30242
Lansing, MI 48909

MD

Jan-12[illegible]



Flouridation & Chlorination

WSSN 2310

Jan-12

D A T E	Fluoride Applied F- mg/l	Fluoride Analyses mg/l			Chlorine App. Mg/l			Chlorine Residual mg/l							
						Chlorine (prior to filtration) mg/L OCl-	Post Chlorine mg/L	B&P	Sta II	Dort	3MG Well		Tap		
		Raw	Tap	Dist				Free	Free	Free	Free			Free	
	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
1			0.56					0.8	0.8	0.7	0.7			0.6	
2			0.56					0.9	0.8	0.7	0.7			0.6	
3			0.59					0.9	0.9	0.8	0.7			0.9	
4			0.64					0.9	0.8	0.7	0.7			0.8	
5			0.63					0.7	0.8	0.7	0.7			0.7	
6			0.65					0.9	0.8	0.7	0.8			0.8	
7			0.65					0.8	0.8	0.7	0.7			0.7	
8			0.67					0.9	0.8	0.8	0.7			0.8	
9			0.69					0.8	0.8	0.7	0.8			0.8	
10			0.68					0.6	0.9	0.7	0.8			0.7	
11			0.70					0.8	0.7	0.7	0.7			0.8	
12			0.65					0.8	0.8	0.7	0.8			0.7	
13			0.68					0.8	0.8	0.7	0.8			0.7	
14			0.62					0.8	0.8	0.7	0.7			0.8	
15			0.61					0.7	0.8	0.7	0.8			0.7	
16			0.65					0.7	0.8	0.7	0.7			0.7	
17			0.66					0.9	0.8	0.7	0.8			0.8	
18			0.65					0.9	0.8	0.7	0.8			0.8	
19			0.67					0.9	0.9	0.7	0.8			0.9	
20			0.69					0.8	0.8	0.7	0.8			0.8	
21			0.62					0.7	0.8	0.7	0.7			0.7	
22			0.60					0.8	0.7	0.7	0.7			0.8	
23			0.64					0.7	0.8	0.7	0.8			0.7	
24			0.65					0.9	0.9	0.7	0.8			0.9	
25			0.62					0.9	0.8	0.7	0.8			0.9	
26			0.63					0.8	0.9	0.7	0.9			0.8	
27			0.62					0.9	0.9	0.8	0.9			0.8	
28			0.67					0.7	0.8	0.7	0.8			0.7	
29			0.66					0.7	0.8	0.7	0.7			0.8	
30			0.64					0.8	0.9	0.7	0.8			0.7	
31			0.64					0.8	0.9	0.6	0.8			0.7	
AVG			0.64					0.8	0.8	0.7	0.8			0.8	
MAX			0.70					0.9	0.9	0.8	0.9			0.9	
MIN			0.56					0.6	0.7	0.6	0.7			0.6	



Chemical Analyses

WSSN 2310

Jan-12

D A T E	pH		Total Hard as CaCO ₃ mg/l		Total Alk as CaCO ₃ mg/l		NonCarbonate Hardness as CaCO ₃ mg/l				Calcium Ca ++ mg/l		Magnesium as Mg ++ mg/l		Chloride as Cl - mg/l	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
1		7.31		98		69		29				29.7		5.8		
2		7.36		98		71		27				29.7		5.8		
3		7.36		98		69		29				28.1		6.8		
4		7.31		102		68		34				28.9		7.3		
5		7.46		98		72		26				29.7		5.8		
6		7.31		94		69		25				27.3		6.3		
7		7.43		98		73		25				29.7		5.8		
8		7.34		94		71		23				27.3		6.3		
9		7.31		96		69		27				28.1		6.3		
10		7.26		96		71		25				28.1		6.3		
11		7.25		96		66		30				27.3		6.8		
12		7.36		96		72		24				29.7		5.3		
13		7.20		98		70		28				29.7		5.8		
14		7.24		98		67		31				29.7		5.8		
15		7.24		96		71		25				29.7		5.3		
16		7.26		98		69		29				29.7		5.8		
17		7.38		100		66		34				31.3		5.3		
18		7.35		96		70		26				27.3		6.8		
19		7.25		98		70		28				28.1		6.8		
20		7.22		96		70		26				27.3		6.8		
21		7.24		96		70		26				28.9		5.3		
22		7.21		96		69		27				29.7		5.3		
23		7.32		96		69		27				28.9		5.8		
24		7.23		98		68		30				28.9		6.3		
25		7.28		94		68		26				26.5		6.8		
26		7.24		96		71		25				27.3		6.8		
27		7.26		96		69		27				27.3		6.8		
28		7.21		96		71		25				28.1		6.3		
29		7.16		98		73		25				28.9		6.3		
30		7.31		98		67		31				29.7		5.8		
31		7.36		98		72		26				29.7		5.8		
AVG		7.29		97		70		27				28.7		6.1		
MAX		7.46		102		73		34				31.3		7.3		
MIN		7.16		94		66		23				26.5		5.3		



Bacteriological & Physical Parameters

WSSN 2310

Jan-12

D A T E	Total Coliform							Standard Plate Count		Wind Direction	Temp deg.C	Color		Odor	
	Plant Tap							Raw	Tap			Raw	Tap	Raw	Tap
	B&P		Dort	3MG Well	Pump	Lab Tap									
60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	
1	1/0		2/0	2/0	2/0	2/0					13.5				
2	1/0		2/0	2/0	2/0	2/0					12.2				
3	1/0		2/0	2/0	2/0	2/0					12.1				
4	1/0		2/0	2/0	2/0	2/0					15.2				
5	1/0		2/0	2/0	2/0	2/0					10.3				
6	1/0		2/0	2/0	2/0	2/0					14.2				
7	1/0		2/0	2/0	2/0	2/0					12.4				
8	1/0		2/0	2/0	2/0	2/0					12.7				
9	1/0		2/0	2/0	2/0	2/0					13.5				
10	1/0		2/0	2/0	2/0	2/0					12.9				
11	1/0		2/0	2/0	2/0	2/0					13.9				
12	1/0		2/0	2/0	2/0	2/0					11.3				
13	1/0		2/0	2/0	2/0	2/0					11.8				
14	1/0		2/0	2/0	2/0	2/0					11.7				
15	1/0		2/0	2/0	2/0	2/0					11.4				
16	1/0		2/0	2/0	2/0	2/0					9.9				
17	1/0		2/0	2/0	2/0	2/0			< 2		11.3				
18	1/0		2/0	2/0	2/0	2/0					13.5				
19	1/0		2/0	2/0	2/0	2/0					13.0				
20	1/0		2/0	2/0	2/0	2/0					11.8				
21	1/0		2/0	2/0	2/0	2/0					10.7				
22	1/0		2/0	2/0	2/0	2/0					10.6				
23	1/0		2/0	2/0	2/0	2/0					10.9				
24	1/0		2/0	2/0	2/0	2/0					13.1				
25	1/0		2/0	2/0	2/0	2/0					12.4				
26	1/0		2/0	2/0	2/0	2/0					12.8				
27	1/0		2/0	2/0	2/0	2/0					14.1				
28	1/0		2/0	2/0	2/0	2/0					11.0				
29	1/0		2/0	2/0	2/0	2/0					10.7				
30	1/0		2/0	2/0	2/0	2/0					10.3				
31	1/0		2/0	2/0	2/0	2/0					10.4				
											12.1				
											15.2				
											9.9				



ROUTINE POSITIVE DISTRIBUTION SAMPLES

Total number of positive routine samples:				Total Coliform: <u>0</u>		Fecal Coliform: <u>0</u>	
Date	Monitoring Station	Total Coliform	Fecal Coliform	Date	Retest of Station, Upstream & Downstream	Total Coliform	Fecal Coliform
Total number of routine distribution samples analyzed:				155			
Total number of routine distribution samples required:				100			