

**Summary of
Michigan Department of Environment, Great Lakes, and Energy
Actions in Response to the
United States Environmental Protection Agency
Emergency Administrative Order
Updated: 4/29/2019**

EXECUTIVE SUMMARY:

The United States Environmental Protection Agency (USEPA) Emergency Administrative Order contains 15 overall items to be addressed by the Michigan Department of Environment, Great Lakes, and Energy (EGLE). This update includes status only on items for which progress was made in the last week. It is anticipated that the next update to this summary will be provided on Monday, May 6, 2019.

Paragraph 57 – 60: chlorine residuals, corrosion control and new water source

- During the 04/25/2019 Order Update call, the city of Flint (City) stated that chlorine residuals are generally good throughout the City and that they would install flushers in an area where residents have mentioned an issue.
- On 04/25/2019, EGLE sent a letter to the City approving the new source water treatment plan and water treatment modification plan. The letter also stated that the corrosion control studies were also approved.
- During the 04/25/2019 Order Update call, the City reported that the corrosion control study is moving forward; the phase 2 faucets are installed and some of the pipes have been installed.

Paragraph 61: necessary, capable and qualified personnel

- During the 04/25/2019 Order Update call, the City reported that in response to the posting of water distribution plant trainee positions in February, they received 17 applicants; 13 of which met the requirements and will be taking an exam on 05/2/2019.

Paragraph 62: optimization plan

- As of the 04/25/2019 Order Update call:
 - The City had scheduled a 50% design meeting on 05/6/2019 for the chemical feed building.
 - The Kearsley Street water main replacement was largely complete; the last tie-ins were planned to be completed in the next week or so.
 - The order was shipped for some of the water meters and the City had three proposals for installing the meters, which staff were reviewing.

- The City was nearing completion of the request for proposals for water quality monitoring.